

Lab. št.	Datum odvzema	Območje	Parameter	Rezultat	Enota
2023/10584	03.01.2024 10:20:00	C2 - Brest	Klor - prosti (na terenu)	0,15	mg/L
2023/10584	03.01.2024 10:20:00	C2 - Brest	Temperatura (na terenu)	10,6	°C
2023/10584	03.01.2024 10:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2023/10584	03.01.2024 10:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2023/10584	03.01.2024 10:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2023/10584	03.01.2024 10:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2023/10583	03.01.2024 10:35:00	C2 - Brest	Prosti klordioksid (na terenu)	0,18	mg/L
2023/10583	03.01.2024 10:35:00	C2 - Brest	Temperatura (na terenu)	11,6	°C
2023/10583	03.01.2024 10:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2023/10583	03.01.2024 10:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2023/10583	03.01.2024 10:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2023/10583	03.01.2024 10:35:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/56	05.01.2024 10:00:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/56	05.01.2024 10:00:00	C2 - Brest	Temperatura (na terenu)	14,9	°C
2024/56	05.01.2024 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/56	05.01.2024 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/56	05.01.2024 10:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/56	05.01.2024 10:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/57	05.01.2024 10:20:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/57	05.01.2024 10:20:00	C2 - Brest	Temperatura (na terenu)	10,8	°C
2024/57	05.01.2024 10:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/57	05.01.2024 10:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/57	05.01.2024 10:20:00	C2 - Brest	Število kolonij pri 36°C	35	cfu/mL
2024/57	05.01.2024 10:20:00	C2 - Brest	Število kolonij pri 22°C	19	cfu/mL
2024/284	12.01.2024 10:10:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/284	12.01.2024 10:10:00	C2 - Brest	Temperatura (na terenu)	9,6	°C
2024/284	12.01.2024 10:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/284	12.01.2024 10:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/284	12.01.2024 10:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/284	12.01.2024 10:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/285	12.01.2024 10:35:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/285	12.01.2024 10:35:00	C2 - Brest	Temperatura (na terenu)	9	°C
2024/285	12.01.2024 10:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/285	12.01.2024 10:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/285	12.01.2024 10:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/285	12.01.2024 10:35:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/283	12.01.2024 10:55:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/283	12.01.2024 10:55:00	C2 - Brest	Temperatura (na terenu)	12,2	°C
2024/283	12.01.2024 10:55:00	C2 - Brest	Pseudomonas aeruginosa	0	cfu/100mL
2024/283	12.01.2024 10:55:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/283	12.01.2024 10:55:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/283	12.01.2024 10:55:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/283	12.01.2024 10:55:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/339	15.01.2024 09:10:00	C2 - Brest	Vonj	brez	-
2024/339	15.01.2024 09:10:00	C2 - Brest	Vidne nečistoče	brez	-
2024/313	15.01.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/339	15.01.2024 09:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/339	15.01.2024 09:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/339	15.01.2024 09:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/339	15.01.2024 09:10:00	C2 - Brest	Električna prevodnost (20°C)	453	uS/cm
2024/339	15.01.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	10,1	°C
2024/313	15.01.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	10,1	°C
2024/339	15.01.2024 09:10:00	C2 - Brest	pH-vrednost	7,5	-
2024/313	15.01.2024 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/313	15.01.2024 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/313	15.01.2024 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/313	15.01.2024 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/339	15.01.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/339	15.01.2024 09:10:00	C2 - Brest	Celotni organski ogljik (TOC)	0,3	mg/L
2024/339	15.01.2024 09:10:00	C2 - Brest	Absorbanca-barva	0,0002	
2024/339	15.01.2024 09:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1

2024/526	22.01.2024 09:15:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/526	22.01.2024 09:15:00	C2 - Brest	Temperatura (na terenu)	10,9	°C
2024/526	22.01.2024 09:15:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/526	22.01.2024 09:15:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/526	22.01.2024 09:15:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/526	22.01.2024 09:15:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/527	22.01.2024 11:04:22	C2 - Brest	Klor - prosti (na terenu)	0,05	mg/L
2024/527	22.01.2024 11:04:22	C2 - Brest	Temperatura (na terenu)	10,1	°C
2024/527	22.01.2024 11:04:22	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/527	22.01.2024 11:04:22	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/527	22.01.2024 11:04:22	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/527	22.01.2024 11:04:22	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/620	24.01.2024 07:30:00	C2 - Brest	Vonj	brez	-
2024/620	24.01.2024 07:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/601	24.01.2024 07:30:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/620	24.01.2024 07:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/620	24.01.2024 07:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/620	24.01.2024 07:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/620	24.01.2024 07:30:00	C2 - Brest	Električna prevodnost (20°C)	444	uS/cm
2024/620	24.01.2024 07:30:00	C2 - Brest	Temperatura (na terenu)	8,5	°C
2024/601	24.01.2024 07:30:00	C2 - Brest	Temperatura (na terenu)	8,5	°C
2024/620	24.01.2024 07:30:00	C2 - Brest	pH-vrednost	7,7	-
2024/601	24.01.2024 07:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/601	24.01.2024 07:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/601	24.01.2024 07:30:00	C2 - Brest	Število kolonij pri 36°C	17	cfu/mL
2024/601	24.01.2024 07:30:00	C2 - Brest	Število kolonij pri 22°C	24	cfu/mL
2024/620	24.01.2024 07:30:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/620	24.01.2024 07:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,41	mg/L
2024/620	24.01.2024 07:30:00	C2 - Brest	Absorbanca-barva	0	
2024/620	24.01.2024 07:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/706	29.01.2024 09:50:00	C2 - Brest	Vonj	brez	-
2024/706	29.01.2024 09:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/706	29.01.2024 09:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/706	29.01.2024 09:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/706	29.01.2024 09:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/706	29.01.2024 09:50:00	C2 - Brest	Električna prevodnost (20°C)	443	uS/cm
2024/706	29.01.2024 09:50:00	C2 - Brest	Temperatura (na terenu)	9	°C
2024/706	29.01.2024 09:50:00	C2 - Brest	pH-vrednost	7,8	-
2024/706	29.01.2024 09:50:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/706	29.01.2024 09:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,35	mg/L
2024/706	29.01.2024 09:50:00	C2 - Brest	Absorbanca-barva	0,0004	
2024/706	29.01.2024 09:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/715	29.01.2024 09:50:34	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/715	29.01.2024 09:50:34	C2 - Brest	Temperatura (na terenu)	9	°C
2024/715	29.01.2024 09:50:34	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/715	29.01.2024 09:50:34	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/715	29.01.2024 09:50:34	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/715	29.01.2024 09:50:34	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/745	30.01.2024 08:40:00	C2 - Brest	Vonj	brez	-
2024/745	30.01.2024 08:40:00	C2 - Brest	Vidne nečistoče	brez	-
2024/759	30.01.2024 08:40:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/745	30.01.2024 08:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/745	30.01.2024 08:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/745	30.01.2024 08:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/745	30.01.2024 08:40:00	C2 - Brest	Električna prevodnost (20°C)	445	uS/cm
2024/745	30.01.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	17,5	°C
2024/759	30.01.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	17,5	°C
2024/745	30.01.2024 08:40:00	C2 - Brest	pH-vrednost	7,7	-
2024/759	30.01.2024 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/759	30.01.2024 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/759	30.01.2024 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/759	30.01.2024 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL

2024/745	30.01.2024 08:40:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/745	30.01.2024 08:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,29	mg/L
2024/745	30.01.2024 08:40:00	C2 - Brest	Absorbanca-barva	0,0005	
2024/745	30.01.2024 08:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/758	30.01.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	0,05	mg/L
2024/758	30.01.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	10,6	°C
2024/758	30.01.2024 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/758	30.01.2024 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/758	30.01.2024 09:10:00	C2 - Brest	Število kolonij pri 36°C	38	cfu/mL
2024/758	30.01.2024 09:10:00	C2 - Brest	Število kolonij pri 22°C	20	cfu/mL
2024/743	30.01.2024 09:40:00	C2 - Brest	Vonj	brez	-
2024/743	30.01.2024 09:40:00	C2 - Brest	Vidne nečistoče	brez	-
2024/743	30.01.2024 09:40:00	C2 - Brest	Prosti klordioksid (na terenu)	0,22	mg/L
2024/756	30.01.2024 09:40:00	C2 - Brest	Prosti klordioksid (na terenu)	0,22	mg/L
2024/743	30.01.2024 09:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/743	30.01.2024 09:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/743	30.01.2024 09:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/743	30.01.2024 09:40:00	C2 - Brest	Električna prevodnost (20°C)	439	uS/cm
2024/743	30.01.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	11,3	°C
2024/756	30.01.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	11,3	°C
2024/743	30.01.2024 09:40:00	C2 - Brest	pH-vrednost	7,5	-
2024/756	30.01.2024 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/756	30.01.2024 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/756	30.01.2024 09:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/756	30.01.2024 09:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/743	30.01.2024 09:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,42	mg/L
2024/743	30.01.2024 09:40:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/743	30.01.2024 09:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/744	30.01.2024 09:50:00	C2 - Brest	Vonj	brez	-
2024/744	30.01.2024 09:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/757	30.01.2024 09:50:00	C2 - Brest	Klor - prosti (na terenu)	0,15	mg/L
2024/744	30.01.2024 09:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/744	30.01.2024 09:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/744	30.01.2024 09:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/744	30.01.2024 09:50:00	C2 - Brest	Električna prevodnost (20°C)	434	uS/cm
2024/744	30.01.2024 09:50:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/757	30.01.2024 09:50:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/744	30.01.2024 09:50:00	C2 - Brest	pH-vrednost	7,5	-
2024/757	30.01.2024 09:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/757	30.01.2024 09:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/757	30.01.2024 09:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/757	30.01.2024 09:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/744	30.01.2024 09:50:00	C2 - Brest	Klor - prosti (na terenu)	0,15	mg/L
2024/744	30.01.2024 09:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,41	mg/L
2024/744	30.01.2024 09:50:00	C2 - Brest	Absorbanca-barva	0,0004	
2024/744	30.01.2024 09:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/855	02.02.2024 10:20:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/855	02.02.2024 10:20:00	C2 - Brest	Temperatura (na terenu)	9,6	°C
2024/855	02.02.2024 10:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/855	02.02.2024 10:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/855	02.02.2024 10:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/855	02.02.2024 10:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/910	05.02.2024 08:20:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/910	05.02.2024 08:20:00	C2 - Brest	Temperatura (na terenu)	8,9	°C
2024/910	05.02.2024 08:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/910	05.02.2024 08:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/910	05.02.2024 08:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/910	05.02.2024 08:20:00	C2 - Brest	Število kolonij pri 22°C	13	cfu/mL
2024/890	05.02.2024 08:40:00	C2 - Brest	Vonj	brez	-
2024/890	05.02.2024 08:40:00	C2 - Brest	Vidne nečistoče	brez	-
2024/912	05.02.2024 08:40:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/890	05.02.2024 08:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L

2024/890	05.02.2024 08:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/890	05.02.2024 08:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/890	05.02.2024 08:40:00	C2 - Brest	Električna prevodnost (20°C)	440	uS/cm
2024/890	05.02.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	8,5	°C
2024/912	05.02.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	8,5	°C
2024/890	05.02.2024 08:40:00	C2 - Brest	pH-vrednost	7,8	-
2024/912	05.02.2024 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/912	05.02.2024 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/912	05.02.2024 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/912	05.02.2024 08:40:00	C2 - Brest	Število kolonij pri 22°C	13	cfu/mL
2024/890	05.02.2024 08:40:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/890	05.02.2024 08:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,28	mg/L
2024/890	05.02.2024 08:40:00	C2 - Brest	Absorbanca-barva	0,0002	
2024/890	05.02.2024 08:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/891	05.02.2024 09:00:00	C2 - Brest	Vonj	brez	-
2024/891	05.02.2024 09:00:00	C2 - Brest	Vidne nečistoče	brez	-
2024/913	05.02.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/891	05.02.2024 09:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/891	05.02.2024 09:00:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/891	05.02.2024 09:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/891	05.02.2024 09:00:00	C2 - Brest	Električna prevodnost (20°C)	441	uS/cm
2024/891	05.02.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	9,5	°C
2024/913	05.02.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	9,5	°C
2024/891	05.02.2024 09:00:00	C2 - Brest	pH-vrednost	7,8	-
2024/913	05.02.2024 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/913	05.02.2024 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/913	05.02.2024 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/913	05.02.2024 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/891	05.02.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/891	05.02.2024 09:00:00	C2 - Brest	Celotni organski ogljik (TOC)	0,29	mg/L
2024/891	05.02.2024 09:00:00	C2 - Brest	Absorbanca-barva	0,0008	
2024/891	05.02.2024 09:00:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/889	05.02.2024 09:20:00	C2 - Brest	Vonj	brez	-
2024/889	05.02.2024 09:20:00	C2 - Brest	Vidne nečistoče	brez	-
2024/911	05.02.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/889	05.02.2024 09:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/889	05.02.2024 09:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/889	05.02.2024 09:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/889	05.02.2024 09:20:00	C2 - Brest	Električna prevodnost (20°C)	391	uS/cm
2024/889	05.02.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	16,6	°C
2024/911	05.02.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	16,6	°C
2024/889	05.02.2024 09:20:00	C2 - Brest	pH-vrednost	7,9	-
2024/911	05.02.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/911	05.02.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/911	05.02.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	19	cfu/mL
2024/911	05.02.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/889	05.02.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/889	05.02.2024 09:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,84	mg/L
2024/889	05.02.2024 09:20:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/889	05.02.2024 09:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/909	05.02.2024 09:40:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/909	05.02.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	10,3	°C
2024/909	05.02.2024 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/909	05.02.2024 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/909	05.02.2024 09:40:00	C2 - Brest	Število kolonij pri 36°C	28	cfu/mL
2024/909	05.02.2024 09:40:00	C2 - Brest	Število kolonij pri 22°C	26	cfu/mL
2024/949	06.02.2024 10:15:00	C2 - Brest	Vonj	brez	-
2024/949	06.02.2024 10:15:00	C2 - Brest	Vidne nečistoče	brez	-
2024/960	06.02.2024 10:15:00	C2 - Brest	Klor - prosti (na terenu)	0,1	mg/L
2024/949	06.02.2024 10:15:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/949	06.02.2024 10:15:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/949	06.02.2024 10:15:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L

2024/949	06.02.2024 10:15:00	C2 - Brest	Električna prevodnost (20°C)	401	uS/cm
2024/949	06.02.2024 10:15:00	C2 - Brest	Temperatura (na terenu)	10,7	°C
2024/960	06.02.2024 10:15:00	C2 - Brest	Temperatura (na terenu)	10,7	°C
2024/949	06.02.2024 10:15:00	C2 - Brest	pH-vrednost	7,6	-
2024/960	06.02.2024 10:15:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/960	06.02.2024 10:15:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/960	06.02.2024 10:15:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/960	06.02.2024 10:15:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/949	06.02.2024 10:15:00	C2 - Brest	Klor - prosti (na terenu)	0,1	mg/L
2024/949	06.02.2024 10:15:00	C2 - Brest	Celotni organski ogljik (TOC)	0,25	mg/L
2024/949	06.02.2024 10:15:00	C2 - Brest	Absorbanca-barva	0,0013	
2024/949	06.02.2024 10:15:00	C2 - Brest	Barva (436 nm)	0,03	m-1
2024/948	06.02.2024 11:00:00	C2 - Brest	Vonj	brez	-
2024/948	06.02.2024 11:00:00	C2 - Brest	Vidne nečistoče	brez	-
2024/948	06.02.2024 11:00:00	C2 - Brest	Prosti klordioksid (na terenu)	0,2	mg/L
2024/958	06.02.2024 11:00:00	C2 - Brest	Prosti klordioksid (na terenu)	0,2	mg/L
2024/948	06.02.2024 11:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/948	06.02.2024 11:00:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/948	06.02.2024 11:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/948	06.02.2024 11:00:00	C2 - Brest	Električna prevodnost (20°C)	556	uS/cm
2024/948	06.02.2024 11:00:00	C2 - Brest	Temperatura (na terenu)	11,6	°C
2024/958	06.02.2024 11:00:00	C2 - Brest	Temperatura (na terenu)	11,6	°C
2024/948	06.02.2024 11:00:00	C2 - Brest	pH-vrednost	7,3	-
2024/958	06.02.2024 11:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/958	06.02.2024 11:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/958	06.02.2024 11:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/958	06.02.2024 11:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/948	06.02.2024 11:00:00	C2 - Brest	Celotni organski ogljik (TOC)	0,65	mg/L
2024/948	06.02.2024 11:00:00	C2 - Brest	Absorbanca-barva	0,00215	
2024/948	06.02.2024 11:00:00	C2 - Brest	Barva (436 nm)	0,04	m-1
2024/1116	13.02.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/1116	13.02.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	19,2	°C
2024/1116	13.02.2024 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/1116	13.02.2024 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/1116	13.02.2024 08:30:00	C2 - Brest	Število kolonij pri 36°C	11	cfu/mL
2024/1116	13.02.2024 08:30:00	C2 - Brest	Število kolonij pri 22°C	14	cfu/mL
2024/1072	13.02.2024 12:11:44	C2 - Brest	Perfluorooktanojska kislina	<0.0005	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Oksadiazon	<0.005	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Molibden	0,15	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Zoksamid	<0.01	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Tribenuron-metil	<0.06	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Triatlat	<0.004	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Tiofanat-metil	<0.06	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Mandipropamid	<0.01	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Karbendazim	<0.010	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Jodosulfuron	<0.005	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Glufosinat-amonijeva sol	<0.2	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Hidrogenkarbonat	287	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Flutriafol	<0.010	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Cimoksanil	<0.01	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Aminometil fosfonska kislina	<0.09	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	5-metil-1H-benzotriazol	<0.004	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	4-metil-1H-benzotriazol	<0.004	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	1-metil-1H-benzotriazol	<0.004	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	1H-benzotriazol	0,022	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Tepraloksidim	<0.01	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Silicij (SiO2)	2,4	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Mangan	0,36	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	m,p-Ksilen	<0.3	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Primisulfuron-metil	<0.014	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Perfluorooktansulfonska kislina	<0.0005	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	m- alkaliteta	4,7	mmol/L

2024/1072	13.02.2024 12:11:44	C2 - Brest	Bromat	<3	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Adsorbljivi organski halogeni (AOX)	<6	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	1,1,1-trikloroetan	<0.4	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	o-ksilen	<0.3	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Etilbenzen	<0.3	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Toluen	<0.3	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Tetraklorometan	<0.4	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Diklorometan	<0.6	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	1,1,2,2-tetrakloroetan	<0.5	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	1,1,2-trikloroetan	<0.7	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	1,1-dikloroeten	<0.4	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	1,1-dikloroetan	<0.4	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Dietiltoluamid (DEET)	<0.01	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Fenuron	<0.008	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	kvinoksifen	<0.009	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Cibutrin	<0.0025	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Bifenoks	<0.009	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Aklonifen	<0.009	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Heksakloroetan	<0.4	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Klorpirifos (klorpirifos-etil)	<0.002	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Ortofosfat PO4	<0.006	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Barva (436 nm)	<0.2	m-1
2024/1072	13.02.2024 12:11:44	C2 - Brest	Glifosat	<0.09	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Železo (preračun v ug/L)	<40	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/1072	13.02.2024 12:11:44	C2 - Brest	Diuron	<0.007	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Diklorfos	<0.003	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Dikamba	<0.05	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Bentazon	<0.012	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/1072	13.02.2024 12:11:44	C2 - Brest	Intestinalni enterokoki	0	cfu/100mL
2024/1072	13.02.2024 12:11:44	C2 - Brest	Clostridium perfringens s sporami	0	cfu/100mL
2024/1072	13.02.2024 12:11:44	C2 - Brest	Amidosulfuron	<0.013	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	vsota nitrat/50+nitrit/3	0,279	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Klorat	<0.05	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Klorit	<0.05	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Trihalometani (vsota)	<0.5	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Tritosulfuron	<0.004	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Triasulfuron	<0.010	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Sebutilazin	<0.008	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Prosulfuron	<0.007	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Propikonazol	<0.002	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Petoksamid	<0.021	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Nikosulfuron	<0.013	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Monuron	<0.010	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Monolinuron	<0.009	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Mezotrion	<0.006	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Mezosulfuron	<0.005	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Metolaklor-OXA	<0.015	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Metolaklor-ESA	<0.017	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Metoksuron	<0.009	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Metobromuron	<0.009	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Metamitron	<0.005	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Metalaksil	<0.001	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	MCPP	<0.013	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	MCPB	<0.022	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	MCPA	<0.013	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Malation	<0.006	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Linuron	<0.009	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Kloridazon	<0.004	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Klorbromuron	<0.011	ug/L

2024/1072	13.02.2024 12:11:44	C2 - Brest	Klomazon	<0.005	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Foramsulfuron	<0.014	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Bromacil	<0.008	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	2,4-DP	<0.020	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	2,4-D	<0.015	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	2,4,5-T	<0.010	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	2,4-DB	<0.016	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Okus	brez posebnosti	-
2024/1072	13.02.2024 12:11:44	C2 - Brest	pH vrednost (na terenu)	7,4	-
2024/1072	13.02.2024 12:11:44	C2 - Brest	Skupna trdota (izračun)	14,4	°N
2024/1072	13.02.2024 12:11:44	C2 - Brest	Tribromometan	<0.5	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Temperatura (na terenu)	9,5	°C
2024/1072	13.02.2024 12:11:44	C2 - Brest	Nikelj	<0.1	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Kloroform	<0.4	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Električna prevodnost (20°C, na terenu)	449	uS/cm
2024/1072	13.02.2024 12:11:44	C2 - Brest	Dibromoklorometan	<0.3	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Bromodiklorometan	<0.3	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Aluminij	<0.9	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Izoproturon	<0.008	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Klorfenvinfos	<0.002	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Atrazin	<0.007	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Nitrat	13,9	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Magnezij	17	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Kalcij	75	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Kalij	1	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Tetrakloroeten	<0.5	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Vonj	brez posebnosti	-
2024/1072	13.02.2024 12:11:44	C2 - Brest	Sulfat	9,98	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Natrij	5	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Trikloroeten	<0.5	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Motnost	0,21	NTU
2024/1072	13.02.2024 12:11:44	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/1072	13.02.2024 12:11:44	C2 - Brest	Klorid	7,45	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Amonij NH4+	<0.01	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Celotni organski ogljik (TOC)	<0.3	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Tetrakloroeten in trikloroeten (vsota)	<0.5	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Živo srebro	<0.01	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Selen	0,11	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Svinec	<0.1	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Nitrit NO2-	0,0015	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Krom	0,47	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Krom-šestvalentni	<10	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Kadmij	<0.02	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Fluorid	0,042	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	1,2-dikloroetan	<0.4	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Bor	0,015	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Benzen	<0.3	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Baker	0,0017	mg/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Arzen	<0.1	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Antimon	<0.05	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/1072	13.02.2024 12:11:44	C2 - Brest	Terbutrin	<0.013	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	2,6-diklorobenzamid	<0.006	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Terbutilazin	<0.015	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Simazin	<0.009	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Propazin	<0.009	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Prometrin	<0.010	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Pesticidi (vsota)	<0.05	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Metribuzin	<0.010	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Metolaklor	<0.011	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Klortoluron	<0.009	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Metazaklor	<0.008	ug/L

2024/1072	13.02.2024 12:11:44	C2 - Brest	Dimetenamid	<0.001	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Desizopropilatrazin	<0.003	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Desetilatrazin	<0.009	ug/L
2024/1072	13.02.2024 12:11:44	C2 - Brest	Desetilterbutilazin	<0.004	ug/L
2024/1232	16.02.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/1232	16.02.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	13,1	°C
2024/1232	16.02.2024 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/1232	16.02.2024 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/1232	16.02.2024 09:00:00	C2 - Brest	Število kolonij pri 36°C	74	cfu/mL
2024/1232	16.02.2024 09:00:00	C2 - Brest	Število kolonij pri 22°C	14	cfu/mL
2024/1294	20.02.2024 11:35:00	C2 - Brest	Vonj	brez	-
2024/1294	20.02.2024 11:35:00	C2 - Brest	Vidne nečistoče	brez	-
2024/1299	20.02.2024 11:35:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/1294	20.02.2024 11:35:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/1294	20.02.2024 11:35:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/1294	20.02.2024 11:35:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/1294	20.02.2024 11:35:00	C2 - Brest	Električna prevodnost (20°C)	451	uS/cm
2024/1294	20.02.2024 11:35:00	C2 - Brest	Temperatura (na terenu)	12	°C
2024/1299	20.02.2024 11:35:00	C2 - Brest	Temperatura (na terenu)	12	°C
2024/1294	20.02.2024 11:35:00	C2 - Brest	pH-vrednost	7,6	-
2024/1299	20.02.2024 11:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/1299	20.02.2024 11:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/1299	20.02.2024 11:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/1299	20.02.2024 11:35:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/1294	20.02.2024 11:35:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/1294	20.02.2024 11:35:00	C2 - Brest	Celotni organski ogljik (TOC)	0,44	mg/L
2024/1294	20.02.2024 11:35:00	C2 - Brest	Absorbanca-barva	0,0006	
2024/1294	20.02.2024 11:35:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/1393	22.02.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0,12	mg/L
2024/1393	22.02.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	11	°C
2024/1393	22.02.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/1393	22.02.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/1393	22.02.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/1393	22.02.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/1392	22.02.2024 10:00:00	C2 - Brest	Prosti klordioksid (na terenu)	0,22	mg/L
2024/1392	22.02.2024 10:00:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/1392	22.02.2024 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/1392	22.02.2024 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/1392	22.02.2024 10:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/1392	22.02.2024 10:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/1562	28.02.2024 11:10:00	C2 - Brest	Vonj	brez	-
2024/1562	28.02.2024 11:10:00	C2 - Brest	Vidne nečistoče	brez	-
2024/1560	28.02.2024 11:10:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/1562	28.02.2024 11:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/1562	28.02.2024 11:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/1562	28.02.2024 11:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/1562	28.02.2024 11:10:00	C2 - Brest	Nitratni dušik	1,7	mg/L
2024/1562	28.02.2024 11:10:00	C2 - Brest	Električna prevodnost (20°C)	422	uS/cm
2024/1562	28.02.2024 11:10:00	C2 - Brest	Temperatura (na terenu)	10,2	°C
2024/1560	28.02.2024 11:10:00	C2 - Brest	Temperatura (na terenu)	10,2	°C
2024/1562	28.02.2024 11:10:00	C2 - Brest	pH-vrednost	7,7	-
2024/1560	28.02.2024 11:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/1560	28.02.2024 11:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/1560	28.02.2024 11:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/1560	28.02.2024 11:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/1562	28.02.2024 11:10:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/1562	28.02.2024 11:10:00	C2 - Brest	Nitrat	7,53	mg/L
2024/1562	28.02.2024 11:10:00	C2 - Brest	Celotni organski ogljik (TOC)	0,49	mg/L
2024/1562	28.02.2024 11:10:00	C2 - Brest	Absorbanca-barva	0,0004	
2024/1562	28.02.2024 11:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/1619	29.02.2024 07:50:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/1619	29.02.2024 07:50:00	C2 - Brest	Temperatura (na terenu)	8,8	°C

2024/1619	29.02.2024 07:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/1619	29.02.2024 07:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/1619	29.02.2024 07:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/1619	29.02.2024 07:50:00	C2 - Brest	Število kolonij pri 22°C	28	cfu/mL
2024/1618	29.02.2024 08:10:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/1618	29.02.2024 08:10:00	C2 - Brest	Temperatura (na terenu)	17,4	°C
2024/1618	29.02.2024 08:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/1618	29.02.2024 08:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/1618	29.02.2024 08:10:00	C2 - Brest	Število kolonij pri 36°C	203	cfu/mL
2024/1618	29.02.2024 08:10:00	C2 - Brest	Število kolonij pri 22°C	151	cfu/mL
2024/1620	29.02.2024 08:40:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/1620	29.02.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	8,4	°C
2024/1620	29.02.2024 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/1620	29.02.2024 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/1620	29.02.2024 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/1620	29.02.2024 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/1636	01.03.2024 07:40:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/1636	01.03.2024 07:40:00	C2 - Brest	Temperatura (na terenu)	15,5	°C
2024/1636	01.03.2024 07:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/1636	01.03.2024 07:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/1636	01.03.2024 07:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/1636	01.03.2024 07:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/1889	08.03.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/1889	08.03.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	9,4	°C
2024/1889	08.03.2024 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/1889	08.03.2024 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/1889	08.03.2024 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/1889	08.03.2024 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/1890	08.03.2024 10:20:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/1890	08.03.2024 10:20:00	C2 - Brest	Temperatura (na terenu)	8,8	°C
2024/1890	08.03.2024 10:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/1890	08.03.2024 10:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/1890	08.03.2024 10:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/1890	08.03.2024 10:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2011	12.03.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/1990	12.03.2024 09:20:00	C2 - Brest	Nitratni dušik	1,73	mg/L
2024/1990	12.03.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	10,7	°C
2024/2011	12.03.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	10,7	°C
2024/2011	12.03.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2011	12.03.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2011	12.03.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2011	12.03.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/1990	12.03.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/1990	12.03.2024 09:20:00	C2 - Brest	Nitrat	7,66	mg/L
2024/2048	13.03.2024 08:50:00	C2 - Brest	Vonj	brez	-
2024/2048	13.03.2024 08:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2064	13.03.2024 08:50:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/2048	13.03.2024 08:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2048	13.03.2024 08:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2048	13.03.2024 08:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2048	13.03.2024 08:50:00	C2 - Brest	Električna prevodnost (20°C)	432	uS/cm
2024/2048	13.03.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	9,4	°C
2024/2064	13.03.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	9,4	°C
2024/2048	13.03.2024 08:50:00	C2 - Brest	pH-vrednost	7,5	-
2024/2064	13.03.2024 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2064	13.03.2024 08:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2064	13.03.2024 08:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2064	13.03.2024 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2048	13.03.2024 08:50:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/2048	13.03.2024 08:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,52	mg/L
2024/2048	13.03.2024 08:50:00	C2 - Brest	Absorbanca-barva	0	
2024/2048	13.03.2024 08:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1

2024/2049	13.03.2024 09:40:00	C2 - Brest	Vonj	brez	-
2024/2049	13.03.2024 09:40:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2065	13.03.2024 09:40:00	C2 - Brest	Klor - prosti (na terenu)	0,07	mg/L
2024/2049	13.03.2024 09:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2049	13.03.2024 09:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2049	13.03.2024 09:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2049	13.03.2024 09:40:00	C2 - Brest	Električna prevodnost (20°C)	408	uS/cm
2024/2049	13.03.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	11,3	°C
2024/2065	13.03.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	11,3	°C
2024/2049	13.03.2024 09:40:00	C2 - Brest	pH-vrednost	7,7	-
2024/2065	13.03.2024 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2065	13.03.2024 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2065	13.03.2024 09:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2065	13.03.2024 09:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2049	13.03.2024 09:40:00	C2 - Brest	Klor - prosti (na terenu)	0,07	mg/L
2024/2049	13.03.2024 09:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,54	mg/L
2024/2049	13.03.2024 09:40:00	C2 - Brest	Absorbanca-barva	0,0002	
2024/2049	13.03.2024 09:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/2066	13.03.2024 10:15:00	C2 - Brest	Klor - prosti (na terenu)	0,06	mg/L
2024/2066	13.03.2024 10:15:00	C2 - Brest	Temperatura (na terenu)	11,2	°C
2024/2066	13.03.2024 10:15:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2066	13.03.2024 10:15:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2066	13.03.2024 10:15:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2066	13.03.2024 10:15:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2067	13.03.2024 10:50:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/2067	13.03.2024 10:50:00	C2 - Brest	Temperatura (na terenu)	11,6	°C
2024/2067	13.03.2024 10:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2067	13.03.2024 10:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2067	13.03.2024 10:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2067	13.03.2024 10:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2102	14.03.2024 09:00:00	C2 - Brest	Vonj	brez	-
2024/2102	14.03.2024 09:00:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2109	14.03.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0,15	mg/L
2024/2102	14.03.2024 09:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2102	14.03.2024 09:00:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2102	14.03.2024 09:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2102	14.03.2024 09:00:00	C2 - Brest	Električna prevodnost (20°C)	416	uS/cm
2024/2102	14.03.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	11,1	°C
2024/2109	14.03.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	11,1	°C
2024/2102	14.03.2024 09:00:00	C2 - Brest	pH-vrednost	7,6	-
2024/2109	14.03.2024 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2109	14.03.2024 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2109	14.03.2024 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2109	14.03.2024 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2102	14.03.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0,15	mg/L
2024/2102	14.03.2024 09:00:00	C2 - Brest	Absorbanca-barva	0,0006	
2024/2102	14.03.2024 09:00:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/2101	14.03.2024 09:10:00	C2 - Brest	Vonj	brez	-
2024/2101	14.03.2024 09:10:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2101	14.03.2024 09:10:00	C2 - Brest	Prosti klordioksid (na terenu)	0,2	mg/L
2024/2107	14.03.2024 09:10:00	C2 - Brest	Prosti klordioksid (na terenu)	0,2	mg/L
2024/2101	14.03.2024 09:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2101	14.03.2024 09:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2101	14.03.2024 09:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2101	14.03.2024 09:10:00	C2 - Brest	Električna prevodnost (20°C)	605	uS/cm
2024/2101	14.03.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	11,9	°C
2024/2107	14.03.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	11,9	°C
2024/2101	14.03.2024 09:10:00	C2 - Brest	pH-vrednost	7,3	-
2024/2107	14.03.2024 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2107	14.03.2024 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2107	14.03.2024 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2107	14.03.2024 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL

2024/2101	14.03.2024 09:10:00	C2 - Brest	Absorbanca-barva	0,0008	
2024/2101	14.03.2024 09:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/2148	15.03.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/2148	15.03.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	12,4	°C
2024/2148	15.03.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2148	15.03.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2148	15.03.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2148	15.03.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2254	20.03.2024 08:45:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/2254	20.03.2024 08:45:00	C2 - Brest	Temperatura (na terenu)	11,7	°C
2024/2254	20.03.2024 08:45:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2254	20.03.2024 08:45:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2254	20.03.2024 08:45:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2254	20.03.2024 08:45:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2255	20.03.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/2255	20.03.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	11,7	°C
2024/2255	20.03.2024 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2255	20.03.2024 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2255	20.03.2024 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2255	20.03.2024 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2324	21.03.2024 09:10:00	C2 - Brest	Vonj	brez	-
2024/2324	21.03.2024 09:10:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2319	21.03.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/2324	21.03.2024 09:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2324	21.03.2024 09:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2324	21.03.2024 09:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2324	21.03.2024 09:10:00	C2 - Brest	Električna prevodnost (20°C)	441	uS/cm
2024/2324	21.03.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	13,1	°C
2024/2319	21.03.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	13,1	°C
2024/2324	21.03.2024 09:10:00	C2 - Brest	pH-vrednost	7,6	-
2024/2319	21.03.2024 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2319	21.03.2024 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2319	21.03.2024 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2319	21.03.2024 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2324	21.03.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/2324	21.03.2024 09:10:00	C2 - Brest	Absorbanca-barva	0,0005	
2024/2324	21.03.2024 09:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/2453	26.03.2024 09:23:00	C2 - Brest	Klor - prosti (na terenu)	0,13	mg/L
2024/2453	26.03.2024 09:23:00	C2 - Brest	Temperatura (na terenu)	11,1	°C
2024/2453	26.03.2024 09:23:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2453	26.03.2024 09:23:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2453	26.03.2024 09:23:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2453	26.03.2024 09:23:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2452	26.03.2024 09:44:00	C2 - Brest	Prosti klordioksid (na terenu)	0,2	mg/L
2024/2452	26.03.2024 09:44:00	C2 - Brest	Temperatura (na terenu)	11,2	°C
2024/2452	26.03.2024 09:44:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2452	26.03.2024 09:44:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2452	26.03.2024 09:44:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2452	26.03.2024 09:44:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2539	28.03.2024 08:40:00	C2 - Brest	Vonj	brez	-
2024/2539	28.03.2024 08:40:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2535	28.03.2024 08:40:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/2539	28.03.2024 08:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2539	28.03.2024 08:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2539	28.03.2024 08:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2539	28.03.2024 08:40:00	C2 - Brest	Električna prevodnost (20°C)	432	uS/cm
2024/2539	28.03.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	10,2	°C
2024/2535	28.03.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	10,2	°C
2024/2539	28.03.2024 08:40:00	C2 - Brest	pH-vrednost	7,8	-
2024/2535	28.03.2024 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2535	28.03.2024 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2535	28.03.2024 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL

2024/2535	28.03.2024 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2539	28.03.2024 08:40:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/2539	28.03.2024 08:40:00	C2 - Brest	Absorbanca-barva	0,0002	
2024/2539	28.03.2024 08:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/2540	28.03.2024 09:05:00	C2 - Brest	Vonj	brez	-
2024/2540	28.03.2024 09:05:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2536	28.03.2024 09:05:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/2540	28.03.2024 09:05:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2540	28.03.2024 09:05:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2540	28.03.2024 09:05:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2540	28.03.2024 09:05:00	C2 - Brest	Električna prevodnost (20°C)	427	uS/cm
2024/2540	28.03.2024 09:05:00	C2 - Brest	Temperatura (na terenu)	9,9	°C
2024/2536	28.03.2024 09:05:00	C2 - Brest	Temperatura (na terenu)	9,9	°C
2024/2540	28.03.2024 09:05:00	C2 - Brest	pH-vrednost	7,8	-
2024/2536	28.03.2024 09:05:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2536	28.03.2024 09:05:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2536	28.03.2024 09:05:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2536	28.03.2024 09:05:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2540	28.03.2024 09:05:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/2540	28.03.2024 09:05:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/2540	28.03.2024 09:05:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/2704	04.04.2024 08:20:00	C2 - Brest	Vonj	brez	-
2024/2704	04.04.2024 08:20:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2718	04.04.2024 08:20:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/2704	04.04.2024 08:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2704	04.04.2024 08:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2704	04.04.2024 08:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2704	04.04.2024 08:20:00	C2 - Brest	Električna prevodnost (20°C)	427	uS/cm
2024/2704	04.04.2024 08:20:00	C2 - Brest	Temperatura (na terenu)	10,3	°C
2024/2718	04.04.2024 08:20:00	C2 - Brest	Temperatura (na terenu)	10,3	°C
2024/2704	04.04.2024 08:20:00	C2 - Brest	pH-vrednost	7,8	-
2024/2718	04.04.2024 08:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2718	04.04.2024 08:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2718	04.04.2024 08:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2718	04.04.2024 08:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2704	04.04.2024 08:20:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/2704	04.04.2024 08:20:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/2704	04.04.2024 08:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/2705	04.04.2024 08:50:00	C2 - Brest	Vonj	brez	-
2024/2705	04.04.2024 08:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2719	04.04.2024 08:50:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/2705	04.04.2024 08:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2705	04.04.2024 08:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2705	04.04.2024 08:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2705	04.04.2024 08:50:00	C2 - Brest	Električna prevodnost (20°C)	428	uS/cm
2024/2705	04.04.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	10,2	°C
2024/2719	04.04.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	10,2	°C
2024/2705	04.04.2024 08:50:00	C2 - Brest	pH-vrednost	7,7	-
2024/2719	04.04.2024 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2719	04.04.2024 08:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2719	04.04.2024 08:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2719	04.04.2024 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2705	04.04.2024 08:50:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/2705	04.04.2024 08:50:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/2705	04.04.2024 08:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/2703	04.04.2024 09:10:00	C2 - Brest	Vonj	brez	-
2024/2703	04.04.2024 09:10:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2717	04.04.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/2703	04.04.2024 09:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2703	04.04.2024 09:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2703	04.04.2024 09:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2703	04.04.2024 09:10:00	C2 - Brest	Električna prevodnost (20°C)	414	uS/cm

2024/2703	04.04.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	14,3	°C
2024/2717	04.04.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	14,3	°C
2024/2703	04.04.2024 09:10:00	C2 - Brest	pH-vrednost	7,6	-
2024/2717	04.04.2024 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2717	04.04.2024 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2717	04.04.2024 09:10:00	C2 - Brest	Število kolonij pri 36°C	>300	cfu/mL
2024/2717	04.04.2024 09:10:00	C2 - Brest	Število kolonij pri 22°C	>300	cfu/mL
2024/2703	04.04.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/2703	04.04.2024 09:10:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/2703	04.04.2024 09:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/2716	04.04.2024 09:40:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/2716	04.04.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	12,1	°C
2024/2716	04.04.2024 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2716	04.04.2024 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2716	04.04.2024 09:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2716	04.04.2024 09:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2748	05.04.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/2748	05.04.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	15,5	°C
2024/2748	05.04.2024 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2748	05.04.2024 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2748	05.04.2024 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2748	05.04.2024 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2749	05.04.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/2749	05.04.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	14,7	°C
2024/2749	05.04.2024 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2749	05.04.2024 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2749	05.04.2024 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2749	05.04.2024 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2857	09.04.2024 08:30:00	C2 - Brest	Vonj	brez	-
2024/2857	09.04.2024 08:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2859	09.04.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/2857	09.04.2024 08:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2857	09.04.2024 08:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2857	09.04.2024 08:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2857	09.04.2024 08:30:00	C2 - Brest	Električna prevodnost (20°C)	410	uS/cm
2024/2857	09.04.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	15,4	°C
2024/2859	09.04.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	15,4	°C
2024/2857	09.04.2024 08:30:00	C2 - Brest	pH-vrednost	7,5	-
2024/2859	09.04.2024 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2859	09.04.2024 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2859	09.04.2024 08:30:00	C2 - Brest	Število kolonij pri 36°C	53	cfu/mL
2024/2859	09.04.2024 08:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2857	09.04.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/2857	09.04.2024 08:30:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/2857	09.04.2024 08:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/2858	09.04.2024 09:10:00	C2 - Brest	Vonj	brez	-
2024/2858	09.04.2024 09:10:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2860	09.04.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/2858	09.04.2024 09:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2858	09.04.2024 09:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2858	09.04.2024 09:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2858	09.04.2024 09:10:00	C2 - Brest	Električna prevodnost (20°C)	416	uS/cm
2024/2858	09.04.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	12,8	°C
2024/2860	09.04.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	12,8	°C
2024/2858	09.04.2024 09:10:00	C2 - Brest	pH-vrednost	7,5	-
2024/2860	09.04.2024 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2860	09.04.2024 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2860	09.04.2024 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2860	09.04.2024 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2858	09.04.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/2858	09.04.2024 09:10:00	C2 - Brest	Absorbanca-barva	0,0005	
2024/2858	09.04.2024 09:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1

2024/2934	11.04.2024 09:20:00	C2 - Brest	Vonj	brez	-
2024/2934	11.04.2024 09:20:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2939	11.04.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0,12	mg/L
2024/2934	11.04.2024 09:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2934	11.04.2024 09:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2934	11.04.2024 09:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2934	11.04.2024 09:20:00	C2 - Brest	Električna prevodnost (20°C)	412	uS/cm
2024/2934	11.04.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	11,1	°C
2024/2939	11.04.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	11,1	°C
2024/2934	11.04.2024 09:20:00	C2 - Brest	pH-vrednost	7,4	-
2024/2939	11.04.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2939	11.04.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2939	11.04.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2939	11.04.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2934	11.04.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0,12	mg/L
2024/2934	11.04.2024 09:20:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/2934	11.04.2024 09:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/2933	11.04.2024 11:15:00	C2 - Brest	Vonj	brez	-
2024/2933	11.04.2024 11:15:00	C2 - Brest	Vidne nečistoče	brez	-
2024/2933	11.04.2024 11:15:00	C2 - Brest	Prosti klordioksid (na terenu)	0,2	mg/L
2024/2938	11.04.2024 11:15:00	C2 - Brest	Prosti klordioksid (na terenu)	0,2	mg/L
2024/2933	11.04.2024 11:15:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/2933	11.04.2024 11:15:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/2933	11.04.2024 11:15:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/2933	11.04.2024 11:15:00	C2 - Brest	Električna prevodnost (20°C)	412	uS/cm
2024/2933	11.04.2024 11:15:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/2938	11.04.2024 11:15:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/2933	11.04.2024 11:15:00	C2 - Brest	pH-vrednost	7,5	-
2024/2938	11.04.2024 11:15:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/2938	11.04.2024 11:15:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2938	11.04.2024 11:15:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2938	11.04.2024 11:15:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2933	11.04.2024 11:15:00	C2 - Brest	Absorbanca-barva	0	
2024/2933	11.04.2024 11:15:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/2984	12.04.2024 10:00:00	C2 - Brest	Klor - prosti (na terenu)	0,06	mg/L
2024/2984	12.04.2024 10:00:00	C2 - Brest	Temperatura (na terenu)	14,6	°C
2024/2984	12.04.2024 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/2984	12.04.2024 10:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/2984	12.04.2024 10:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/2984	12.04.2024 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3021	15.04.2024 08:40:00	C2 - Brest	Klor - prosti (na terenu)	0,05	mg/L
2024/3021	15.04.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	14	°C
2024/3021	15.04.2024 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3021	15.04.2024 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3021	15.04.2024 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3021	15.04.2024 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3114	16.04.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0,13	mg/L
2024/3114	16.04.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	11,2	°C
2024/3114	16.04.2024 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3114	16.04.2024 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3114	16.04.2024 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3114	16.04.2024 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3113	16.04.2024 10:50:00	C2 - Brest	Prosti klordioksid (na terenu)	0,18	mg/L
2024/3113	16.04.2024 10:50:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/3113	16.04.2024 10:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3113	16.04.2024 10:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3113	16.04.2024 10:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3113	16.04.2024 10:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3146	17.04.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/3088	17.04.2024 09:30:00	C2 - Brest	Nitratri dušik	1,75	mg/L
2024/3088	17.04.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	12,3	°C
2024/3146	17.04.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	12,3	°C

2024/3088	17.04.2024 09:30:00	C2 - Brest	Tetrakloroeten	<0.5	ug/L
2024/3088	17.04.2024 09:30:00	C2 - Brest	Trikloroeten	<0.5	ug/L
2024/3146	17.04.2024 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3146	17.04.2024 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3146	17.04.2024 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3146	17.04.2024 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3088	17.04.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/3088	17.04.2024 09:30:00	C2 - Brest	Nitrat	7,75	mg/L
2024/3186	18.04.2024 07:30:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/3186	18.04.2024 07:30:00	C2 - Brest	Temperatura (na terenu)	18,6	°C
2024/3186	18.04.2024 07:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3186	18.04.2024 07:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3186	18.04.2024 07:30:00	C2 - Brest	Število kolonij pri 36°C	66	cfu/mL
2024/3186	18.04.2024 07:30:00	C2 - Brest	Število kolonij pri 22°C	39	cfu/mL
2024/3215	19.04.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0,05	mg/L
2024/3215	19.04.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	12,2	°C
2024/3215	19.04.2024 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3215	19.04.2024 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3215	19.04.2024 08:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3215	19.04.2024 08:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3216	19.04.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	0,05	mg/L
2024/3216	19.04.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	11,5	°C
2024/3216	19.04.2024 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3216	19.04.2024 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3216	19.04.2024 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3216	19.04.2024 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3217	19.04.2024 09:50:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/3217	19.04.2024 09:50:00	C2 - Brest	Temperatura (na terenu)	11,5	°C
2024/3217	19.04.2024 09:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3217	19.04.2024 09:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3217	19.04.2024 09:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3217	19.04.2024 09:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3525	03.05.2024 08:00:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/3525	03.05.2024 08:00:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/3525	03.05.2024 08:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3525	03.05.2024 08:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3525	03.05.2024 08:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3525	03.05.2024 08:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3526	03.05.2024 08:20:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/3526	03.05.2024 08:20:00	C2 - Brest	Temperatura (na terenu)	11,1	°C
2024/3526	03.05.2024 08:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3526	03.05.2024 08:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3526	03.05.2024 08:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3526	03.05.2024 08:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3658	08.05.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/3658	08.05.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	14,5	°C
2024/3658	08.05.2024 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3658	08.05.2024 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3658	08.05.2024 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3658	08.05.2024 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3664	08.05.2024 11:30:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/3664	08.05.2024 11:30:00	C2 - Brest	Temperatura (na terenu)	14,8	°C
2024/3664	08.05.2024 11:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3664	08.05.2024 11:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3664	08.05.2024 11:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3664	08.05.2024 11:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3690	09.05.2024 09:50:00	C2 - Brest	Klor - prosti (na terenu)	0,07	mg/L
2024/3690	09.05.2024 09:50:00	C2 - Brest	Temperatura (na terenu)	14,4	°C
2024/3690	09.05.2024 09:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3690	09.05.2024 09:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3690	09.05.2024 09:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3690	09.05.2024 09:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL

2024/3608	09.05.2024 10:55:31	C2 - Brest	3,5-Dimetilfenol	<0.03	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	2-Nitrofenol	<0.03	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	2-Metoksifenol	<0.03	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	2-Metilfenol	<0.03	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	2-Metil-4,6-dinitrofenol	<0.06	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	2-Klorofenol	<0.03	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	2,4-Dinitrofenol	<0.2	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	2,4-Dimetilfenol	<0.03	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	2,4-Diklorofenol	<0.03	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	2,4,6-Triklorofenol	<0.03	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	1-metil-1H-benzotriazol	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Železo (preračun v ug/L)	<40	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Zoksamid	<0.01	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Tribenuron-metil	<0.06	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Trialat	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Tiofanat-metil	<0.06	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Tepraloksidim	<0.01	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Salicilna kislina	<0.03	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Perfluorooktansulfonska kislina	<0.0005	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Perfluorooktanojska kislina	<0.0005	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Oksadiazon	<0.005	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Mandipropamid	<0.01	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Karbendazim	<0.01	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Jodosulfuron	<0.005	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Glufosinat-amonijeva sol	<0.2	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Flutriafol	<0.01	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Cimoksanil	<0.01	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Butilhidroksitoluen	<300	ng/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Aminometil fosfonska kislina	<0.09	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	4-Nitrofenol	<0.06	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	4-Kloro-3-metilfenol	<0.03	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	3-Metilfenol + 4-Metilfenol	<0.06	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	4-(1,1,3,3-Tetrametilbutil)fenol monoetoksilat	<0.005	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Triklosan	<0.03	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Paracetamol	<0.010	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Naproksen	<0.009	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Gemfibrozil	<0.005	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Di-n-oktil ftalat	<0.24	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Etinilestradiol	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Estriol	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	5-metil-1H-benzotriazol	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	4-metil-1H-benzotriazol	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	1H-benzotriazol	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Estron	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Estradiol	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	4-Nonilfenol monoetoksilat	<0.03	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	4-Nonilfenol	<0.1	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Bisfenol A	<0.01	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	4-Nonilfenol dietoksilat	<0.06	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	4-(1,1,3,3-tetrametilbutil)fenol	<0.006	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3608	09.05.2024 10:55:31	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3608	09.05.2024 10:55:31	C2 - Brest	Bromat	<3	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Dinonil ftalat	<0.24	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Dietil ftalat	<0.24	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Dibutil ftalat	<0.24	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Di-(2-etilheksil)-ftalat	<0.24	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Benzil butil ftalat	<0.24	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Teofilin	<0.02	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Testosteron	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Sulfametoksazol	<0.006	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Ketoprofen	<0.005	ug/L

2024/3608	09.05.2024 10:55:31	C2 - Brest	Indometacin	<0.005	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Fenoterol	<0.003	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Diklofenak	<0.012	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Bezafibrat	<0.006	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Betaksolol	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Metoprolol	<0.005	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Trimetoprim	<0.006	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Sulfamerazin	<0.010	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Fenuron	<0.008	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Cibutrin	<0.0025	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Bifenoks	<0.009	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Aklonifen	<0.009	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Dietiltoluamid (DEET)	<0.01	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	kvinoksifen	<0.009	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	1,1,2-trikloroetan	<0.7	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	1,1-dikloroeten	<0.4	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Ortofosfat PO4	0,028	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Klorpirifos (klorpirifos-etil)	<0.002	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	1,1-dikloroetan	<0.4	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Svinec	<0.1	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Sulfat	3,97	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Simazin	<0.009	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Silicij (SiO2)	1,8	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Selen	0,11	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Propazin	<0.009	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Prometrin	<0.010	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Metolaklor-OXA	<0.015	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Benzo(g,h,i)perilen	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Benzo(b)fluoranten	<0.005	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Adsorbljivi organski halogeni (AOX)	16	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	1,1,2,2-tetrakloroetan	<0.5	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Nitrit NO2-	0,0062	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Nikelj	<0.1	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Natrij	1,1	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Motnost	0,12	NTU
2024/3608	09.05.2024 10:55:31	C2 - Brest	Molibden	0,16	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Metolaklor	<0.011	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Metazaklor	<0.008	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Mangan	1,9	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Magnezij	29	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Intestinalni enterokoki	0	cfu/100mL
2024/3608	09.05.2024 10:55:31	C2 - Brest	Nitrat	7,17	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Metribuzin	<0.010	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	pH vrednost (na terenu)	7,3	-
2024/3608	09.05.2024 10:55:31	C2 - Brest	Diklorometan	<0.6	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Dibromoklorometan	0,7	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Desizopropilatrazin	<0.003	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Desetilterbutilazin	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Desetilatrazin	0,059	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Krom	0,47	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Metolaklor-ESA	<0.017	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Metoksuron	<0.009	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Metobromuron	<0.009	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Bromodiklorometan	0,6	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Bor	0,0037	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Metamitron	<0.005	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Metalaksil	<0.001	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Benzo(k)fluoranten	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Benzo(a)piren	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Benzen	<0.3	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Barva (436 nm)	<0.2	m-1
2024/3608	09.05.2024 10:55:31	C2 - Brest	MCPP	<0.013	ug/L

2024/3608	09.05.2024 10:55:31	C2 - Brest	MCPB	<0.022	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Baker	0,0007	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Atrazin	<0.007	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	MCPA	<0.013	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Arzen	0,18	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Antimon	<0.05	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Malation	<0.006	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Linuron	<0.009	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Kloridazon	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Amonij NH4+	<0.01	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Klorbromuron	<0.011	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Aluminij	9,2	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Klomazon	<0.005	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Foramsulfuron	<0.014	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	2,6-diklorobenzamid	<0.006	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	1,2-dikloroetan	<0.4	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	1,1,1-trikloroetan	<0.4	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3608	09.05.2024 10:55:31	C2 - Brest	Kofein	<0.017	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Klortoluron	<0.009	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Kloroform	0,5	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Klorid	1,91	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Klor - prosti (na terenu)	<0.03	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Karbamazepin	<0.006	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Kalij	0,85	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Kalcij	55	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Diklorfos	<0.003	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Dikamba	<0.05	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Kadmij	<0.02	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Indeno(1,2,3-cd)piren	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Hidrogenkarbonat	293	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Bromacil	<0.008	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Bentazon	<0.012	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Amidosulfuron	<0.013	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Etilbenzen	<0.3	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3608	09.05.2024 10:55:31	C2 - Brest	2,4-DP	<0.020	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	2,4-D	<0.015	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	2,4,5-T	<0.010	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	2,4-DB	<0.016	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Okus	brez posebnosti	-
2024/3608	09.05.2024 10:55:31	C2 - Brest	Električna prevodnost (20°C, na terenu)	407	uS/cm
2024/3608	09.05.2024 10:55:31	C2 - Brest	Dimetilftalat	<0.24	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Dimetenamid	<0.001	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Primisulfuron-metil	<0.014	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Clostridium perfringens s sporami	0	cfu/100mL
2024/3608	09.05.2024 10:55:31	C2 - Brest	Fluorid	<0.04	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	vsota nitrat/50+nitrit/3	0,145	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Klorat	<0.05	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Klorit	<0.05	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Tetrakloroeten in trikloroeten (vsota)	<0.5	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Trihalometani (vsota)	1,8	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Tritosulfuron	<0.004	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Triasulfuron	<0.010	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Sebutilazin	<0.008	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Prosulfuron	<0.007	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Propikonazol	<0.002	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Petoksamid	<0.021	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Nikosulfuron	<0.013	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Monuron	<0.010	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Monolinuron	<0.009	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Mezotrion	<0.006	ug/L

2024/3608	09.05.2024 10:55:31	C2 - Brest	Mezosulfuron	<0.005	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Fenol	<5	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Pentaklorofenol	<0.06	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	m,p-Ksilen	<0.3	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Krom-šestvalentni	<10	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Živo srebro	<0.01	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Skupna trdota (izračun)	14,4	°N
2024/3608	09.05.2024 10:55:31	C2 - Brest	Klorfenvinfos	<0.002	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Izoproturon	<0.008	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Heksakloroetan	<0.4	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Glifosat	<0.09	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Diuron	<0.007	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Pesticidi (vsota)	0,059	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	o-ksilen	<0.3	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	m- alkaliteta	4,8	mmol/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Celotni organski ogljik (TOC)	<0.3	mg/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Vonj	brez posebnosti	-
2024/3608	09.05.2024 10:55:31	C2 - Brest	Trikloroeten	0,6	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Tribromometan	<0.5	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Toluen	<0.3	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Tetraklorometan	<0.4	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Tetrakloroeten	<0.5	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Terbutrin	<0.013	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Terbutilazin	<0.015	ug/L
2024/3608	09.05.2024 10:55:31	C2 - Brest	Temperatura (na terenu)	15,1	°C
2024/3842	15.05.2024 09:10:00	C2 - Brest	Vonj	brez	-
2024/3842	15.05.2024 09:10:00	C2 - Brest	Vidne nečistoče	brez	-
2024/3823	15.05.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/3865	15.05.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/3842	15.05.2024 09:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/3842	15.05.2024 09:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/3842	15.05.2024 09:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/3823	15.05.2024 09:10:00	C2 - Brest	Nitratni dušik	1,7	mg/L
2024/3842	15.05.2024 09:10:00	C2 - Brest	Električna prevodnost (20°C)	409	uS/cm
2024/3823	15.05.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	13,1	°C
2024/3842	15.05.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	13,1	°C
2024/3865	15.05.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	13,1	°C
2024/3842	15.05.2024 09:10:00	C2 - Brest	pH-vrednost	7,7	-
2024/3823	15.05.2024 09:10:00	C2 - Brest	Tetrakloroeten	<0.5	ug/L
2024/3823	15.05.2024 09:10:00	C2 - Brest	Trikloroeten	<0.5	ug/L
2024/3865	15.05.2024 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3865	15.05.2024 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3865	15.05.2024 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3865	15.05.2024 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3842	15.05.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/3842	15.05.2024 09:10:00	C2 - Brest	Absorbanca-barva	0,0004	
2024/3823	15.05.2024 09:10:00	C2 - Brest	Nitrat	7,53	mg/L
2024/3842	15.05.2024 09:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/3904	16.05.2024 08:40:00	C2 - Brest	Vonj	brez	-
2024/3904	16.05.2024 08:40:00	C2 - Brest	Vidne nečistoče	brez	-
2024/3904	16.05.2024 08:40:00	C2 - Brest	Prosti klordioksid (na terenu)	0,17	mg/L
2024/3906	16.05.2024 08:40:00	C2 - Brest	Prosti klordioksid (na terenu)	0,17	mg/L
2024/3904	16.05.2024 08:40:00	C2 - Brest	Barva (436 nm)	0,03	m-1
2024/3904	16.05.2024 08:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/3904	16.05.2024 08:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/3904	16.05.2024 08:40:00	C2 - Brest	Električna prevodnost (20°C)	564	uS/cm
2024/3904	16.05.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	12	°C
2024/3906	16.05.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	12	°C
2024/3904	16.05.2024 08:40:00	C2 - Brest	pH-vrednost	7,2	-
2024/3906	16.05.2024 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3906	16.05.2024 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3906	16.05.2024 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL

2024/3906	16.05.2024 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3904	16.05.2024 08:40:00	C2 - Brest	Absorbanca-barva	0,0016	
2024/3904	16.05.2024 08:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/3905	16.05.2024 09:00:00	C2 - Brest	Vonj	brez	-
2024/3905	16.05.2024 09:00:00	C2 - Brest	Vidne nečistoče	brez	-
2024/3907	16.05.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0,13	mg/L
2024/3905	16.05.2024 09:00:00	C2 - Brest	Barva (436 nm)	0,07	m-1
2024/3905	16.05.2024 09:00:00	C2 - Brest	Motnost	0,33	NTU
2024/3905	16.05.2024 09:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/3905	16.05.2024 09:00:00	C2 - Brest	Električna prevodnost (20°C)	408	uS/cm
2024/3905	16.05.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	11,2	°C
2024/3907	16.05.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	11,2	°C
2024/3905	16.05.2024 09:00:00	C2 - Brest	pH-vrednost	7,5	-
2024/3907	16.05.2024 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/3907	16.05.2024 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/3907	16.05.2024 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/3907	16.05.2024 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/3905	16.05.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0,13	mg/L
2024/3905	16.05.2024 09:00:00	C2 - Brest	Absorbanca-barva	0,0037	
2024/3905	16.05.2024 09:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/4041	21.05.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0,13	mg/L
2024/4041	21.05.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	11,1	°C
2024/4041	21.05.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4041	21.05.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4041	21.05.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4041	21.05.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4040	21.05.2024 10:20:00	C2 - Brest	Prosti klordiodksid (na terenu)	0,19	mg/L
2024/4040	21.05.2024 10:20:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/4040	21.05.2024 10:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4040	21.05.2024 10:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4040	21.05.2024 10:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4040	21.05.2024 10:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4030	21.05.2024 10:35:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/4030	21.05.2024 10:35:00	C2 - Brest	Temperatura (na terenu)	16,8	°C
2024/4030	21.05.2024 10:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4030	21.05.2024 10:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4030	21.05.2024 10:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4030	21.05.2024 10:35:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4033	21.05.2024 11:00:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/4033	21.05.2024 11:00:00	C2 - Brest	Temperatura (na terenu)	13,1	°C
2024/4033	21.05.2024 11:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4033	21.05.2024 11:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4033	21.05.2024 11:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4033	21.05.2024 11:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4236	28.05.2024 09:30:00	C2 - Brest	Vonj	brez	-
2024/4236	28.05.2024 09:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/4244	28.05.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0,09	mg/L
2024/4236	28.05.2024 09:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/4236	28.05.2024 09:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/4236	28.05.2024 09:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/4236	28.05.2024 09:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,43	mg/L
2024/4236	28.05.2024 09:30:00	C2 - Brest	Električna prevodnost (20°C)	418	uS/cm
2024/4236	28.05.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	16,5	°C
2024/4244	28.05.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	16,5	°C
2024/4236	28.05.2024 09:30:00	C2 - Brest	pH-vrednost	7,5	-
2024/4244	28.05.2024 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4244	28.05.2024 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4244	28.05.2024 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4244	28.05.2024 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4236	28.05.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0,09	mg/L
2024/4236	28.05.2024 09:30:00	C2 - Brest	Absorbanca-barva	0,0006	
2024/4236	28.05.2024 09:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L

2024/4273	29.05.2024 10:30:00	C2 - Brest	Vonj	brez	-
2024/4273	29.05.2024 10:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/4280	29.05.2024 10:30:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/4273	29.05.2024 10:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/4273	29.05.2024 10:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/4273	29.05.2024 10:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/4273	29.05.2024 10:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,46	mg/L
2024/4273	29.05.2024 10:30:00	C2 - Brest	Električna prevodnost (20°C)	410	uS/cm
2024/4273	29.05.2024 10:30:00	C2 - Brest	Temperatura (na terenu)	13,3	°C
2024/4280	29.05.2024 10:30:00	C2 - Brest	Temperatura (na terenu)	13,3	°C
2024/4273	29.05.2024 10:30:00	C2 - Brest	pH-vrednost	7,7	-
2024/4280	29.05.2024 10:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4280	29.05.2024 10:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4280	29.05.2024 10:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4280	29.05.2024 10:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4273	29.05.2024 10:30:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/4273	29.05.2024 10:30:00	C2 - Brest	Absorbanca-barva	0,0004	
2024/4273	29.05.2024 10:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/4271	29.05.2024 10:50:00	C2 - Brest	Vonj	brez	-
2024/4271	29.05.2024 10:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/4277	29.05.2024 10:50:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/4271	29.05.2024 10:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/4271	29.05.2024 10:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/4271	29.05.2024 10:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/4271	29.05.2024 10:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,49	mg/L
2024/4271	29.05.2024 10:50:00	C2 - Brest	Električna prevodnost (20°C)	425	uS/cm
2024/4271	29.05.2024 10:50:00	C2 - Brest	Temperatura (na terenu)	15,5	°C
2024/4277	29.05.2024 10:50:00	C2 - Brest	Temperatura (na terenu)	15,5	°C
2024/4271	29.05.2024 10:50:00	C2 - Brest	pH-vrednost	7,5	-
2024/4277	29.05.2024 10:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4277	29.05.2024 10:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4277	29.05.2024 10:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4277	29.05.2024 10:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4271	29.05.2024 10:50:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/4271	29.05.2024 10:50:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/4271	29.05.2024 10:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/4272	29.05.2024 11:30:00	C2 - Brest	Vonj	brez	-
2024/4272	29.05.2024 11:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/4278	29.05.2024 11:30:00	C2 - Brest	Klor - prosti (na terenu)	0,05	mg/L
2024/4272	29.05.2024 11:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/4272	29.05.2024 11:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/4272	29.05.2024 11:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/4272	29.05.2024 11:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,46	mg/L
2024/4272	29.05.2024 11:30:00	C2 - Brest	Električna prevodnost (20°C)	412	uS/cm
2024/4272	29.05.2024 11:30:00	C2 - Brest	Temperatura (na terenu)	13,2	°C
2024/4278	29.05.2024 11:30:00	C2 - Brest	Temperatura (na terenu)	13,2	°C
2024/4272	29.05.2024 11:30:00	C2 - Brest	pH-vrednost	7,7	-
2024/4278	29.05.2024 11:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4278	29.05.2024 11:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4278	29.05.2024 11:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4278	29.05.2024 11:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4272	29.05.2024 11:30:00	C2 - Brest	Klor - prosti (na terenu)	0,05	mg/L
2024/4272	29.05.2024 11:30:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/4272	29.05.2024 11:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/4549	06.06.2024 09:30:00	C2 - Brest	Vonj	brez	-
2024/4549	06.06.2024 09:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/4508	06.06.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/4549	06.06.2024 09:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/4549	06.06.2024 09:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/4549	06.06.2024 09:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/4549	06.06.2024 09:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,49	mg/L
2024/4549	06.06.2024 09:30:00	C2 - Brest	Električna prevodnost (20°C)	414	uS/cm

2024/4549	06.06.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	19,1	°C
2024/4508	06.06.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	19,1	°C
2024/4549	06.06.2024 09:30:00	C2 - Brest	pH-vrednost	7,6	-
2024/4508	06.06.2024 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4508	06.06.2024 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4508	06.06.2024 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4508	06.06.2024 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4549	06.06.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/4549	06.06.2024 09:30:00	C2 - Brest	Absorbanca-barva	0,0005	
2024/4549	06.06.2024 09:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/4532	07.06.2024 09:55:00	C2 - Brest	Klor - prosti (na terenu)	0,05	mg/L
2024/4532	07.06.2024 09:55:00	C2 - Brest	Temperatura (na terenu)	16,7	°C
2024/4532	07.06.2024 09:55:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4532	07.06.2024 09:55:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4532	07.06.2024 09:55:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4532	07.06.2024 09:55:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4612	10.06.2024 09:50:00	C2 - Brest	Vonj	brez	-
2024/4612	10.06.2024 09:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/4620	10.06.2024 09:50:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/4612	10.06.2024 09:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/4612	10.06.2024 09:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/4612	10.06.2024 09:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/4612	10.06.2024 09:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,48	mg/L
2024/4612	10.06.2024 09:50:00	C2 - Brest	Električna prevodnost (20°C)	423	uS/cm
2024/4612	10.06.2024 09:50:00	C2 - Brest	Temperatura (na terenu)	13,8	°C
2024/4620	10.06.2024 09:50:00	C2 - Brest	Temperatura (na terenu)	13,8	°C
2024/4612	10.06.2024 09:50:00	C2 - Brest	pH-vrednost	7,7	-
2024/4620	10.06.2024 09:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4620	10.06.2024 09:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4620	10.06.2024 09:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4620	10.06.2024 09:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4612	10.06.2024 09:50:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/4612	10.06.2024 09:50:00	C2 - Brest	Absorbanca-barva	0	
2024/4612	10.06.2024 09:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/4613	10.06.2024 10:15:00	C2 - Brest	Vonj	brez	-
2024/4613	10.06.2024 10:15:00	C2 - Brest	Vidne nečistoče	brez	-
2024/4622	10.06.2024 10:15:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/4613	10.06.2024 10:15:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/4613	10.06.2024 10:15:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/4613	10.06.2024 10:15:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/4613	10.06.2024 10:15:00	C2 - Brest	Celotni organski ogljik (TOC)	0,49	mg/L
2024/4613	10.06.2024 10:15:00	C2 - Brest	Električna prevodnost (20°C)	419	uS/cm
2024/4613	10.06.2024 10:15:00	C2 - Brest	Temperatura (na terenu)	13,9	°C
2024/4622	10.06.2024 10:15:00	C2 - Brest	Temperatura (na terenu)	13,9	°C
2024/4613	10.06.2024 10:15:00	C2 - Brest	pH-vrednost	7,7	-
2024/4622	10.06.2024 10:15:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4622	10.06.2024 10:15:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4622	10.06.2024 10:15:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4622	10.06.2024 10:15:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4613	10.06.2024 10:15:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/4613	10.06.2024 10:15:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/4613	10.06.2024 10:15:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/4617	10.06.2024 10:40:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/4617	10.06.2024 10:40:00	C2 - Brest	Temperatura (na terenu)	20	°C
2024/4617	10.06.2024 10:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4617	10.06.2024 10:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4617	10.06.2024 10:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4617	10.06.2024 10:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4741	13.06.2024 07:50:00	C2 - Brest	Vonj	brez	-
2024/4741	13.06.2024 07:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/4746	13.06.2024 07:50:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/4741	13.06.2024 07:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1

2024/4741	13.06.2024 07:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/4741	13.06.2024 07:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/4741	13.06.2024 07:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,43	mg/L
2024/4741	13.06.2024 07:50:00	C2 - Brest	Električna prevodnost (20°C)	437	uS/cm
2024/4741	13.06.2024 07:50:00	C2 - Brest	Temperatura (na terenu)	18,2	°C
2024/4746	13.06.2024 07:50:00	C2 - Brest	Temperatura (na terenu)	18,2	°C
2024/4741	13.06.2024 07:50:00	C2 - Brest	pH-vrednost	7,5	-
2024/4746	13.06.2024 07:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4746	13.06.2024 07:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4746	13.06.2024 07:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4746	13.06.2024 07:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4741	13.06.2024 07:50:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/4741	13.06.2024 07:50:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/4741	13.06.2024 07:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/4809	17.06.2024 08:00:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/4809	17.06.2024 08:00:00	C2 - Brest	Temperatura (na terenu)	18,2	°C
2024/4809	17.06.2024 08:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4809	17.06.2024 08:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4809	17.06.2024 08:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4809	17.06.2024 08:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4814	17.06.2024 08:25:00	C2 - Brest	Vonj	brez	-
2024/4814	17.06.2024 08:25:00	C2 - Brest	Vidne nečistoče	brez	-
2024/4810	17.06.2024 08:25:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/4814	17.06.2024 08:25:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/4814	17.06.2024 08:25:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/4814	17.06.2024 08:25:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/4814	17.06.2024 08:25:00	C2 - Brest	Celotni organski ogljik (TOC)	0,43	mg/L
2024/4814	17.06.2024 08:25:00	C2 - Brest	Električna prevodnost (20°C)	419	uS/cm
2024/4814	17.06.2024 08:25:00	C2 - Brest	Temperatura (na terenu)	19,5	°C
2024/4810	17.06.2024 08:25:00	C2 - Brest	Temperatura (na terenu)	19,5	°C
2024/4814	17.06.2024 08:25:00	C2 - Brest	pH-vrednost	7,5	-
2024/4810	17.06.2024 08:25:00	C2 - Brest	Število kolonij pri 36°C	26	cfu/mL
2024/4810	17.06.2024 08:25:00	C2 - Brest	Število kolonij pri 22°C	11	cfu/mL
2024/4810	17.06.2024 08:25:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4810	17.06.2024 08:25:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4814	17.06.2024 08:25:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/4814	17.06.2024 08:25:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/4814	17.06.2024 08:25:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/4811	17.06.2024 08:45:00	C2 - Brest	Klor - prosti (na terenu)	0,05	mg/L
2024/4811	17.06.2024 08:45:00	C2 - Brest	Temperatura (na terenu)	14,9	°C
2024/4811	17.06.2024 08:45:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4811	17.06.2024 08:45:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4811	17.06.2024 08:45:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4811	17.06.2024 08:45:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4812	17.06.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/4812	17.06.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	24	°C
2024/4812	17.06.2024 09:10:00	C2 - Brest	Število kolonij pri 36°C	98	cfu/mL
2024/4812	17.06.2024 09:10:00	C2 - Brest	Število kolonij pri 22°C	18	cfu/mL
2024/4812	17.06.2024 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4812	17.06.2024 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4813	17.06.2024 10:30:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/4813	17.06.2024 10:30:00	C2 - Brest	Temperatura (na terenu)	21,6	°C
2024/4813	17.06.2024 10:30:00	C2 - Brest	Število kolonij pri 36°C	11	cfu/mL
2024/4813	17.06.2024 10:30:00	C2 - Brest	Število kolonij pri 22°C	11	cfu/mL
2024/4813	17.06.2024 10:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4813	17.06.2024 10:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4895	18.06.2024 10:40:00	C2 - Brest	Vonj	brez	-
2024/4895	18.06.2024 10:40:00	C2 - Brest	Vidne nečistoče	brez	-
2024/4888	18.06.2024 10:40:00	C2 - Brest	Klor - prosti (na terenu)	0,11	mg/L
2024/4895	18.06.2024 10:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/4895	18.06.2024 10:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/4895	18.06.2024 10:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L

2024/4895	18.06.2024 10:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,48	mg/L
2024/4895	18.06.2024 10:40:00	C2 - Brest	Električna prevodnost (20°C)	418	uS/cm
2024/4895	18.06.2024 10:40:00	C2 - Brest	Temperatura (na terenu)	11,2	°C
2024/4888	18.06.2024 10:40:00	C2 - Brest	Temperatura (na terenu)	11,2	°C
2024/4895	18.06.2024 10:40:00	C2 - Brest	pH-vrednost	7,5	-
2024/4888	18.06.2024 10:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4888	18.06.2024 10:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4888	18.06.2024 10:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4888	18.06.2024 10:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4895	18.06.2024 10:40:00	C2 - Brest	Klor - prosti (na terenu)	0,11	mg/L
2024/4895	18.06.2024 10:40:00	C2 - Brest	Absorbanca-barva	0,0002	
2024/4895	18.06.2024 10:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/4894	18.06.2024 11:45:00	C2 - Brest	Vonj	brez	-
2024/4894	18.06.2024 11:45:00	C2 - Brest	Vidne nečistoče	brez	-
2024/4894	18.06.2024 11:45:00	C2 - Brest	Prosti klordioksid (na terenu)	0,19	mg/L
2024/4887	18.06.2024 11:45:00	C2 - Brest	Prosti klordioksid (na terenu)	0,19	mg/L
2024/4894	18.06.2024 11:45:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/4894	18.06.2024 11:45:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/4894	18.06.2024 11:45:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/4894	18.06.2024 11:45:00	C2 - Brest	Celotni organski ogljik (TOC)	0,73	mg/L
2024/4894	18.06.2024 11:45:00	C2 - Brest	Električna prevodnost (20°C)	540	uS/cm
2024/4894	18.06.2024 11:45:00	C2 - Brest	Temperatura (na terenu)	12,1	°C
2024/4887	18.06.2024 11:45:00	C2 - Brest	Temperatura (na terenu)	12,1	°C
2024/4894	18.06.2024 11:45:00	C2 - Brest	pH-vrednost	7,2	-
2024/4887	18.06.2024 11:45:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4887	18.06.2024 11:45:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4887	18.06.2024 11:45:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4887	18.06.2024 11:45:00	C2 - Brest	Koliformne bakterije 36°C	2	cfu/100mL
2024/4894	18.06.2024 11:45:00	C2 - Brest	Absorbanca-barva	0,0006	
2024/4894	18.06.2024 11:45:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/4934	19.06.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/4904	19.06.2024 09:30:00	C2 - Brest	Nitratni dušik	1,72	mg/L
2024/4904	19.06.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	14,7	°C
2024/4934	19.06.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	14,7	°C
2024/4904	19.06.2024 09:30:00	C2 - Brest	Tetrakloroeten	<0.5	ug/L
2024/4904	19.06.2024 09:30:00	C2 - Brest	Trikloroeten	<0.5	ug/L
2024/4934	19.06.2024 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4934	19.06.2024 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4934	19.06.2024 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4934	19.06.2024 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4904	19.06.2024 09:30:00	C2 - Brest	Nitrat	7,62	mg/L
2024/4950	19.06.2024 11:25:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/4950	19.06.2024 11:25:00	C2 - Brest	Temperatura (na terenu)	14,2	°C
2024/4950	19.06.2024 11:25:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4950	19.06.2024 11:25:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4950	19.06.2024 11:25:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4950	19.06.2024 11:25:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/4949	19.06.2024 12:00:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/4949	19.06.2024 12:00:00	C2 - Brest	Temperatura (na terenu)	14,1	°C
2024/4949	19.06.2024 12:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/4949	19.06.2024 12:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/4949	19.06.2024 12:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/4949	19.06.2024 12:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5037	24.06.2024 08:50:00	C2 - Brest	Klor - prosti (na terenu)	0,13	mg/L
2024/5037	24.06.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	11,7	°C
2024/5037	24.06.2024 08:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5037	24.06.2024 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5037	24.06.2024 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5037	24.06.2024 08:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5035	24.06.2024 09:10:00	C2 - Brest	Prosti klordioksid (na terenu)	0,18	mg/L
2024/5035	24.06.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	11,7	°C
2024/5035	24.06.2024 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL

2024/5035	24.06.2024 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5035	24.06.2024 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5035	24.06.2024 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5090	26.06.2024 07:50:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/5090	26.06.2024 07:50:00	C2 - Brest	Temperatura (na terenu)	19,6	°C
2024/5090	26.06.2024 07:50:00	C2 - Brest	Število kolonij pri 36°C	61	cfu/mL
2024/5090	26.06.2024 07:50:00	C2 - Brest	Število kolonij pri 22°C	78	cfu/mL
2024/5090	26.06.2024 07:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5090	26.06.2024 07:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5049	26.06.2024 12:56:18	C2 - Brest	Desetilterbutilazin	<0.004	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Desetilatratin	0,058	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Desizopropilatrazin	<0.003	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Dimetenamid	<0.001	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Metazaklor	<0.008	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Klortoluron	<0.009	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Metolaklor	<0.011	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Metribuzin	<0.010	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Pesticidi (vsota)	0,058	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Prometrin	<0.010	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Propazin	<0.009	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Simazin	<0.009	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Terbutilazin	<0.015	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	2,6-diklorobenzamid	<0.006	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Terbutrin	<0.013	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5049	26.06.2024 12:56:18	C2 - Brest	Antimon	<0.05	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Arzen	0,19	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Baker	0,002	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Benzen	<0.3	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Bor	0,0038	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	1,2-dikloroetan	<0.4	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Fluorid	<0.05	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Kadmij	<0.02	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Krom-šestvalentni	<10	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Krom	0,49	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Nitrit NO2-	<0.001	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Svinec	<0.1	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Selen	<0.1	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Živo srebro	<0.01	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Tetrakloroeten in trikloroeten (vsota)	0,5	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Celotni organski ogljik (TOC)	<0.3	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Amonij NH4+	<0.01	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Klorid	1,97	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5049	26.06.2024 12:56:18	C2 - Brest	Motnost	<0.03	NTU
2024/5049	26.06.2024 12:56:18	C2 - Brest	Trikloroeten	0,5	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Natrij	1	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Sulfat	3,96	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Vonj	brez posebnosti	-
2024/5049	26.06.2024 12:56:18	C2 - Brest	Tetrakloroeten	<0.5	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Kalij	0,8	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Kalcij	55	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Magnezij	28	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Nitrat	8,1	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Atrazin	<0.007	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Klorfenvinfos	<0.002	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Izoproturon	<0.008	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Aluminij	4,2	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Bromodiklorometan	0,8	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Dibromodiklorometan	0,3	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Električna prevodnost (20°C, na terenu)	429	uS/cm
2024/5049	26.06.2024 12:56:18	C2 - Brest	Kloroform	0,6	ug/L

2024/5049	26.06.2024 12:56:18	C2 - Brest	Nikelj	0,51	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Temperatura (na terenu)	17,3	°C
2024/5049	26.06.2024 12:56:18	C2 - Brest	Tribromometan	<0.5	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Skupna trdota (izračun)	14,2	°N
2024/5049	26.06.2024 12:56:18	C2 - Brest	pH vrednost (na terenu)	7,4	-
2024/5049	26.06.2024 12:56:18	C2 - Brest	Okus	brez posebnosti	-
2024/5049	26.06.2024 12:56:18	C2 - Brest	2,4-DB	<0.016	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	2,4,5-T	<0.010	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	2,4-D	<0.015	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	2,4-DP	<0.020	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Bromacil	<0.008	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Foramsulfuron	<0.014	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Klomazon	<0.005	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Klorbromuron	<0.011	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Kloridazon	<0.004	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Linuron	<0.009	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Malation	<0.006	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	MCPA	<0.013	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	MCPB	<0.022	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	MCPP	<0.013	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Metalaksil	<0.001	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Metamitron	<0.005	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Metobromuron	<0.009	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Metoksuron	<0.009	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Metolaklor-ESA	<0.017	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Metolaklor-OXA	<0.015	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Mezosulfuron	<0.005	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Mezotrion	<0.006	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Monolinuron	<0.009	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Monuron	<0.010	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Nikosulfuron	<0.013	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Petoksamid	<0.021	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Propikonazol	<0.002	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Prosulfuron	<0.007	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Sebutilazin	<0.008	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Triasulfuron	<0.010	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Tritosulfuron	<0.004	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Trihalometani (vsota)	1,7	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Klorit	<0.05	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Klorat	<0.05	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	vsota nitrat/50+nitrit/3	0,162	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Klor - prosti (na terenu)	<0.03	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Amidosulfuron	<0.013	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Clostridium perfringens s sporami	0	cfu/100mL
2024/5049	26.06.2024 12:56:18	C2 - Brest	Intestinalni enterokoki	0	cfu/100mL
2024/5049	26.06.2024 12:56:18	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5049	26.06.2024 12:56:18	C2 - Brest	Bentazon	<0.012	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Dikamba	<0.05	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Diklorfos	<0.003	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Diuron	<0.007	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5049	26.06.2024 12:56:18	C2 - Brest	Železo (preračun v ug/L)	<40	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Glifosat	<0.09	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Barva (436 nm)	<0.2	m-1
2024/5049	26.06.2024 12:56:18	C2 - Brest	Ortofosfat PO4	0,027	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Klorpirifos (klorpirifos-etil)	<0.002	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Heksakloroetan	<0.4	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Aklonifen	<0.009	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Bifenoks	<0.009	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Cibutrin	<0.0025	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	kvinoksifen	<0.009	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Fenuron	<0.008	ug/L

2024/5049	26.06.2024 12:56:18	C2 - Brest	Dietiltoluamid (DEET)	<0.01	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	1,1-dikloroetan	<0.4	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	1,1-dikloroeten	<0.4	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	1,1,2-trikloroetan	<0.7	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	1,1,2,2-tetrakloroetan	<0.5	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Diklorometan	<0.9	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Tetraklorometan	<0.4	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Toluen	<0.3	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Etilbenzen	<0.3	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	o-ksilen	<0.3	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	1,1,1-trikloroetan	<0.4	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Adsorbljivi organski halogeni (AOX)	9,5	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Bromat	<3	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	m- alkaliteta	4,9	mmol/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Perfluorooktansulfonska kislina	<0.0005	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Primisulfuron-metil	<0.014	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	m,p-Ksilen	<0.3	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Mangan	0,34	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Silicij (SiO2)	1,7	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Tepraloksidim	<0.01	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	1H-benzotriazol	<0.004	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	1-metil-1H-benzotriazol	<0.004	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	4-metil-1H-benzotriazol	<0.004	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	5-metil-1H-benzotriazol	<0.004	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Aminometil fosfonska kislina	<0.09	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Cimoksanil	<0.01	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Flutriafol	<0.01	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Hidrogenkarbonat	299	mg/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Glufosinat-amonijeva sol	<0.2	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Jodosulfuron	<0.005	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Karbendazim	<0.01	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Mandipropamid	<0.01	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Tiofanat-metil	<0.06	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Trialat	<0.004	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Tribenuron-metil	<0.06	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Zoksamid	<0.01	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Molibden	0,14	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Oksadiazon	<0.005	ug/L
2024/5049	26.06.2024 12:56:18	C2 - Brest	Perfluorooktanojska kislina	<0.0005	ug/L
2024/5146	27.06.2024 10:00:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/5146	27.06.2024 10:00:00	C2 - Brest	Temperatura (na terenu)	18,8	°C
2024/5146	27.06.2024 10:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5146	27.06.2024 10:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5146	27.06.2024 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5146	27.06.2024 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5147	27.06.2024 10:35:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/5147	27.06.2024 10:35:00	C2 - Brest	Temperatura (na terenu)	17,8	°C
2024/5147	27.06.2024 10:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5147	27.06.2024 10:35:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5147	27.06.2024 10:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5147	27.06.2024 10:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5235	01.07.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0,14	mg/L
2024/5235	01.07.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	11,3	°C
2024/5235	01.07.2024 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5235	01.07.2024 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5235	01.07.2024 08:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5235	01.07.2024 08:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5234	01.07.2024 08:40:00	C2 - Brest	Prosti klordioksid (na terenu)	0,2	mg/L
2024/5234	01.07.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	11,6	°C
2024/5234	01.07.2024 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5234	01.07.2024 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5234	01.07.2024 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL

2024/5234	01.07.2024 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5287	02.07.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/5287	02.07.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	15,4	°C
2024/5287	02.07.2024 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5287	02.07.2024 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5287	02.07.2024 08:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5287	02.07.2024 08:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5289	02.07.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/5289	02.07.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	15,7	°C
2024/5289	02.07.2024 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5289	02.07.2024 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5289	02.07.2024 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5289	02.07.2024 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5383	05.07.2024 10:40:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/5383	05.07.2024 10:40:00	C2 - Brest	Temperatura (na terenu)	17,1	°C
2024/5383	05.07.2024 10:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5383	05.07.2024 10:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5383	05.07.2024 10:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5383	05.07.2024 10:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5384	05.07.2024 11:10:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/5384	05.07.2024 11:10:00	C2 - Brest	Temperatura (na terenu)	19,7	°C
2024/5384	05.07.2024 11:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5384	05.07.2024 11:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5384	05.07.2024 11:10:00	C2 - Brest	Število kolonij pri 36°C	14	cfu/mL
2024/5384	05.07.2024 11:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5463	08.07.2024 09:40:00	C2 - Brest	Vonj	brez	-
2024/5463	08.07.2024 09:40:00	C2 - Brest	Vidne nečistoče	brez	-
2024/5466	08.07.2024 09:40:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/5463	08.07.2024 09:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/5463	08.07.2024 09:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/5463	08.07.2024 09:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/5463	08.07.2024 09:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,53	mg/L
2024/5463	08.07.2024 09:40:00	C2 - Brest	Električna prevodnost (20°C)	437	uS/cm
2024/5463	08.07.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	19,1	°C
2024/5466	08.07.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	19,1	°C
2024/5463	08.07.2024 09:40:00	C2 - Brest	pH-vrednost	7,5	-
2024/5466	08.07.2024 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5466	08.07.2024 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5466	08.07.2024 09:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5466	08.07.2024 09:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5463	08.07.2024 09:40:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/5463	08.07.2024 09:40:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/5463	08.07.2024 09:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/5485	09.07.2024 08:50:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/5512	09.07.2024 08:50:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/5485	09.07.2024 08:50:00	C2 - Brest	Nitrati dušik	1,95	mg/L
2024/5485	09.07.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	17,6	°C
2024/5512	09.07.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	17,6	°C
2024/5485	09.07.2024 08:50:00	C2 - Brest	Tetrakloroeten	<0.5	ug/L
2024/5485	09.07.2024 08:50:00	C2 - Brest	Trikloroeten	<0.5	ug/L
2024/5512	09.07.2024 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5512	09.07.2024 08:50:00	C2 - Brest	Koliformne bakterije 36°C	3	cfu/100mL
2024/5512	09.07.2024 08:50:00	C2 - Brest	Število kolonij pri 36°C	13	cfu/mL
2024/5512	09.07.2024 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5485	09.07.2024 08:50:00	C2 - Brest	Nitrat	8,64	mg/L
2024/5744	16.07.2024 10:20:00	C2 - Brest	Vonj	brez	-
2024/5744	16.07.2024 10:20:00	C2 - Brest	Vidne nečistoče	brez	-
2024/5651	16.07.2024 10:20:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/5744	16.07.2024 10:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/5744	16.07.2024 10:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/5744	16.07.2024 10:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/5744	16.07.2024 10:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,52	mg/L

2024/5744	16.07.2024 10:20:00	C2 - Brest	Električna prevodnost (20°C)	443	uS/cm
2024/5744	16.07.2024 10:20:00	C2 - Brest	Temperatura (na terenu)	16,8	°C
2024/5651	16.07.2024 10:20:00	C2 - Brest	Temperatura (na terenu)	16,8	°C
2024/5744	16.07.2024 10:20:00	C2 - Brest	pH-vrednost	7,7	-
2024/5651	16.07.2024 10:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5651	16.07.2024 10:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5651	16.07.2024 10:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5651	16.07.2024 10:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5744	16.07.2024 10:20:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/5744	16.07.2024 10:20:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/5744	16.07.2024 10:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/5743	16.07.2024 10:50:00	C2 - Brest	Vonj	brez	-
2024/5743	16.07.2024 10:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/5650	16.07.2024 10:50:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/5743	16.07.2024 10:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/5743	16.07.2024 10:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/5743	16.07.2024 10:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/5743	16.07.2024 10:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,49	mg/L
2024/5743	16.07.2024 10:50:00	C2 - Brest	Električna prevodnost (20°C)	443	uS/cm
2024/5743	16.07.2024 10:50:00	C2 - Brest	Temperatura (na terenu)	16,9	°C
2024/5650	16.07.2024 10:50:00	C2 - Brest	Temperatura (na terenu)	16,9	°C
2024/5743	16.07.2024 10:50:00	C2 - Brest	pH-vrednost	7,7	-
2024/5650	16.07.2024 10:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5650	16.07.2024 10:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5650	16.07.2024 10:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5650	16.07.2024 10:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5743	16.07.2024 10:50:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/5743	16.07.2024 10:50:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/5743	16.07.2024 10:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/5792	18.07.2024 07:10:00	C2 - Brest	Vonj	brez	-
2024/5792	18.07.2024 07:10:00	C2 - Brest	Vidne nečistoče	brez	-
2024/5667	18.07.2024 07:10:00	C2 - Brest	Klor - prosti (na terenu)	0,1	mg/L
2024/5792	18.07.2024 07:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/5792	18.07.2024 07:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/5792	18.07.2024 07:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/5792	18.07.2024 07:10:00	C2 - Brest	Celotni organski ogljik (TOC)	0,43	mg/L
2024/5792	18.07.2024 07:10:00	C2 - Brest	Električna prevodnost (20°C)	436	uS/cm
2024/5792	18.07.2024 07:10:00	C2 - Brest	Temperatura (na terenu)	11,3	°C
2024/5667	18.07.2024 07:10:00	C2 - Brest	Temperatura (na terenu)	11,3	°C
2024/5792	18.07.2024 07:10:00	C2 - Brest	pH-vrednost	7,4	-
2024/5667	18.07.2024 07:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5667	18.07.2024 07:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5667	18.07.2024 07:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5667	18.07.2024 07:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5792	18.07.2024 07:10:00	C2 - Brest	Klor - prosti (na terenu)	0,1	mg/L
2024/5792	18.07.2024 07:10:00	C2 - Brest	Absorbanca-barva	0,0002	
2024/5792	18.07.2024 07:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/5791	18.07.2024 07:50:00	C2 - Brest	Vonj	brez	-
2024/5791	18.07.2024 07:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/5791	18.07.2024 07:50:00	C2 - Brest	Prosti klordioksid (na terenu)	0,16	mg/L
2024/5666	18.07.2024 07:50:00	C2 - Brest	Prosti klordioksid (na terenu)	0,16	mg/L
2024/5791	18.07.2024 07:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/5791	18.07.2024 07:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/5791	18.07.2024 07:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/5791	18.07.2024 07:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,77	mg/L
2024/5791	18.07.2024 07:50:00	C2 - Brest	Električna prevodnost (20°C)	585	uS/cm
2024/5791	18.07.2024 07:50:00	C2 - Brest	Temperatura (na terenu)	12,2	°C
2024/5666	18.07.2024 07:50:00	C2 - Brest	Temperatura (na terenu)	12,2	°C
2024/5791	18.07.2024 07:50:00	C2 - Brest	pH-vrednost	7,2	-
2024/5666	18.07.2024 07:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5666	18.07.2024 07:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5666	18.07.2024 07:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL

2024/5666	18.07.2024 07:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5791	18.07.2024 07:50:00	C2 - Brest	Absorbanca-barva	0,0006	
2024/5791	18.07.2024 07:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/5929	24.07.2024 09:00:00	C2 - Brest	Vonj	brez	-
2024/5929	24.07.2024 09:00:00	C2 - Brest	Vidne nečistoče	brez	-
2024/5877	24.07.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/5929	24.07.2024 09:00:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/5929	24.07.2024 09:00:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/5929	24.07.2024 09:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/5929	24.07.2024 09:00:00	C2 - Brest	Celotni organski ogljik (TOC)	0,45	mg/L
2024/5929	24.07.2024 09:00:00	C2 - Brest	Električna prevodnost (20°C)	445	uS/cm
2024/5929	24.07.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	19,5	°C
2024/5877	24.07.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	19,5	°C
2024/5929	24.07.2024 09:00:00	C2 - Brest	pH-vrednost	7,5	-
2024/5877	24.07.2024 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5877	24.07.2024 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5877	24.07.2024 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5877	24.07.2024 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5929	24.07.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/5929	24.07.2024 09:00:00	C2 - Brest	Absorbanca-barva	0,0002	
2024/5929	24.07.2024 09:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/5930	24.07.2024 09:30:00	C2 - Brest	Vonj	brez	-
2024/5930	24.07.2024 09:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/5878	24.07.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/5930	24.07.2024 09:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/5930	24.07.2024 09:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/5930	24.07.2024 09:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/5930	24.07.2024 09:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,52	mg/L
2024/5930	24.07.2024 09:30:00	C2 - Brest	Električna prevodnost (20°C)	439	uS/cm
2024/5930	24.07.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	21	°C
2024/5878	24.07.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	21	°C
2024/5930	24.07.2024 09:30:00	C2 - Brest	pH-vrednost	7,5	-
2024/5878	24.07.2024 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/5878	24.07.2024 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/5878	24.07.2024 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/5878	24.07.2024 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/5930	24.07.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/5930	24.07.2024 09:30:00	C2 - Brest	Absorbanca-barva	0,0002	
2024/5930	24.07.2024 09:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/6192	06.08.2024 09:00:00	C2 - Brest	Vonj	brez	-
2024/6192	06.08.2024 09:00:00	C2 - Brest	Vidne nečistoče	brez	-
2024/6187	06.08.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/6192	06.08.2024 09:00:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/6192	06.08.2024 09:00:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/6192	06.08.2024 09:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/6192	06.08.2024 09:00:00	C2 - Brest	Celotni organski ogljik (TOC)	0,47	mg/L
2024/6192	06.08.2024 09:00:00	C2 - Brest	Električna prevodnost (20°C)	445	uS/cm
2024/6192	06.08.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	17,9	°C
2024/6187	06.08.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	17,9	°C
2024/6192	06.08.2024 09:00:00	C2 - Brest	pH-vrednost	7,7	-
2024/6187	06.08.2024 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/6187	06.08.2024 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6187	06.08.2024 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/6187	06.08.2024 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6192	06.08.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/6192	06.08.2024 09:00:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/6192	06.08.2024 09:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/6190	06.08.2024 09:40:00	C2 - Brest	Vonj	brez	-
2024/6190	06.08.2024 09:40:00	C2 - Brest	Vidne nečistoče	brez	-
2024/6185	06.08.2024 09:40:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/6190	06.08.2024 09:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/6190	06.08.2024 09:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU

2024/6190	06.08.2024 09:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/6190	06.08.2024 09:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,52	mg/L
2024/6190	06.08.2024 09:40:00	C2 - Brest	Električna prevodnost (20°C)	472	uS/cm
2024/6190	06.08.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	24,9	°C
2024/6185	06.08.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	24,9	°C
2024/6190	06.08.2024 09:40:00	C2 - Brest	pH-vrednost	7,6	-
2024/6185	06.08.2024 09:40:00	C2 - Brest	Število kolonij pri 36°C	46	cfu/mL
2024/6185	06.08.2024 09:40:00	C2 - Brest	Število kolonij pri 22°C	15	cfu/mL
2024/6185	06.08.2024 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/6185	06.08.2024 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6190	06.08.2024 09:40:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/6190	06.08.2024 09:40:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/6190	06.08.2024 09:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/6191	06.08.2024 10:50:00	C2 - Brest	Vonj	brez	-
2024/6191	06.08.2024 10:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/6186	06.08.2024 10:50:00	C2 - Brest	Klor - prosti (na terenu)	0,05	mg/L
2024/6191	06.08.2024 10:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/6191	06.08.2024 10:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/6191	06.08.2024 10:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/6191	06.08.2024 10:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,5	mg/L
2024/6191	06.08.2024 10:50:00	C2 - Brest	Električna prevodnost (20°C)	445	uS/cm
2024/6191	06.08.2024 10:50:00	C2 - Brest	Temperatura (na terenu)	17,4	°C
2024/6186	06.08.2024 10:50:00	C2 - Brest	Temperatura (na terenu)	17,4	°C
2024/6191	06.08.2024 10:50:00	C2 - Brest	pH-vrednost	7,7	-
2024/6186	06.08.2024 10:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/6186	06.08.2024 10:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6186	06.08.2024 10:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/6186	06.08.2024 10:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6191	06.08.2024 10:50:00	C2 - Brest	Klor - prosti (na terenu)	0,05	mg/L
2024/6191	06.08.2024 10:50:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/6191	06.08.2024 10:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/6273	08.08.2024 08:20:00	C2 - Brest	Vonj	brez	-
2024/6273	08.08.2024 08:20:00	C2 - Brest	Vidne nečistoče	brez	-
2024/6289	08.08.2024 08:20:00	C2 - Brest	Klor - prosti (na terenu)	0,11	mg/L
2024/6273	08.08.2024 08:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/6273	08.08.2024 08:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/6273	08.08.2024 08:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/6273	08.08.2024 08:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,57	mg/L
2024/6273	08.08.2024 08:20:00	C2 - Brest	Električna prevodnost (20°C)	460	uS/cm
2024/6273	08.08.2024 08:20:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/6289	08.08.2024 08:20:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/6273	08.08.2024 08:20:00	C2 - Brest	pH-vrednost	7,4	-
2024/6289	08.08.2024 08:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/6289	08.08.2024 08:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6289	08.08.2024 08:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/6289	08.08.2024 08:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6273	08.08.2024 08:20:00	C2 - Brest	Klor - prosti (na terenu)	0,11	mg/L
2024/6273	08.08.2024 08:20:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/6273	08.08.2024 08:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/6272	08.08.2024 08:50:00	C2 - Brest	Vonj	brez	-
2024/6272	08.08.2024 08:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/6272	08.08.2024 08:50:00	C2 - Brest	Prosti klordioksid (na terenu)	0,18	mg/L
2024/6287	08.08.2024 08:50:00	C2 - Brest	Prosti klordioksid (na terenu)	0,18	mg/L
2024/6272	08.08.2024 08:50:00	C2 - Brest	Barva (436 nm)	0,18	m-1
2024/6272	08.08.2024 08:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/6272	08.08.2024 08:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/6272	08.08.2024 08:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,82	mg/L
2024/6272	08.08.2024 08:50:00	C2 - Brest	Električna prevodnost (20°C)	600	uS/cm
2024/6272	08.08.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	12,6	°C
2024/6287	08.08.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	12,6	°C
2024/6272	08.08.2024 08:50:00	C2 - Brest	pH-vrednost	7,2	-
2024/6287	08.08.2024 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL

2024/6287	08.08.2024 08:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6287	08.08.2024 08:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/6287	08.08.2024 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6272	08.08.2024 08:50:00	C2 - Brest	Absorbanca-barva	0,009	
2024/6272	08.08.2024 08:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/6455	16.08.2024 09:40:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/6455	16.08.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	17,8	°C
2024/6455	16.08.2024 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/6455	16.08.2024 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6455	16.08.2024 09:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/6455	16.08.2024 09:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6488	19.08.2024 10:20:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/6488	19.08.2024 10:20:00	C2 - Brest	Temperatura (na terenu)	21,4	°C
2024/6488	19.08.2024 10:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/6488	19.08.2024 10:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6488	19.08.2024 10:20:00	C2 - Brest	Število kolonij pri 36°C	108	cfu/mL
2024/6488	19.08.2024 10:20:00	C2 - Brest	Število kolonij pri 22°C	66	cfu/mL
2024/6646	22.08.2024 07:30:00	C2 - Brest	Klor - prosti (na terenu)	0,11	mg/L
2024/6646	22.08.2024 07:30:00	C2 - Brest	Temperatura (na terenu)	11,3	°C
2024/6646	22.08.2024 07:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/6646	22.08.2024 07:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6646	22.08.2024 07:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/6646	22.08.2024 07:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6645	22.08.2024 08:20:00	C2 - Brest	Prosti klordiodksid (na terenu)	0,18	mg/L
2024/6645	22.08.2024 08:20:00	C2 - Brest	Temperatura (na terenu)	11,7	°C
2024/6645	22.08.2024 08:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/6645	22.08.2024 08:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6645	22.08.2024 08:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/6645	22.08.2024 08:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6656	22.08.2024 08:40:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/6656	22.08.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	18,4	°C
2024/6656	22.08.2024 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/6656	22.08.2024 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6656	22.08.2024 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/6656	22.08.2024 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6657	22.08.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/6657	22.08.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	18,3	°C
2024/6657	22.08.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/6657	22.08.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6657	22.08.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/6657	22.08.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6654	22.08.2024 09:50:00	C2 - Brest	Klor - prosti (na terenu)	0,06	mg/L
2024/6654	22.08.2024 09:50:00	C2 - Brest	Temperatura (na terenu)	22,5	°C
2024/6654	22.08.2024 09:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/6654	22.08.2024 09:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6654	22.08.2024 09:50:00	C2 - Brest	Število kolonij pri 36°C	44	cfu/mL
2024/6654	22.08.2024 09:50:00	C2 - Brest	Število kolonij pri 22°C	27	cfu/mL
2024/6784	27.08.2024 10:40:00	C2 - Brest	Vonj	brez	-
2024/6784	27.08.2024 10:40:00	C2 - Brest	Vidne nečistoče	brez	-
2024/6791	27.08.2024 10:40:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/6784	27.08.2024 10:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/6784	27.08.2024 10:40:00	C2 - Brest	Motnost	0,49	NTU
2024/6784	27.08.2024 10:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/6784	27.08.2024 10:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,57	mg/L
2024/6784	27.08.2024 10:40:00	C2 - Brest	Električna prevodnost (20°C)	440	uS/cm
2024/6784	27.08.2024 10:40:00	C2 - Brest	Temperatura (na terenu)	17,4	°C
2024/6791	27.08.2024 10:40:00	C2 - Brest	Temperatura (na terenu)	17,4	°C
2024/6784	27.08.2024 10:40:00	C2 - Brest	pH-vrednost	7,5	-
2024/6791	27.08.2024 10:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/6791	27.08.2024 10:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6791	27.08.2024 10:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/6791	27.08.2024 10:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL

2024/6784	27.08.2024 10:40:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/6784	27.08.2024 10:40:00	C2 - Brest	Absorbanca-barva	0,0007	
2024/6784	27.08.2024 10:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/6828	28.08.2024 08:50:00	C2 - Brest	Vonj	brez	-
2024/6828	28.08.2024 08:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/6808	28.08.2024 08:50:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/6845	28.08.2024 08:50:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/6828	28.08.2024 08:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/6828	28.08.2024 08:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/6828	28.08.2024 08:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/6828	28.08.2024 08:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,45	mg/L
2024/6808	28.08.2024 08:50:00	C2 - Brest	Nitrati dušik	2,1	mg/L
2024/6828	28.08.2024 08:50:00	C2 - Brest	Električna prevodnost (20°C)	448	uS/cm
2024/6808	28.08.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	17,7	°C
2024/6828	28.08.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	17,7	°C
2024/6845	28.08.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	17,7	°C
2024/6828	28.08.2024 08:50:00	C2 - Brest	pH-vrednost	7,7	-
2024/6808	28.08.2024 08:50:00	C2 - Brest	Tetrakloroeten	<0.5	ug/L
2024/6808	28.08.2024 08:50:00	C2 - Brest	Trikloroeten	<0.5	ug/L
2024/6845	28.08.2024 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/6845	28.08.2024 08:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/6845	28.08.2024 08:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/6845	28.08.2024 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6828	28.08.2024 08:50:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/6828	28.08.2024 08:50:00	C2 - Brest	Absorbanca-barva	0,0002	
2024/6808	28.08.2024 08:50:00	C2 - Brest	Nitrat	9,3	mg/L
2024/6828	28.08.2024 08:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/6994	03.09.2024 07:00:00	C2 - Brest	Vonj	brez	-
2024/6994	03.09.2024 07:00:00	C2 - Brest	Vidne nečistoče	brez	-
2024/7003	03.09.2024 07:00:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/6994	03.09.2024 07:00:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/6994	03.09.2024 07:00:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/6994	03.09.2024 07:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/6994	03.09.2024 07:00:00	C2 - Brest	Celotni organski ogljik (TOC)	0,44	mg/L
2024/6994	03.09.2024 07:00:00	C2 - Brest	Električna prevodnost (20°C)	443	uS/cm
2024/6994	03.09.2024 07:00:00	C2 - Brest	Temperatura (na terenu)	18,2	°C
2024/7003	03.09.2024 07:00:00	C2 - Brest	Temperatura (na terenu)	18,2	°C
2024/6994	03.09.2024 07:00:00	C2 - Brest	pH-vrednost	7,7	-
2024/7003	03.09.2024 07:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7003	03.09.2024 07:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7003	03.09.2024 07:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/7003	03.09.2024 07:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6994	03.09.2024 07:00:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/6994	03.09.2024 07:00:00	C2 - Brest	Absorbanca-barva	0,0005	
2024/6994	03.09.2024 07:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/6995	03.09.2024 07:30:00	C2 - Brest	Vonj	brez	-
2024/6995	03.09.2024 07:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/7004	03.09.2024 07:30:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/6995	03.09.2024 07:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/6995	03.09.2024 07:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/6995	03.09.2024 07:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/6995	03.09.2024 07:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,43	mg/L
2024/6995	03.09.2024 07:30:00	C2 - Brest	Električna prevodnost (20°C)	449	uS/cm
2024/6995	03.09.2024 07:30:00	C2 - Brest	Temperatura (na terenu)	18,3	°C
2024/7004	03.09.2024 07:30:00	C2 - Brest	Temperatura (na terenu)	8,3	°C
2024/6995	03.09.2024 07:30:00	C2 - Brest	pH-vrednost	7,6	-
2024/7004	03.09.2024 07:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7004	03.09.2024 07:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7004	03.09.2024 07:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/7004	03.09.2024 07:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6995	03.09.2024 07:30:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/6995	03.09.2024 07:30:00	C2 - Brest	Absorbanca-barva	0,0009	

2024/6995	03.09.2024 07:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/6993	03.09.2024 09:20:00	C2 - Brest	Vonj	brez	-
2024/6993	03.09.2024 09:20:00	C2 - Brest	Vidne nečistoče	brez	-
2024/7002	03.09.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0,08	mg/L
2024/6993	03.09.2024 09:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/6993	03.09.2024 09:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/6993	03.09.2024 09:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/6993	03.09.2024 09:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,39	mg/L
2024/6993	03.09.2024 09:20:00	C2 - Brest	Električna prevodnost (20°C)	417	uS/cm
2024/6993	03.09.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	11,3	°C
2024/7002	03.09.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	11,3	°C
2024/6993	03.09.2024 09:20:00	C2 - Brest	pH-vrednost	7,5	-
2024/7002	03.09.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7002	03.09.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7002	03.09.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/7002	03.09.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6993	03.09.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0,08	mg/L
2024/6993	03.09.2024 09:20:00	C2 - Brest	Absorbanca-barva	0,0008	
2024/6993	03.09.2024 09:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/6992	03.09.2024 09:40:00	C2 - Brest	Vonj	brez	-
2024/6992	03.09.2024 09:40:00	C2 - Brest	Vidne nečistoče	brez	-
2024/6992	03.09.2024 09:40:00	C2 - Brest	Prosti klordioksid (na terenu)	0,14	mg/L
2024/7001	03.09.2024 09:40:00	C2 - Brest	Prosti klordioksid (na terenu)	0,14	mg/L
2024/6992	03.09.2024 09:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/6992	03.09.2024 09:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/6992	03.09.2024 09:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/6992	03.09.2024 09:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,84	mg/L
2024/6992	03.09.2024 09:40:00	C2 - Brest	Električna prevodnost (20°C)	589	uS/cm
2024/6992	03.09.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	12,4	°C
2024/7001	03.09.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	12,4	°C
2024/6992	03.09.2024 09:40:00	C2 - Brest	pH-vrednost	7,2	-
2024/7001	03.09.2024 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7001	03.09.2024 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7001	03.09.2024 09:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/7001	03.09.2024 09:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/6992	03.09.2024 09:40:00	C2 - Brest	Absorbanca-barva	0,0008	
2024/6992	03.09.2024 09:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/7081	05.09.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/7092	05.09.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/7081	05.09.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	21,2	°C
2024/7092	05.09.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	19,7	°C
2024/7081	05.09.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7081	05.09.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7081	05.09.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	47	cfu/mL
2024/7081	05.09.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	49	cfu/mL
2024/7092	05.09.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7092	05.09.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7092	05.09.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/7092	05.09.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/7093	05.09.2024 09:45:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/7093	05.09.2024 09:45:00	C2 - Brest	Temperatura (na terenu)	19,9	°C
2024/7093	05.09.2024 09:45:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7093	05.09.2024 09:45:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7093	05.09.2024 09:45:00	C2 - Brest	Število kolonij pri 36°C	48	cfu/mL
2024/7093	05.09.2024 09:45:00	C2 - Brest	Število kolonij pri 22°C	>300	cfu/mL
2024/7125	06.09.2024 10:00:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/7125	06.09.2024 10:00:00	C2 - Brest	Temperatura (na terenu)	23,6	°C
2024/7125	06.09.2024 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7125	06.09.2024 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7125	06.09.2024 10:00:00	C2 - Brest	Število kolonij pri 36°C	69	cfu/mL
2024/7125	06.09.2024 10:00:00	C2 - Brest	Število kolonij pri 22°C	18	cfu/mL
2024/7405	16.09.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0,11	mg/L

2024/7405	16.09.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	11,2	°C
2024/7405	16.09.2024 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7405	16.09.2024 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7405	16.09.2024 08:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/7405	16.09.2024 08:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/7404	16.09.2024 08:40:00	C2 - Brest	Prosti klordioksid (na terenu)	0,16	mg/L
2024/7404	16.09.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	11,5	°C
2024/7404	16.09.2024 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/7404	16.09.2024 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7404	16.09.2024 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7404	16.09.2024 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/7455	17.09.2024 10:50:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/7455	17.09.2024 10:50:00	C2 - Brest	Temperatura (na terenu)	20,8	°C
2024/7455	17.09.2024 10:50:00	C2 - Brest	Pseudomonas aeruginosa	0	cfu/100mL
2024/7455	17.09.2024 10:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7455	17.09.2024 10:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7455	17.09.2024 10:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/7455	17.09.2024 10:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/7392	17.09.2024 10:55:27	C2 - Brest	Aluminij	<0.9	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Adsorbiljivi organski halogeni (AOX)	7,2	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Kadmij	<0.02	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Molibden	<0.1	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Svinec	<0.1	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Krom	0,57	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Selen	0,12	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Bromacil	<0.008	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	2,4-DP	<0.020	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	2,4-D	<0.015	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	2,4,5-T	<0.010	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Okus	brez posebnosti	-
2024/7392	17.09.2024 10:55:27	C2 - Brest	Dibromoklorometan	<0.3	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Bromodiklorometan	<0.3	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	S-metolaklor	<0.03	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Pendimetalin	<0.001	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Izoproturon	<0.008	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Klorfenvinfos	<0.002	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Alaklor	<0.007	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Atrazin	<0.007	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Nitrat	19,6	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Vinilklorid	<0.05	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Magnezij	39	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Kalcij	75	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Kalij	1	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Železo	<40	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Vonj	brez posebnosti	-
2024/7392	17.09.2024 10:55:27	C2 - Brest	Sulfat	4,46	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Natrij	1,6	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Motnost	0,05	NTU
2024/7392	17.09.2024 10:55:27	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7392	17.09.2024 10:55:27	C2 - Brest	Klorid	3,39	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Električna prevodnost (20°C)	581	uS/cm
2024/7392	17.09.2024 10:55:27	C2 - Brest	Fluorid	<0.05	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	1,2-dikloroetan	<0.4	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Bor	0,006	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Benzen	<0.3	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Baker	0,00048	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7392	17.09.2024 10:55:27	C2 - Brest	Terbutrin	<0.013	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	2,6-diklorobenzamid	<0.006	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Terbutilazin	<0.015	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Simazin	<0.009	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Propazin	<0.009	ug/L

2024/7392	17.09.2024 10:55:27	C2 - Brest	Prometrin	<0.010	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Pesticidi (vsota)	<0.05	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Metribuzin	<0.010	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Metolaklor	<0.011	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Metazaklor	<0.008	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Dimetenamid	<0.001	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Perfluoropentanojska kislina	<0.0005	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Perfluorononanojska kislina	<0.0005	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Perfluoroheptanojska kislina	<0.0005	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Perfluoroheksanojska kislina	<0.0005	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Perfluorododekanojska kislina	<0.0005	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Perfluorodekanojska kislina	<0.0005	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Perfluorobutanojska kislina	<0.0005	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Nitrit	0,0064	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Nitrat/50+nitrit/3	0,394	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Monokloroocetna kislina	<5.0	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Monobromoocetna kislina	<5.0	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Metaflumizon	<0.01	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	m-Alkaliteta	6,7	mmol/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Krom (VI)	<10	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Hidrogenkarbonati	409	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Fosfat-orto	0,015	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Celotni organski ogljik - TOC	0,41	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Amonij	<0.01	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Temperatura vode	12,2	°C
2024/7392	17.09.2024 10:55:27	C2 - Brest	pH	7,2	-
2024/7392	17.09.2024 10:55:27	C2 - Brest	Terbutilazin-desetil	<0.004	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	N,N-dietil-m-toluamid	<0.01	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Klorpirifos-etil	<0.002	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Klorotoluron	<0.009	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Atrazin, Desizopropil-	<0.003	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Atrazin, Desetil-	0,022	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	2,4 - DB	<0.016	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Trikloroeten (trikloroetilen)	<0.5	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Tetrakloroeten+trikloroeten	<0.5	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	m,p- Ksilen	<0.3	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Uran	0,46	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Triklorometan (kloroform)	<0.4	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Tribromometan (bromoform)	<0.5	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Tetrakloroeten (tetrakloroetilen)	<0.5	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Skupna trdota	19,5	°N
2024/7392	17.09.2024 10:55:27	C2 - Brest	Prosulfokarb	<0.006	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Perfluoroundekanojska kislina	<0.0005	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Dibromoocetna kislina	<5.0	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Dikloroocetna kislina	<5.0	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Trikloroocetna kislina	<5.0	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Zoksamid	<0.01	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Tribenuron-metil	<0.06	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Mandipropamid	<0.01	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Jodosulfuron	<0.005	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Glufosinat-amonijeva sol	<0.2	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Cimoksanil	<0.01	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Aminometil fosfonska kislina	<0.09	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	5-metil-1H-benzotriazol	<0.004	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	4-metil-1H-benzotriazol	<0.004	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	1-metil-1H-benzotriazol	<0.004	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	1H-benzotriazol	<0.004	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Mangan	<0.1	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Perfluorooktansulfonska kislina	<0.0005	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Cianid - prosti	<0.5	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Bromat	<3	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	1,1,1-trikloroetan	<0.4	ug/L

2024/7392	17.09.2024 10:55:27	C2 - Brest	o-ksilen	<0.3	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Etilbenzen	<0.3	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Toluen	<0.3	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Tetraklorometan	<0.4	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Diklorometan	<0.6	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	1,1,2,2-tetrakloroetan	<0.5	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	1,1,2-trikloroetan	<0.7	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	1,1-dikloroeten	<0.4	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	1,1-dikloroetan	<0.4	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Piridat-M	<0.005	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Pirimikarb	<0.009	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Fenuron	<0.008	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Diklobenil	<0.03	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	kvinoksifen	<0.009	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Diflufenikan	<0.006	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Heksakloroetan	<0.4	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Tebukonazol	<0.01	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Klorpirifos-metil	<0.003	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Barva (436 nm)	<0.2	m-1
2024/7392	17.09.2024 10:55:27	C2 - Brest	Glifosat	<0.09	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/7392	17.09.2024 10:55:27	C2 - Brest	Diuron	<0.007	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Dimetoat	<0.001	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Dikamba	<0.05	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Cianazin	<0.009	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Bentazon	<0.012	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/7392	17.09.2024 10:55:27	C2 - Brest	Intestinalni enterokoki	0	cfu/100mL
2024/7392	17.09.2024 10:55:27	C2 - Brest	Clostridium perfringens s sporami	0	cfu/100mL
2024/7392	17.09.2024 10:55:27	C2 - Brest	Amidosulfuron	<0.013	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Acetoklor	<0.007	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Prosti klordioksid (na terenu)	0,19	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Klorat	0,064	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Klorit	<0.05	mg/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Trihalometani (vsota)	<0.5	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Tritosulfuron	<0.004	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Triasulfuron	<0.010	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Tiaklopid	<0.007	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Sebutilazin	<0.008	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Rimsulfuron	<0.05	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Propikonazol	<0.002	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Pinoksaden	<0.007	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Petoksamid	<0.021	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Nikosulfuron	<0.013	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Monuron	<0.010	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Monolinuron	<0.009	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Mezotrion	<0.006	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Mezosulfuron	<0.005	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Metolaklor-OXA	<0.015	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Metolaklor-ESA	<0.017	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Metoksuron	<0.009	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Metamitron	<0.005	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Metalaksil	<0.001	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	MCPP	<0.013	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	MCPB	<0.022	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	MCPA	<0.013	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Malation	<0.006	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Linuron	<0.009	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Kloridazon	<0.004	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Imidaklopid	<0.003	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Foramsulfuron	<0.014	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Flufenacet	<0.003	ug/L

2024/7392	17.09.2024 10:55:27	C2 - Brest	Živo srebro	<0.01	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Arzen	0,16	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Antimon	<0.05	ug/L
2024/7392	17.09.2024 10:55:27	C2 - Brest	Nikelj	0,21	ug/L
2024/7567	18.09.2024 10:35:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/7567	18.09.2024 10:35:00	C2 - Brest	Temperatura (na terenu)	16,8	°C
2024/7567	18.09.2024 10:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7567	18.09.2024 10:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7567	18.09.2024 10:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/7567	18.09.2024 10:35:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/7692	20.09.2024 11:15:00	C2 - Brest	Klor - prosti (na terenu)	0,01	mg/L
2024/7692	20.09.2024 11:15:00	C2 - Brest	Temperatura (na terenu)	17,4	°C
2024/7692	20.09.2024 11:15:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7692	20.09.2024 11:15:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7692	20.09.2024 11:15:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/7692	20.09.2024 11:15:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/7691	20.09.2024 11:45:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/7691	20.09.2024 11:45:00	C2 - Brest	Temperatura (na terenu)	17,8	°C
2024/7691	20.09.2024 11:45:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7691	20.09.2024 11:45:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7691	20.09.2024 11:45:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/7691	20.09.2024 11:45:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/7773	24.09.2024 09:20:00	C2 - Brest	Vonj	brez	-
2024/7773	24.09.2024 09:20:00	C2 - Brest	Vidne nečistoče	brez	-
2024/7779	24.09.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/7773	24.09.2024 09:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/7773	24.09.2024 09:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/7773	24.09.2024 09:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/7773	24.09.2024 09:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,47	mg/L
2024/7773	24.09.2024 09:20:00	C2 - Brest	Električna prevodnost (20°C)	454	uS/cm
2024/7773	24.09.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	20,8	°C
2024/7779	24.09.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	20,8	°C
2024/7773	24.09.2024 09:20:00	C2 - Brest	pH-vrednost	7,5	-
2024/7779	24.09.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7779	24.09.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7779	24.09.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	11	cfu/mL
2024/7779	24.09.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	18	cfu/mL
2024/7773	24.09.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/7773	24.09.2024 09:20:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/7773	24.09.2024 09:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/7774	24.09.2024 09:50:00	C2 - Brest	Vonj	brez	-
2024/7774	24.09.2024 09:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/7781	24.09.2024 09:50:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/7774	24.09.2024 09:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/7774	24.09.2024 09:50:00	C2 - Brest	Motnost	0,13	NTU
2024/7774	24.09.2024 09:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/7774	24.09.2024 09:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,44	mg/L
2024/7774	24.09.2024 09:50:00	C2 - Brest	Električna prevodnost (20°C)	445	uS/cm
2024/7774	24.09.2024 09:50:00	C2 - Brest	Temperatura (na terenu)	21,7	°C
2024/7781	24.09.2024 09:50:00	C2 - Brest	Temperatura (na terenu)	21,7	°C
2024/7774	24.09.2024 09:50:00	C2 - Brest	pH-vrednost	7,5	-
2024/7781	24.09.2024 09:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7781	24.09.2024 09:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7781	24.09.2024 09:50:00	C2 - Brest	Število kolonij pri 36°C	35	cfu/mL
2024/7781	24.09.2024 09:50:00	C2 - Brest	Število kolonij pri 22°C	23	cfu/mL
2024/7774	24.09.2024 09:50:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/7774	24.09.2024 09:50:00	C2 - Brest	Absorbanca-barva	0,0009	
2024/7774	24.09.2024 09:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/7802	25.09.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/7851	25.09.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/7802	25.09.2024 08:30:00	C2 - Brest	Nitratri dušik	1,75	mg/L
2024/7802	25.09.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	16,5	°C

2024/7851	25.09.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	16,5	°C
2024/7802	25.09.2024 08:30:00	C2 - Brest	Tetrakloroeten	<0.5	ug/L
2024/7802	25.09.2024 08:30:00	C2 - Brest	Trikloroeten	<0.5	ug/L
2024/7851	25.09.2024 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/7851	25.09.2024 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/7851	25.09.2024 08:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/7851	25.09.2024 08:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/7802	25.09.2024 08:30:00	C2 - Brest	Nitrat	7,75	mg/L
2024/7995	30.09.2024 08:35:00	C2 - Brest	Vonj	brez	-
2024/7995	30.09.2024 08:35:00	C2 - Brest	Vidne nečistoče	brez	-
2024/8027	30.09.2024 08:35:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/7995	30.09.2024 08:35:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/7995	30.09.2024 08:35:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/7995	30.09.2024 08:35:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/7995	30.09.2024 08:35:00	C2 - Brest	Celotni organski ogljik (TOC)	0,46	mg/L
2024/7995	30.09.2024 08:35:00	C2 - Brest	Električna prevodnost (20°C)	431	uS/cm
2024/7995	30.09.2024 08:35:00	C2 - Brest	Temperatura (na terenu)	18,6	°C
2024/8027	30.09.2024 08:35:00	C2 - Brest	Temperatura (na terenu)	18,6	°C
2024/7995	30.09.2024 08:35:00	C2 - Brest	pH-vrednost	7,4	-
2024/8027	30.09.2024 08:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8027	30.09.2024 08:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8027	30.09.2024 08:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8027	30.09.2024 08:35:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/7995	30.09.2024 08:35:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/7995	30.09.2024 08:35:00	C2 - Brest	Absorbanca-barva	0,0002	
2024/7995	30.09.2024 08:35:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/8072	01.10.2024 09:20:00	C2 - Brest	Vonj	brez	-
2024/8072	01.10.2024 09:20:00	C2 - Brest	Vidne nečistoče	brez	-
2024/8060	01.10.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/8072	01.10.2024 09:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/8072	01.10.2024 09:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/8072	01.10.2024 09:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/8072	01.10.2024 09:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,4	mg/L
2024/8072	01.10.2024 09:20:00	C2 - Brest	Električna prevodnost (20°C)	440	uS/cm
2024/8072	01.10.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	16,7	°C
2024/8060	01.10.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	16,7	°C
2024/8072	01.10.2024 09:20:00	C2 - Brest	pH-vrednost	7,7	-
2024/8060	01.10.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8060	01.10.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8060	01.10.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8060	01.10.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/8072	01.10.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/8072	01.10.2024 09:20:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/8072	01.10.2024 09:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/8075	01.10.2024 09:35:00	C2 - Brest	Vonj	brez	-
2024/8075	01.10.2024 09:35:00	C2 - Brest	Vidne nečistoče	brez	-
2024/8106	01.10.2024 09:35:00	C2 - Brest	Klor - prosti (na terenu)	0,1	mg/L
2024/8075	01.10.2024 09:35:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/8075	01.10.2024 09:35:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/8075	01.10.2024 09:35:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/8075	01.10.2024 09:35:00	C2 - Brest	Celotni organski ogljik (TOC)	0,61	mg/L
2024/8075	01.10.2024 09:35:00	C2 - Brest	Električna prevodnost (20°C)	438	uS/cm
2024/8075	01.10.2024 09:35:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/8106	01.10.2024 09:35:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/8075	01.10.2024 09:35:00	C2 - Brest	pH-vrednost	7,4	-
2024/8106	01.10.2024 09:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8106	01.10.2024 09:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8106	01.10.2024 09:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8106	01.10.2024 09:35:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/8075	01.10.2024 09:35:00	C2 - Brest	Klor - prosti (na terenu)	0,1	mg/L
2024/8075	01.10.2024 09:35:00	C2 - Brest	Absorbanca-barva	0,0006	
2024/8075	01.10.2024 09:35:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L

2024/8073	01.10.2024 09:50:00	C2 - Brest	Vonj	brez	-
2024/8073	01.10.2024 09:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/8061	01.10.2024 09:50:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/8073	01.10.2024 09:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/8073	01.10.2024 09:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/8073	01.10.2024 09:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/8073	01.10.2024 09:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,74	mg/L
2024/8073	01.10.2024 09:50:00	C2 - Brest	Električna prevodnost (20°C)	440	uS/cm
2024/8073	01.10.2024 09:50:00	C2 - Brest	Temperatura (na terenu)	16,3	°C
2024/8061	01.10.2024 09:50:00	C2 - Brest	Temperatura (na terenu)	16,3	°C
2024/8073	01.10.2024 09:50:00	C2 - Brest	pH-vrednost	7,7	-
2024/8061	01.10.2024 09:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8061	01.10.2024 09:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8061	01.10.2024 09:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8061	01.10.2024 09:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/8073	01.10.2024 09:50:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/8073	01.10.2024 09:50:00	C2 - Brest	Absorbanca-barva	0	
2024/8073	01.10.2024 09:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/8074	01.10.2024 10:45:00	C2 - Brest	Vonj	brez	-
2024/8074	01.10.2024 10:45:00	C2 - Brest	Vidne nečistoče	brez	-
2024/8074	01.10.2024 10:45:00	C2 - Brest	Prosti klordioksid (na terenu)	0,17	mg/L
2024/8105	01.10.2024 10:45:00	C2 - Brest	Prosti klordioksid (na terenu)	0,17	mg/L
2024/8074	01.10.2024 10:45:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/8074	01.10.2024 10:45:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/8074	01.10.2024 10:45:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/8074	01.10.2024 10:45:00	C2 - Brest	Celotni organski ogljik (TOC)	0,5	mg/L
2024/8074	01.10.2024 10:45:00	C2 - Brest	Električna prevodnost (20°C)	434	uS/cm
2024/8074	01.10.2024 10:45:00	C2 - Brest	Temperatura (na terenu)	11,6	°C
2024/8105	01.10.2024 10:45:00	C2 - Brest	Temperatura (na terenu)	11,6	°C
2024/8074	01.10.2024 10:45:00	C2 - Brest	pH-vrednost	7,5	-
2024/8105	01.10.2024 10:45:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8105	01.10.2024 10:45:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8105	01.10.2024 10:45:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8105	01.10.2024 10:45:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/8074	01.10.2024 10:45:00	C2 - Brest	Absorbanca-barva	0,0008	
2024/8074	01.10.2024 10:45:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/8179	03.10.2024 08:00:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/8179	03.10.2024 08:00:00	C2 - Brest	Temperatura (na terenu)	21,6	°C
2024/8179	03.10.2024 08:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8179	03.10.2024 08:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8179	03.10.2024 08:00:00	C2 - Brest	Število kolonij pri 36°C	13	cfu/mL
2024/8179	03.10.2024 08:00:00	C2 - Brest	Število kolonij pri 22°C	15	cfu/mL
2024/8548	15.10.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0,09	mg/L
2024/8548	15.10.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	11,7	°C
2024/8548	15.10.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8548	15.10.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8548	15.10.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8548	15.10.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/8547	15.10.2024 09:30:00	C2 - Brest	Prosti klordioksid (na terenu)	0,14	mg/L
2024/8547	15.10.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	11,8	°C
2024/8547	15.10.2024 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8547	15.10.2024 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8547	15.10.2024 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8547	15.10.2024 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/8825	23.10.2024 09:35:00	C2 - Brest	Vonj	brez	-
2024/8825	23.10.2024 09:35:00	C2 - Brest	Vidne nečistoče	brez	-
2024/8838	23.10.2024 09:35:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/8825	23.10.2024 09:35:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/8825	23.10.2024 09:35:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/8825	23.10.2024 09:35:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/8825	23.10.2024 09:35:00	C2 - Brest	Celotni organski ogljik (TOC)	0,51	mg/L
2024/8825	23.10.2024 09:35:00	C2 - Brest	Električna prevodnost (20°C)	455	uS/cm

2024/8825	23.10.2024 09:35:00	C2 - Brest	Temperatura (na terenu)	16,5	°C
2024/8838	23.10.2024 09:35:00	C2 - Brest	Temperatura (na terenu)	16,5	°C
2024/8825	23.10.2024 09:35:00	C2 - Brest	pH-vrednost	7,3	-
2024/8838	23.10.2024 09:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8838	23.10.2024 09:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8838	23.10.2024 09:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8838	23.10.2024 09:35:00	C2 - Brest	Število kolonij pri 22°C	18	cfu/mL
2024/8825	23.10.2024 09:35:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/8825	23.10.2024 09:35:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/8825	23.10.2024 09:35:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/8782	23.10.2024 10:40:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/8843	23.10.2024 10:40:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/8782	23.10.2024 10:40:00	C2 - Brest	Nitrati dušik	2,12	mg/L
2024/8782	23.10.2024 10:40:00	C2 - Brest	Temperatura (na terenu)	14,4	°C
2024/8843	23.10.2024 10:40:00	C2 - Brest	Temperatura (na terenu)	14,4	°C
2024/8782	23.10.2024 10:40:00	C2 - Brest	Tetrakloroeten	0,5	ug/L
2024/8782	23.10.2024 10:40:00	C2 - Brest	Trikloroeten	<0.5	ug/L
2024/8843	23.10.2024 10:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8843	23.10.2024 10:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8843	23.10.2024 10:40:00	C2 - Brest	Število kolonij pri 36°C	21	cfu/mL
2024/8843	23.10.2024 10:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/8782	23.10.2024 10:40:00	C2 - Brest	Nitrat	9,39	mg/L
2024/8899	24.10.2024 09:15:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/8899	24.10.2024 09:15:00	C2 - Brest	Temperatura (na terenu)	17,4	°C
2024/8899	24.10.2024 09:15:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8899	24.10.2024 09:15:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8899	24.10.2024 09:15:00	C2 - Brest	Število kolonij pri 36°C	12	cfu/mL
2024/8899	24.10.2024 09:15:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/8881	24.10.2024 09:35:00	C2 - Brest	Vonj	brez	-
2024/8881	24.10.2024 09:35:00	C2 - Brest	Vidne nečistoče	brez	-
2024/8901	24.10.2024 09:35:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/8881	24.10.2024 09:35:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/8881	24.10.2024 09:35:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/8881	24.10.2024 09:35:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/8881	24.10.2024 09:35:00	C2 - Brest	Celotni organski ogljik (TOC)	0,51	mg/L
2024/8881	24.10.2024 09:35:00	C2 - Brest	Električna prevodnost (20°C)	448	uS/cm
2024/8881	24.10.2024 09:35:00	C2 - Brest	Temperatura (na terenu)	15,8	°C
2024/8901	24.10.2024 09:35:00	C2 - Brest	Temperatura (na terenu)	15,8	°C
2024/8881	24.10.2024 09:35:00	C2 - Brest	pH-vrednost	7,4	-
2024/8901	24.10.2024 09:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8901	24.10.2024 09:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8901	24.10.2024 09:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8901	24.10.2024 09:35:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/8881	24.10.2024 09:35:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/8881	24.10.2024 09:35:00	C2 - Brest	Absorbanca-barva	0,0008	
2024/8881	24.10.2024 09:35:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/8910	24.10.2024 09:40:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/8910	24.10.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	14,7	°C
2024/8910	24.10.2024 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8910	24.10.2024 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8910	24.10.2024 09:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8910	24.10.2024 09:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/8904	24.10.2024 10:00:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/8904	24.10.2024 10:00:00	C2 - Brest	Temperatura (na terenu)	15,4	°C
2024/8904	24.10.2024 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8904	24.10.2024 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8904	24.10.2024 10:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8904	24.10.2024 10:00:00	C2 - Brest	Število kolonij pri 22°C	144	cfu/mL
2024/8908	24.10.2024 10:30:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/8908	24.10.2024 10:30:00	C2 - Brest	Temperatura (na terenu)	15,7	°C
2024/8908	24.10.2024 10:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8908	24.10.2024 10:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL

2024/8908	24.10.2024 10:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8908	24.10.2024 10:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/8882	24.10.2024 10:50:00	C2 - Brest	Vonj	brez	-
2024/8882	24.10.2024 10:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/8903	24.10.2024 10:50:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/8882	24.10.2024 10:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/8882	24.10.2024 10:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/8882	24.10.2024 10:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/8882	24.10.2024 10:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,5	mg/L
2024/8882	24.10.2024 10:50:00	C2 - Brest	Električna prevodnost (20°C)	438	uS/cm
2024/8882	24.10.2024 10:50:00	C2 - Brest	Temperatura (na terenu)	16,1	°C
2024/8903	24.10.2024 10:50:00	C2 - Brest	Temperatura (na terenu)	16,1	°C
2024/8882	24.10.2024 10:50:00	C2 - Brest	pH-vrednost	7,4	-
2024/8903	24.10.2024 10:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8903	24.10.2024 10:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8903	24.10.2024 10:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8903	24.10.2024 10:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/8882	24.10.2024 10:50:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/8882	24.10.2024 10:50:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/8882	24.10.2024 10:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/8938	25.10.2024 08:50:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/8938	25.10.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	18,5	°C
2024/8938	25.10.2024 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8938	25.10.2024 08:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8938	25.10.2024 08:50:00	C2 - Brest	Število kolonij pri 36°C	14	cfu/mL
2024/8938	25.10.2024 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/8939	25.10.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/8939	25.10.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	17	°C
2024/8939	25.10.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/8939	25.10.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/8939	25.10.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/8939	25.10.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9053	30.10.2024 09:35:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/9053	30.10.2024 09:35:00	C2 - Brest	Temperatura (na terenu)	17,6	°C
2024/9053	30.10.2024 09:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9053	30.10.2024 09:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9053	30.10.2024 09:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9053	30.10.2024 09:35:00	C2 - Brest	Število kolonij pri 22°C	13	cfu/mL
2024/9069	04.11.2024 08:00:00	C2 - Brest	Vonj	brez	-
2024/9069	04.11.2024 08:00:00	C2 - Brest	Vidne nečistoče	brez	-
2024/9081	04.11.2024 08:00:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/9069	04.11.2024 08:00:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/9069	04.11.2024 08:00:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/9069	04.11.2024 08:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/9069	04.11.2024 08:00:00	C2 - Brest	Celotni organski ogljik (TOC)	0,69	mg/L
2024/9069	04.11.2024 08:00:00	C2 - Brest	Električna prevodnost (20°C)	455	uS/cm
2024/9069	04.11.2024 08:00:00	C2 - Brest	Temperatura (na terenu)	14,7	°C
2024/9081	04.11.2024 08:00:00	C2 - Brest	Temperatura (na terenu)	14,7	°C
2024/9069	04.11.2024 08:00:00	C2 - Brest	pH-vrednost	7,7	-
2024/9081	04.11.2024 08:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9081	04.11.2024 08:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9081	04.11.2024 08:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9081	04.11.2024 08:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9069	04.11.2024 08:00:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/9069	04.11.2024 08:00:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/9069	04.11.2024 08:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/9070	04.11.2024 08:30:00	C2 - Brest	Vonj	brez	-
2024/9070	04.11.2024 08:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/9082	04.11.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/9070	04.11.2024 08:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/9070	04.11.2024 08:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/9070	04.11.2024 08:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L

2024/9070	04.11.2024 08:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,51	mg/L
2024/9070	04.11.2024 08:30:00	C2 - Brest	Električna prevodnost (20°C)	451	uS/cm
2024/9070	04.11.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	14,2	°C
2024/9082	04.11.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	14,2	°C
2024/9070	04.11.2024 08:30:00	C2 - Brest	pH-vrednost	7,6	-
2024/9082	04.11.2024 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9082	04.11.2024 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9082	04.11.2024 08:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9082	04.11.2024 08:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9070	04.11.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/9070	04.11.2024 08:30:00	C2 - Brest	Absorbanca-barva	0,0002	
2024/9070	04.11.2024 08:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/9135	05.11.2024 09:20:00	C2 - Brest	Vonj	brez	-
2024/9135	05.11.2024 09:20:00	C2 - Brest	Vidne nečistoče	brez	-
2024/9137	05.11.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)		mg/L
2024/9135	05.11.2024 09:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/9135	05.11.2024 09:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/9135	05.11.2024 09:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/9135	05.11.2024 09:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,48	mg/L
2024/9135	05.11.2024 09:20:00	C2 - Brest	Električna prevodnost (20°C)	444	uS/cm
2024/9135	05.11.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	11,5	°C
2024/9137	05.11.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	11,5	°C
2024/9135	05.11.2024 09:20:00	C2 - Brest	pH-vrednost	7,4	-
2024/9137	05.11.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9137	05.11.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9137	05.11.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9137	05.11.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9135	05.11.2024 09:20:00	C2 - Brest	Klor - prosti (na terenu)	0,09	mg/L
2024/9135	05.11.2024 09:20:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/9135	05.11.2024 09:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/9134	05.11.2024 10:30:00	C2 - Brest	Vonj	brez	-
2024/9134	05.11.2024 10:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/9134	05.11.2024 10:30:00	C2 - Brest	Prosti klordioksid (na terenu)	0,16	mg/L
2024/9136	05.11.2024 10:30:00	C2 - Brest	Prosti klordioksid (na terenu)		mg/L
2024/9134	05.11.2024 10:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/9134	05.11.2024 10:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/9134	05.11.2024 10:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/9134	05.11.2024 10:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,99	mg/L
2024/9134	05.11.2024 10:30:00	C2 - Brest	Električna prevodnost (20°C)	611	uS/cm
2024/9134	05.11.2024 10:30:00	C2 - Brest	Temperatura (na terenu)	13,5	°C
2024/9136	05.11.2024 10:30:00	C2 - Brest	Temperatura (na terenu)	13,5	°C
2024/9134	05.11.2024 10:30:00	C2 - Brest	pH-vrednost	7,1	-
2024/9136	05.11.2024 10:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9136	05.11.2024 10:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9136	05.11.2024 10:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9136	05.11.2024 10:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9134	05.11.2024 10:30:00	C2 - Brest	Absorbanca-barva	0,0005	
2024/9134	05.11.2024 10:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/9201	07.11.2024 07:40:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/9201	07.11.2024 07:40:00	C2 - Brest	Temperatura (na terenu)	16,1	°C
2024/9201	07.11.2024 07:40:00	C2 - Brest	Pseudomonas aeruginosa	0	cfu/100mL
2024/9201	07.11.2024 07:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9201	07.11.2024 07:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9201	07.11.2024 07:40:00	C2 - Brest	Število kolonij pri 36°C	10	cfu/mL
2024/9201	07.11.2024 07:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9477	15.11.2024 08:20:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/9477	15.11.2024 08:20:00	C2 - Brest	Temperatura (na terenu)	14,6	°C
2024/9477	15.11.2024 08:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9477	15.11.2024 08:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9477	15.11.2024 08:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9477	15.11.2024 08:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9468	15.11.2024 09:55:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L

2024/9468	15.11.2024 09:55:00	C2 - Brest	Temperatura (na terenu)	14,2	°C
2024/9468	15.11.2024 09:55:00	C2 - Brest	Pseudomonas aeruginosa	0	cfu/100mL
2024/9468	15.11.2024 09:55:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9468	15.11.2024 09:55:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9468	15.11.2024 09:55:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9468	15.11.2024 09:55:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9586	19.11.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	0,16	mg/L
2024/9586	19.11.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	11,7	°C
2024/9586	19.11.2024 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9586	19.11.2024 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9586	19.11.2024 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9586	19.11.2024 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9585	19.11.2024 09:20:00	C2 - Brest	Prosti klordioksid (na terenu)	0,14	mg/L
2024/9585	19.11.2024 09:20:00	C2 - Brest	Temperatura (na terenu)	11,7	°C
2024/9585	19.11.2024 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9585	19.11.2024 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9585	19.11.2024 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9585	19.11.2024 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9840	27.11.2024 09:40:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/9813	27.11.2024 09:40:00	C2 - Brest	Nitratni dušik	2,02	mg/L
2024/9813	27.11.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	12	°C
2024/9840	27.11.2024 09:40:00	C2 - Brest	Temperatura (na terenu)	12	°C
2024/9813	27.11.2024 09:40:00	C2 - Brest	Tetrakloroeten	<0,5	ug/L
2024/9813	27.11.2024 09:40:00	C2 - Brest	Trikloroeten	<0,5	ug/L
2024/9840	27.11.2024 09:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9840	27.11.2024 09:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9840	27.11.2024 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9840	27.11.2024 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9813	27.11.2024 09:40:00	C2 - Brest	Nitrat	8,95	mg/L
2024/9836	27.11.2024 10:00:00	C2 - Brest	Vonj	brez	-
2024/9836	27.11.2024 10:00:00	C2 - Brest	Vidne nečistoče	brez	-
2024/9853	27.11.2024 10:00:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/9836	27.11.2024 10:00:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/9836	27.11.2024 10:00:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/9836	27.11.2024 10:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/9836	27.11.2024 10:00:00	C2 - Brest	Celotni organski ogljik (TOC)	0,45	mg/L
2024/9836	27.11.2024 10:00:00	C2 - Brest	Električna prevodnost (20°C)	436	uS/cm
2024/9836	27.11.2024 10:00:00	C2 - Brest	Temperatura (na terenu)	14,5	°C
2024/9853	27.11.2024 10:00:00	C2 - Brest	Temperatura (na terenu)	14,5	°C
2024/9836	27.11.2024 10:00:00	C2 - Brest	pH-vrednost	7,5	-
2024/9853	27.11.2024 10:00:00	C2 - Brest	Število kolonij pri 36°C	12	cfu/mL
2024/9853	27.11.2024 10:00:00	C2 - Brest	Število kolonij pri 22°C	16	cfu/mL
2024/9853	27.11.2024 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9853	27.11.2024 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9836	27.11.2024 10:00:00	C2 - Brest	Klor - prosti (na terenu)	0,03	mg/L
2024/9836	27.11.2024 10:00:00	C2 - Brest	Absorbanca-barva	0,0006	
2024/9836	27.11.2024 10:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/9871	28.11.2024 08:30:00	C2 - Brest	Vonj	brez	-
2024/9871	28.11.2024 08:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/9873	28.11.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/9871	28.11.2024 08:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/9871	28.11.2024 08:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/9871	28.11.2024 08:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/9871	28.11.2024 08:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,5	mg/L
2024/9871	28.11.2024 08:30:00	C2 - Brest	Električna prevodnost (20°C)	453	uS/cm
2024/9871	28.11.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/9873	28.11.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/9871	28.11.2024 08:30:00	C2 - Brest	pH-vrednost	7,4	-
2024/9873	28.11.2024 08:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9873	28.11.2024 08:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9873	28.11.2024 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9873	28.11.2024 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL

2024/9871	28.11.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/9871	28.11.2024 08:30:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/9871	28.11.2024 08:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/9874	28.11.2024 08:45:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/9874	28.11.2024 08:45:00	C2 - Brest	Temperatura (na terenu)	13,6	°C
2024/9874	28.11.2024 08:45:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9874	28.11.2024 08:45:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9874	28.11.2024 08:45:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9874	28.11.2024 08:45:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9876	28.11.2024 09:05:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/9876	28.11.2024 09:05:00	C2 - Brest	Temperatura (na terenu)	12,6	°C
2024/9876	28.11.2024 09:05:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9876	28.11.2024 09:05:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9876	28.11.2024 09:05:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9876	28.11.2024 09:05:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9872	28.11.2024 09:30:00	C2 - Brest	Vonj	brez	-
2024/9872	28.11.2024 09:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/9875	28.11.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/9872	28.11.2024 09:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/9872	28.11.2024 09:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/9872	28.11.2024 09:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/9872	28.11.2024 09:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,5	mg/L
2024/9872	28.11.2024 09:30:00	C2 - Brest	Električna prevodnost (20°C)	442	uS/cm
2024/9872	28.11.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	14,6	°C
2024/9875	28.11.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	14,6	°C
2024/9872	28.11.2024 09:30:00	C2 - Brest	pH-vrednost	7,4	-
2024/9875	28.11.2024 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9875	28.11.2024 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9875	28.11.2024 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9875	28.11.2024 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9872	28.11.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/9872	28.11.2024 09:30:00	C2 - Brest	Absorbanca-barva	0,0006	
2024/9872	28.11.2024 09:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/9877	28.11.2024 10:00:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/9877	28.11.2024 10:00:00	C2 - Brest	Temperatura (na terenu)	11,9	°C
2024/9877	28.11.2024 10:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9877	28.11.2024 10:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9877	28.11.2024 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9877	28.11.2024 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9879	28.11.2024 10:35:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/9879	28.11.2024 10:35:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/9879	28.11.2024 10:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9879	28.11.2024 10:35:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9879	28.11.2024 10:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9879	28.11.2024 10:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/9878	28.11.2024 11:00:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/9878	28.11.2024 11:00:00	C2 - Brest	Temperatura (na terenu)	12,3	°C
2024/9878	28.11.2024 11:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/9878	28.11.2024 11:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/9878	28.11.2024 11:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/9878	28.11.2024 11:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10005	03.12.2024 09:30:00	C2 - Brest	Vonj	brez	-
2024/10005	03.12.2024 09:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/10008	03.12.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0,09	mg/L
2024/10005	03.12.2024 09:30:00	C2 - Brest	Barva (436 nm)	0,04	m-1
2024/10005	03.12.2024 09:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/10005	03.12.2024 09:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/10005	03.12.2024 09:30:00	C2 - Brest	Celotni organski ogljik (TOC)	1,13	mg/L
2024/10005	03.12.2024 09:30:00	C2 - Brest	Električna prevodnost (20°C)	427	uS/cm
2024/10005	03.12.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/10008	03.12.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/10005	03.12.2024 09:30:00	C2 - Brest	pH-vrednost	7,4	-

2024/10008	03.12.2024 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/10008	03.12.2024 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/10008	03.12.2024 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10008	03.12.2024 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10005	03.12.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0,09	mg/L
2024/10005	03.12.2024 09:30:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/10005	03.12.2024 09:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/10004	03.12.2024 11:10:00	C2 - Brest	Vonj	brez	-
2024/10004	03.12.2024 11:10:00	C2 - Brest	Vidne nečistoče	brez	-
2024/10004	03.12.2024 11:10:00	C2 - Brest	Prosti klordioksid (na terenu)	0,2	mg/L
2024/10007	03.12.2024 11:10:00	C2 - Brest	Prosti klordioksid (na terenu)	0,2	mg/L
2024/10004	03.12.2024 11:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/10004	03.12.2024 11:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/10004	03.12.2024 11:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/10004	03.12.2024 11:10:00	C2 - Brest	Celotni organski ogljik (TOC)	1,19	mg/L
2024/10004	03.12.2024 11:10:00	C2 - Brest	Električna prevodnost (20°C)	581	uS/cm
2024/10004	03.12.2024 11:10:00	C2 - Brest	Temperatura (na terenu)	12,5	°C
2024/10007	03.12.2024 11:10:00	C2 - Brest	Temperatura (na terenu)	12,5	°C
2024/10004	03.12.2024 11:10:00	C2 - Brest	pH-vrednost	7,1	-
2024/10007	03.12.2024 11:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/10007	03.12.2024 11:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/10007	03.12.2024 11:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10007	03.12.2024 11:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10004	03.12.2024 11:10:00	C2 - Brest	Absorbanca-barva	0,00195	
2024/10004	03.12.2024 11:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/10098	05.12.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/10098	05.12.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	15,9	°C
2024/10098	05.12.2024 08:30:00	C2 - Brest	Število kolonij pri 36°C	13	cfu/mL
2024/10098	05.12.2024 08:30:00	C2 - Brest	Število kolonij pri 22°C	12	cfu/mL
2024/10098	05.12.2024 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10098	05.12.2024 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10089	05.12.2024 09:00:00	C2 - Brest	Vonj	brez	-
2024/10089	05.12.2024 09:00:00	C2 - Brest	Vidne nečistoče	brez	-
2024/10100	05.12.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/10089	05.12.2024 09:00:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/10089	05.12.2024 09:00:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/10089	05.12.2024 09:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/10089	05.12.2024 09:00:00	C2 - Brest	Celotni organski ogljik (TOC)	0,51	mg/L
2024/10089	05.12.2024 09:00:00	C2 - Brest	Električna prevodnost (20°C)	452	uS/cm
2024/10089	05.12.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	11,6	°C
2024/10100	05.12.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	11,6	°C
2024/10089	05.12.2024 09:00:00	C2 - Brest	pH-vrednost	7,7	-
2024/10100	05.12.2024 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/10100	05.12.2024 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/10100	05.12.2024 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10100	05.12.2024 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10089	05.12.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/10089	05.12.2024 09:00:00	C2 - Brest	Absorbanca-barva	0,0002	
2024/10089	05.12.2024 09:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/10090	05.12.2024 09:30:00	C2 - Brest	Vonj	brez	-
2024/10090	05.12.2024 09:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/10101	05.12.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/10090	05.12.2024 09:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/10090	05.12.2024 09:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/10090	05.12.2024 09:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/10090	05.12.2024 09:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,52	mg/L
2024/10090	05.12.2024 09:30:00	C2 - Brest	Električna prevodnost (20°C)	448	uS/cm
2024/10090	05.12.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	10,8	°C
2024/10101	05.12.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	10,8	°C
2024/10090	05.12.2024 09:30:00	C2 - Brest	pH-vrednost	7,7	-
2024/10101	05.12.2024 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/10101	05.12.2024 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL

2024/10101	05.12.2024 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10101	05.12.2024 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10090	05.12.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	<LOQ=0.02	mg/L
2024/10090	05.12.2024 09:30:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/10090	05.12.2024 09:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/10099	05.12.2024 10:00:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/10099	05.12.2024 10:00:00	C2 - Brest	Temperatura (na terenu)	15,5	°C
2024/10099	05.12.2024 10:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/10099	05.12.2024 10:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/10099	05.12.2024 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10099	05.12.2024 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10125	06.12.2024 08:40:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/10125	06.12.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	13,6	°C
2024/10125	06.12.2024 08:40:00	C2 - Brest	Število kolonij pri 36°C	13	cfu/mL
2024/10125	06.12.2024 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/10125	06.12.2024 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10125	06.12.2024 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10390	16.12.2024 09:10:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/10390	16.12.2024 09:10:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/10390	16.12.2024 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/10390	16.12.2024 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/10390	16.12.2024 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10390	16.12.2024 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10384	16.12.2024 09:30:00	C2 - Brest	Vonj	brez	-
2024/10384	16.12.2024 09:30:00	C2 - Brest	Vidne nečistoče	brez	-
2024/10384	16.12.2024 09:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/10384	16.12.2024 09:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/10384	16.12.2024 09:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/10384	16.12.2024 09:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,61	mg/L
2024/10384	16.12.2024 09:30:00	C2 - Brest	Električna prevodnost (20°C)	461	uS/cm
2024/10384	16.12.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	11,4	°C
2024/10384	16.12.2024 09:30:00	C2 - Brest	pH-vrednost	7,4	-
2024/10384	16.12.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0,04	mg/L
2024/10384	16.12.2024 09:30:00	C2 - Brest	Absorbanca-barva	0,0001	
2024/10384	16.12.2024 09:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/10421	17.12.2024 08:40:00	C2 - Brest	Klor - prosti (na terenu)	0,13	mg/L
2024/10421	17.12.2024 08:40:00	C2 - Brest	Temperatura (na terenu)	11,3	°C
2024/10421	17.12.2024 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/10421	17.12.2024 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/10421	17.12.2024 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10421	17.12.2024 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10420	17.12.2024 08:50:00	C2 - Brest	Prosti klordiodksid (na terenu)	0,2	mg/L
2024/10420	17.12.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	12,7	°C
2024/10420	17.12.2024 08:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/10420	17.12.2024 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/10420	17.12.2024 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10420	17.12.2024 08:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10512	19.12.2024 08:20:00	C2 - Brest	Vonj	brez	-
2024/10512	19.12.2024 08:20:00	C2 - Brest	Vidne nečistoče	brez	-
2024/10526	19.12.2024 08:20:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/10512	19.12.2024 08:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/10512	19.12.2024 08:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/10512	19.12.2024 08:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/10512	19.12.2024 08:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,46	mg/L
2024/10512	19.12.2024 08:20:00	C2 - Brest	Električna prevodnost (20°C)	420	uS/cm
2024/10512	19.12.2024 08:20:00	C2 - Brest	Temperatura (na terenu)	11,2	°C
2024/10526	19.12.2024 08:20:00	C2 - Brest	Temperatura (na terenu)	11,2	°C
2024/10512	19.12.2024 08:20:00	C2 - Brest	pH-vrednost	7,5	-
2024/10526	19.12.2024 08:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/10526	19.12.2024 08:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/10526	19.12.2024 08:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10526	19.12.2024 08:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL

2024/10512	19.12.2024 08:20:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/10512	19.12.2024 08:20:00	C2 - Brest	Absorbanca-barva	0,0002	
2024/10512	19.12.2024 08:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/10510	19.12.2024 08:50:00	C2 - Brest	Vonj	brez	-
2024/10510	19.12.2024 08:50:00	C2 - Brest	Vidne nečistoče	brez	-
2024/10525	19.12.2024 08:50:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/10510	19.12.2024 08:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1
2024/10510	19.12.2024 08:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU
2024/10510	19.12.2024 08:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L
2024/10510	19.12.2024 08:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,64	mg/L
2024/10510	19.12.2024 08:50:00	C2 - Brest	Električna prevodnost (20°C)	453	uS/cm
2024/10510	19.12.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	10,4	°C
2024/10525	19.12.2024 08:50:00	C2 - Brest	Temperatura (na terenu)	10,4	°C
2024/10510	19.12.2024 08:50:00	C2 - Brest	pH-vrednost	7,4	-
2024/10525	19.12.2024 08:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/10525	19.12.2024 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/10525	19.12.2024 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10525	19.12.2024 08:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10510	19.12.2024 08:50:00	C2 - Brest	Klor - prosti (na terenu)	0,02	mg/L
2024/10510	19.12.2024 08:50:00	C2 - Brest	Absorbanca-barva	0,0003	
2024/10510	19.12.2024 08:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L
2024/10481	19.12.2024 10:40:00	C2 - Brest	Nitratni dušik	1,93	mg/L
2024/10481	19.12.2024 10:40:00	C2 - Brest	Temperatura (na terenu)	11	°C
2024/10517	19.12.2024 10:40:00	C2 - Brest	Temperatura (na terenu)	11	°C
2024/10481	19.12.2024 10:40:00	C2 - Brest	Tetrakloroeten	<0.5	ug/L
2024/10481	19.12.2024 10:40:00	C2 - Brest	Trikloroeten	<0.5	ug/L
2024/10517	19.12.2024 10:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/10517	19.12.2024 10:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/10517	19.12.2024 10:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10517	19.12.2024 10:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10481	19.12.2024 10:40:00	C2 - Brest	Nitrat	8,55	mg/L
2024/10690	31.12.2024 08:30:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/10690	31.12.2024 08:30:00	C2 - Brest	Temperatura (na terenu)	18	°C
2024/10690	31.12.2024 08:30:00	C2 - Brest	Število kolonij pri 36°C	110	cfu/mL
2024/10690	31.12.2024 08:30:00	C2 - Brest	Število kolonij pri 22°C	104	cfu/mL
2024/10690	31.12.2024 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10690	31.12.2024 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10691	31.12.2024 09:00:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/10691	31.12.2024 09:00:00	C2 - Brest	Temperatura (na terenu)	9,7	°C
2024/10691	31.12.2024 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/10691	31.12.2024 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/10691	31.12.2024 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10691	31.12.2024 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL
2024/10692	31.12.2024 09:30:00	C2 - Brest	Klor - prosti (na terenu)	0	mg/L
2024/10692	31.12.2024 09:30:00	C2 - Brest	Temperatura (na terenu)	8,8	°C
2024/10692	31.12.2024 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL
2024/10692	31.12.2024 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL
2024/10692	31.12.2024 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL
2024/10692	31.12.2024 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL