

Lab. št.	Datum odvzema	Območje	Parameter	Rezultat	Enota	Mejna vrednost
2026/88	06.01.2026 09:15:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/88	06.01.2026 09:15:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/88	06.01.2026 09:15:00	C2 - Brest	Prosti klor	0,08	mg/L	ni mej
2026/88	06.01.2026 09:15:00	C2 - Brest	Število kolonij pri 22°C	10	cfu/mL	brez neobičajne spremembe
2026/88	06.01.2026 09:15:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/88	06.01.2026 09:15:00	C2 - Brest	Temperatura vode	11,8	°C	ni mej
2026/94	06.01.2026 09:15:00	C2 - Brest	Absorbanca-barva	0,0004		ni mej
2026/94	06.01.2026 09:15:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/94	06.01.2026 09:15:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/94	06.01.2026 09:15:00	C2 - Brest	Celotni organski ogljik (TOC)	0,43	mg/L	brez neobičajne spremembe
2026/94	06.01.2026 09:15:00	C2 - Brest	Električna prevodnost (20°C)	430	uS/cm	<2500
2026/94	06.01.2026 09:15:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/94	06.01.2026 09:15:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/94	06.01.2026 09:15:00	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/94	06.01.2026 09:15:00	C2 - Brest	Prosti klor	0,08	mg/L	ni mej
2026/94	06.01.2026 09:15:00	C2 - Brest	Temperatura vode	11,8	°C	ni mej
2026/94	06.01.2026 09:15:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/94	06.01.2026 09:15:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/87	06.01.2026 10:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/87	06.01.2026 10:35:00	C2 - Brest	Klor dioksid	0,17	mg/L	ni mej
2026/87	06.01.2026 10:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/87	06.01.2026 10:35:00	C2 - Brest	Število kolonij pri 22°C	30	cfu/mL	brez neobičajne spremembe
2026/87	06.01.2026 10:35:00	C2 - Brest	Število kolonij pri 36°C	10	cfu/mL	<100
2026/87	06.01.2026 10:35:00	C2 - Brest	Temperatura vode	11,7	°C	ni mej
2026/92	06.01.2026 10:35:00	C2 - Brest	Absorbanca-barva	0,0015		ni mej
2026/92	06.01.2026 10:35:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/92	06.01.2026 10:35:00	C2 - Brest	Barva (436 nm)	0,03	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/92	06.01.2026 10:35:00	C2 - Brest	Celotni organski ogljik (TOC)	0,44	mg/L	brez neobičajne spremembe
2026/92	06.01.2026 10:35:00	C2 - Brest	Električna prevodnost (20°C)	430	uS/cm	<2500
2026/92	06.01.2026 10:35:00	C2 - Brest	Klor dioksid	0,17	mg/L	ni mej
2026/92	06.01.2026 10:35:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/92	06.01.2026 10:35:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/92	06.01.2026 10:35:00	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/92	06.01.2026 10:35:00	C2 - Brest	Temperatura vode	11,7	°C	ni mej
2026/92	06.01.2026 10:35:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/92	06.01.2026 10:35:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/89	06.01.2026 11:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/89	06.01.2026 11:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/89	06.01.2026 11:50:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/89	06.01.2026 11:50:00	C2 - Brest	Število kolonij pri 22°C	21	cfu/mL	brez neobičajne spremembe
2026/89	06.01.2026 11:50:00	C2 - Brest	Število kolonij pri 36°C	17	cfu/mL	<100
2026/89	06.01.2026 11:50:00	C2 - Brest	Temperatura vode	10,2	°C	ni mej
2026/124	07.01.2026 08:30:00	C2 - Brest	Absorbanca-barva	0,0004		ni mej
2026/124	07.01.2026 08:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/124	07.01.2026 08:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/124	07.01.2026 08:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,43	mg/L	brez neobičajne spremembe
2026/124	07.01.2026 08:30:00	C2 - Brest	Električna prevodnost (20°C)	441	uS/cm	<2500
2026/124	07.01.2026 08:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/124	07.01.2026 08:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/124	07.01.2026 08:30:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/124	07.01.2026 08:30:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/124	07.01.2026 08:30:00	C2 - Brest	Temperatura vode	12,6	°C	ni mej
2026/124	07.01.2026 08:30:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/124	07.01.2026 08:30:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/130	07.01.2026 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/130	07.01.2026 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/130	07.01.2026 08:30:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/130	07.01.2026 08:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/130	07.01.2026 08:30:00	C2 - Brest	Število kolonij pri 36°C	19	cfu/mL	<100
2026/130	07.01.2026 08:30:00	C2 - Brest	Temperatura vode	12,6	°C	ni mej
2026/125	07.01.2026 09:10:00	C2 - Brest	Absorbanca-barva	0,0004		ni mej
2026/125	07.01.2026 09:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/125	07.01.2026 09:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/125	07.01.2026 09:10:00	C2 - Brest	Celotni organski ogljik (TOC)	0,46	mg/L	brez neobičajne spremembe
2026/125	07.01.2026 09:10:00	C2 - Brest	Električna prevodnost (20°C)	458	uS/cm	<2500
2026/125	07.01.2026 09:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/125	07.01.2026 09:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/125	07.01.2026 09:10:00	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5

2026/125	07.01.2026 09:10:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/125	07.01.2026 09:10:00	C2 - Brest	Temperatura vode	11,3	°C	ni mej
2026/125	07.01.2026 09:10:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/125	07.01.2026 09:10:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/131	07.01.2026 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/131	07.01.2026 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/131	07.01.2026 09:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/131	07.01.2026 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/131	07.01.2026 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/131	07.01.2026 09:10:00	C2 - Brest	Temperatura vode	11,3	°C	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	1,1,1-trikloroetan	<0.4	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	1,1,2,2-tetrakloroetan	<0.5	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	1,1,2-trikloroetan	<0.7	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	1,1-dikloroetan	<0.4	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	1,1-dikloroeten	<0.4	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	1,2-dikloroetan	<0.4	ug/L	<3
2026/258	14.01.2026 07:25:04	C2 - Brest	1H-benzotriazol	0,011	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	1-metil-1H-benzotriazol	<0.004	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	2,4 - DB	<0.016	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	2,4,5-T	<0.010	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	2,4-D	<0.015	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	2,4-DP	<0.020	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	2,6-diklorobenzamid	<0.006	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	4-metil-1H-benzotriazol	<0.004	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	5-metil-1H-benzotriazol	<0.004	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Acetoklor	<0.007	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Adsorbiljivi organski halogeni (AOX)	<6	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Alaklor	<0.007	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Aluminij	<0.9	ug/L	<200
2026/258	14.01.2026 07:25:04	C2 - Brest	Amidosulfuron	<0.013	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Aminometil fosfonska kislina	<0.09	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Amonij	<0.01	mg/L	<0.50
2026/258	14.01.2026 07:25:04	C2 - Brest	Antimon	<0.05	ug/L	<10
2026/258	14.01.2026 07:25:04	C2 - Brest	Arzen	<0.1	ug/L	<10
2026/258	14.01.2026 07:25:04	C2 - Brest	Atrazin	<0.007	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Atrazin, Desetil-	0,022	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Atrazin, Desizopropil-	<0.003	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Baker	0,0016	mg/L	<2.0
2026/258	14.01.2026 07:25:04	C2 - Brest	Barva (436 nm)	<0.2	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/258	14.01.2026 07:25:04	C2 - Brest	Bentazon	<0.012	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Benzen	<0.3	ug/L	<1
2026/258	14.01.2026 07:25:04	C2 - Brest	Bor	0,0096	mg/L	<1.5
2026/258	14.01.2026 07:25:04	C2 - Brest	Bromacil	<0.008	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Bromat	<3	ug/L	<10
2026/258	14.01.2026 07:25:04	C2 - Brest	Bromodiklorometan	<0.3	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Celotni organski ogljik - TOC	<0.3	mg/L	brez neobičajne spremembe
2026/258	14.01.2026 07:25:04	C2 - Brest	Cianazin	<0.009	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Cianid - prosti	<0.3	ug/L	<50
2026/258	14.01.2026 07:25:04	C2 - Brest	Cimoksanil	<0.01	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Clostridium perfringens s sporami	0	cfu/100mL	0
2026/258	14.01.2026 07:25:04	C2 - Brest	Dibromoklorometan	<0.3	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Dibromooctna kislina	<5	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Diflufenikan	<0.006	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Dikamba	<0.05	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Diklobenil	<0.03	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Diklorometan	<0.6	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Diklorooctna kislina	<5	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Dimetenamid	<0.001	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Dimetoat	<0.001	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Diuron	<0.007	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Električna prevodnost (20°C)	452	uS/cm	<2500
2026/258	14.01.2026 07:25:04	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/258	14.01.2026 07:25:04	C2 - Brest	Etilbenzen	<0.3	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Fenuron	<0.008	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Flufenacet	<0.003	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Fluorid	<0.05	mg/L	<1.5
2026/258	14.01.2026 07:25:04	C2 - Brest	Foramsulfuron	<0.014	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Fosfat-orto	0,0079	mg/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Glifosat	<0.09	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Glufosinat-amonijeva sol	<0.20	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Heksakloroetan	<0.4	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Hidrogenkarbonati	299	mg/L	ni mej

2026/258	14.01.2026 07:25:04	C2 - Brest	Imidakloprid	<0.003	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Intestinalni enterokoki	0	cfu/100mL	0
2026/258	14.01.2026 07:25:04	C2 - Brest	Izoproturon	<0.008	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Jodosulfuron	<0.005	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Kadmij	<0.02	ug/L	<5.0
2026/258	14.01.2026 07:25:04	C2 - Brest	Kalcij	72	mg/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Kalij	0,92	mg/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Klorat	<0.05	mg/L	<0.25
2026/258	14.01.2026 07:25:04	C2 - Brest	Klorfenvinfos	<0.002	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Klorid	5,7	mg/L	<250
2026/258	14.01.2026 07:25:04	C2 - Brest	Kloridazon	<0.004	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Klorit	<0.05	mg/L	<0.25
2026/258	14.01.2026 07:25:04	C2 - Brest	Klorotoluron	<0.009	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Klorpirifos-etil	<0.002	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Klorpirifos-metil	<0.003	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/258	14.01.2026 07:25:04	C2 - Brest	Krom	0,48	ug/L	<50
2026/258	14.01.2026 07:25:04	C2 - Brest	Krom (VI)	<10	ug/L	<50
2026/258	14.01.2026 07:25:04	C2 - Brest	kvinoksifen	<0.002	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Linuron	<0.009	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	m,p- Ksilen	<0.3	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Magnezij	19	mg/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Malation	<0.006	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	m-Alkaliteta	4,9	mmol/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Mandipropamid	<0.01	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Mangan	0,48	ug/L	<50
2026/258	14.01.2026 07:25:04	C2 - Brest	MCPA	<0.013	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	MCPB	<0.022	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	MCPP	<0.013	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Metaflumizon	<0.01	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Metalaksil	<0.001	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Metamitron	<0.005	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Metazaklor	<0.008	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Metoksuron	<0.009	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Metolaklor	<0.011	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Metolaklor-ESA	<0.017	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Metolaklor-OXA	<0.015	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Metribuzin	<0.010	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Mezosulfuron	<0.005	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Mezotrion	<0.006	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Molibden	0,14	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Monobromooacetna kislina	<5	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Monoklorooacetna kislina	<5	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Monolinuron	<0.009	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Monuron	<0.010	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Motnost	0,1	NTU	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	N,N-dietil-m-toluamid	<0.01	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Natrij	5,2	mg/L	<200
2026/258	14.01.2026 07:25:04	C2 - Brest	Nikelj	0,1	ug/L	<20
2026/258	14.01.2026 07:25:04	C2 - Brest	Nikosulfuron	<0.013	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Nitrat	11	mg/L	<50
2026/258	14.01.2026 07:25:04	C2 - Brest	Nitrat/50+nitrit/3	0,221	mg/L	<1
2026/258	14.01.2026 07:25:04	C2 - Brest	Nitrit	0,0028	mg/L	<0.50
2026/258	14.01.2026 07:25:04	C2 - Brest	o-ksilen	<0.3	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Okus	brez posebnosti	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/258	14.01.2026 07:25:04	C2 - Brest	Pendimetalin	<0.001	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Perfluorobutanojska kislina (PFBA)	0,00088	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Perfluorobutansulfonska kislina (PFBS)	0,00085	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Perfluorodekanojska kislina (PFDA)	<0.0005	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Perfluorododekanojska kislina (PFDoA)	<0.0005	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Perfluoroheksanojska kislina (PFHxA)	0,00061	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Perfluoroheksansulfonska kislina (PFHxS)	<0.0005	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Perfluoroheptanojska kislina (PFHpA)	<0.0005	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Perfluorononanojska kislina (PFNA)	<0.0005	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Perfluorooktansulfonska kislina (PFOS)	<0.0005	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Perfluoropentanojska kislina (PFPeA)	<0.0005	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Perfluoroundekanojska kislina (PFUdA)	<0.0005	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Pesticidi (vsota)	<0.05	ug/L	<0.50
2026/258	14.01.2026 07:25:04	C2 - Brest	Petoksamid	<0.021	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/258	14.01.2026 07:25:04	C2 - Brest	Pinoksaden	<0.007	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Piridat-M	<0.005	ug/L	<0.10

2026/258	14.01.2026 07:25:04	C2 - Brest	Pirimikarb	<0.009	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Prometrin	<0.010	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Propazin	<0.009	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Propikonazol	<0.002	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Prosti klor	0,04	mg/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Prosulfokarb	<0.006	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Rimsulfuron	<0.05	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Sebutilazin	<0.008	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Selen	0,15	ug/L	<20
2026/258	14.01.2026 07:25:04	C2 - Brest	Simazin	<0.009	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Skupna trdota	14,5	°N	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	S-metolaklor	<0.03	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Sulfat	8,5	mg/L	<250
2026/258	14.01.2026 07:25:04	C2 - Brest	Svinec	<0.1	ug/L	<10
2026/258	14.01.2026 07:25:04	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/258	14.01.2026 07:25:04	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/258	14.01.2026 07:25:04	C2 - Brest	Tebukonazol	<0.01	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Temperatura vode	8,2	°C	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Terbutilazin	<0.015	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Terbutilazin-desetil	<0.004	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Terbutrin	<0.013	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Tetrakloroeten (tetrakloroetilen)	<0.5	ug/L	<10
2026/258	14.01.2026 07:25:04	C2 - Brest	Tetrakloroeten+trikloroeten	<0.5	ug/L	<10
2026/258	14.01.2026 07:25:04	C2 - Brest	Tetraklorometan	<0.4	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Tiakloprid	<0.007	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Toluen	<0.3	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Triasulfuron	<0.010	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Tribenuron-metil	<0.06	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Tribromometan (bromoform)	<0.5	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Trihalometani (vsota)	<0.5	ug/L	<100
2026/258	14.01.2026 07:25:04	C2 - Brest	Trikloroeten (trikloroetilen)	<0.5	ug/L	<10
2026/258	14.01.2026 07:25:04	C2 - Brest	Triklorometan (kloroform)	<0.4	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Trikloroacetna kislina	<5	ug/L	ni mej
2026/258	14.01.2026 07:25:04	C2 - Brest	Tritosulfuron	<0.004	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Uran	0,41	ug/L	<30
2026/258	14.01.2026 07:25:04	C2 - Brest	Vinilklorid	<0.05	ug/L	<0.5
2026/258	14.01.2026 07:25:04	C2 - Brest	Vonj	brez posebnosti	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/258	14.01.2026 07:25:04	C2 - Brest	Zoksamid	<0.01	ug/L	<0.10
2026/258	14.01.2026 07:25:04	C2 - Brest	Železo	<40.00	ug/L	<200
2026/258	14.01.2026 07:25:04	C2 - Brest	Živo srebro	<0.01	ug/L	<1.0
2026/398	16.01.2026 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/398	16.01.2026 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/398	16.01.2026 09:40:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/398	16.01.2026 09:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/398	16.01.2026 09:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/398	16.01.2026 09:40:00	C2 - Brest	Temperatura vode	8,1	°C	ni mej
2026/438	19.01.2026 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/438	19.01.2026 09:00:00	C2 - Brest	Klor dioksid	0,16	mg/L	ni mej
2026/438	19.01.2026 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/438	19.01.2026 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/438	19.01.2026 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/438	19.01.2026 09:00:00	C2 - Brest	Temperatura vode	12,6	°C	ni mej
2026/439	19.01.2026 09:15:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/439	19.01.2026 09:15:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/439	19.01.2026 09:15:00	C2 - Brest	Prosti klor	0,1	mg/L	ni mej
2026/439	19.01.2026 09:15:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/439	19.01.2026 09:15:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/439	19.01.2026 09:15:00	C2 - Brest	Temperatura vode	12,1	°C	ni mej
2026/461	20.01.2026 08:50:00	C2 - Brest	Absorbanca-barva	0,0004		ni mej
2026/461	20.01.2026 08:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/461	20.01.2026 08:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/461	20.01.2026 08:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,51	mg/L	brez neobičajne spremembe
2026/461	20.01.2026 08:50:00	C2 - Brest	Električna prevodnost (20°C)	445	uS/cm	<2500
2026/461	20.01.2026 08:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/461	20.01.2026 08:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/461	20.01.2026 08:50:00	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/461	20.01.2026 08:50:00	C2 - Brest	Prosti klor	0,04	mg/L	ni mej
2026/461	20.01.2026 08:50:00	C2 - Brest	Temperatura vode	10,4	°C	ni mej
2026/461	20.01.2026 08:50:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/461	20.01.2026 08:50:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/466	20.01.2026 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0

2026/466	20.01.2026 08:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/466	20.01.2026 08:50:00	C2 - Brest	Prosti klor	0,04	mg/L	ni mej
2026/466	20.01.2026 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/466	20.01.2026 08:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/466	20.01.2026 08:50:00	C2 - Brest	Temperatura vode	10,4	°C	ni mej
2026/501	21.01.2026 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/501	21.01.2026 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/501	21.01.2026 08:30:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/501	21.01.2026 08:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/501	21.01.2026 08:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/501	21.01.2026 08:30:00	C2 - Brest	Temperatura vode	15,6	°C	ni mej
2026/687	28.01.2026 10:20:00	C2 - Brest	Nitrat	7,75	mg/L	<50
2026/687	28.01.2026 10:20:00	C2 - Brest	Prosti klor	0,04	mg/L	ni mej
2026/687	28.01.2026 10:20:00	C2 - Brest	Temperatura vode	9,7	°C	ni mej
2026/687	28.01.2026 10:20:00	C2 - Brest	Tetrakloroeten	<0.5	ug/L	<10
2026/687	28.01.2026 10:20:00	C2 - Brest	Trikloroeten	<0.5	ug/L	<10
2026/711	28.01.2026 10:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/711	28.01.2026 10:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/711	28.01.2026 10:20:00	C2 - Brest	Prosti klor	0,04	mg/L	ni mej
2026/711	28.01.2026 10:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/711	28.01.2026 10:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/711	28.01.2026 10:20:00	C2 - Brest	Temperatura vode	9,7	°C	ni mej
2026/742	29.01.2026 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/742	29.01.2026 08:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/742	29.01.2026 08:50:00	C2 - Brest	Prosti klor	0,03	mg/L	ni mej
2026/742	29.01.2026 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/742	29.01.2026 08:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/742	29.01.2026 08:50:00	C2 - Brest	Temperatura vode	7,9	°C	ni mej
2026/737	29.01.2026 09:20:00	C2 - Brest	Absorbanca-barva	0,0001		ni mej
2026/737	29.01.2026 09:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/737	29.01.2026 09:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/737	29.01.2026 09:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,47	mg/L	brez neobičajne spremembe
2026/737	29.01.2026 09:20:00	C2 - Brest	Električna prevodnost (20°C)	427	uS/cm	<2500
2026/737	29.01.2026 09:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/737	29.01.2026 09:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/737	29.01.2026 09:20:00	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/737	29.01.2026 09:20:00	C2 - Brest	Prosti klor	0,04	mg/L	ni mej
2026/737	29.01.2026 09:20:00	C2 - Brest	Temperatura vode	7,3	°C	ni mej
2026/737	29.01.2026 09:20:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/737	29.01.2026 09:20:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/741	29.01.2026 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/741	29.01.2026 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/741	29.01.2026 09:20:00	C2 - Brest	Prosti klor	0,04	mg/L	ni mej
2026/741	29.01.2026 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/741	29.01.2026 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/741	29.01.2026 09:20:00	C2 - Brest	Temperatura vode	7,3	°C	ni mej
2026/743	29.01.2026 09:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/743	29.01.2026 09:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/743	29.01.2026 09:50:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/743	29.01.2026 09:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/743	29.01.2026 09:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/743	29.01.2026 09:50:00	C2 - Brest	Temperatura vode	9	°C	ni mej
2026/738	29.01.2026 10:20:00	C2 - Brest	Absorbanca-barva	0,0001		ni mej
2026/738	29.01.2026 10:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/738	29.01.2026 10:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/738	29.01.2026 10:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,59	mg/L	brez neobičajne spremembe
2026/738	29.01.2026 10:20:00	C2 - Brest	Električna prevodnost (20°C)	439	uS/cm	<2500
2026/738	29.01.2026 10:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/738	29.01.2026 10:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/738	29.01.2026 10:20:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/738	29.01.2026 10:20:00	C2 - Brest	Prosti klor	0,04	mg/L	ni mej
2026/738	29.01.2026 10:20:00	C2 - Brest	Temperatura vode	8,7	°C	ni mej
2026/738	29.01.2026 10:20:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/738	29.01.2026 10:20:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/744	29.01.2026 10:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/744	29.01.2026 10:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/744	29.01.2026 10:20:00	C2 - Brest	Prosti klor	0,04	mg/L	ni mej
2026/744	29.01.2026 10:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/744	29.01.2026 10:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/744	29.01.2026 10:20:00	C2 - Brest	Temperatura vode	8,7	°C	ni mej
2026/776	30.01.2026 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0

2026/776	30.01.2026 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/776	30.01.2026 10:00:00	C2 - Brest	Prosti klor	0,05	mg/L	ni mej
2026/776	30.01.2026 10:00:00	C2 - Brest	Število kolonij pri 22°C	14	cfu/mL	brez neobičajne spremembe
2026/776	30.01.2026 10:00:00	C2 - Brest	Število kolonij pri 36°C	148	cfu/mL	<100
2026/776	30.01.2026 10:00:00	C2 - Brest	Temperatura vode	9,4	°C	ni mej
2026/937	05.02.2026 07:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/937	05.02.2026 07:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/937	05.02.2026 07:20:00	C2 - Brest	Prosti klor	0,02	mg/L	ni mej
2026/937	05.02.2026 07:20:00	C2 - Brest	Število kolonij pri 22°C	36	cfu/mL	brez neobičajne spremembe
2026/937	05.02.2026 07:20:00	C2 - Brest	Število kolonij pri 36°C	48	cfu/mL	<100
2026/937	05.02.2026 07:20:00	C2 - Brest	Temperatura vode	9,6	°C	ni mej
2026/978	06.02.2026 08:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/978	06.02.2026 08:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/978	06.02.2026 08:20:00	C2 - Brest	Prosti klor	0,04	mg/L	ni mej
2026/978	06.02.2026 08:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/978	06.02.2026 08:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/978	06.02.2026 08:20:00	C2 - Brest	Temperatura vode	9,4	°C	ni mej
2026/1030	09.02.2026 09:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1030	09.02.2026 09:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1030	09.02.2026 09:35:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/1030	09.02.2026 09:35:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1030	09.02.2026 09:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1030	09.02.2026 09:35:00	C2 - Brest	Temperatura vode	8,7	°C	ni mej
2026/1031	09.02.2026 09:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1031	09.02.2026 09:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1031	09.02.2026 09:50:00	C2 - Brest	Prosti klor	14,4	mg/L	ni mej
2026/1031	09.02.2026 09:50:00	C2 - Brest	Število kolonij pri 22°C	45	cfu/mL	brez neobičajne spremembe
2026/1031	09.02.2026 09:50:00	C2 - Brest	Število kolonij pri 36°C	14	cfu/mL	<100
2026/1031	09.02.2026 09:50:00	C2 - Brest	Temperatura vode	0	°C	ni mej
2026/1109	11.02.2026 08:50:00	C2 - Brest	Absorbanca-barva	0,00175		ni mej
2026/1109	11.02.2026 08:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/1109	11.02.2026 08:50:00	C2 - Brest	Barva (436 nm)	0,04	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/1109	11.02.2026 08:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,37	mg/L	brez neobičajne spremembe
2026/1109	11.02.2026 08:50:00	C2 - Brest	Električna prevodnost (20°C)	420	uS/cm	<2500
2026/1109	11.02.2026 08:50:00	C2 - Brest	Klor dioksid	0,17	mg/L	ni mej
2026/1109	11.02.2026 08:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/1109	11.02.2026 08:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/1109	11.02.2026 08:50:00	C2 - Brest	pH-vrednost	7,5	-	6.5-9.5
2026/1109	11.02.2026 08:50:00	C2 - Brest	Temperatura vode	11,5	°C	ni mej
2026/1109	11.02.2026 08:50:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/1109	11.02.2026 08:50:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/1111	11.02.2026 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1111	11.02.2026 08:50:00	C2 - Brest	Klor dioksid	0,17	mg/L	ni mej
2026/1111	11.02.2026 08:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1111	11.02.2026 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1111	11.02.2026 08:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1111	11.02.2026 08:50:00	C2 - Brest	Temperatura vode	11,5	°C	ni mej
2026/1110	11.02.2026 09:20:00	C2 - Brest	Absorbanca-barva	0,0003		ni mej
2026/1110	11.02.2026 09:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/1110	11.02.2026 09:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/1110	11.02.2026 09:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,39	mg/L	brez neobičajne spremembe
2026/1110	11.02.2026 09:20:00	C2 - Brest	Električna prevodnost (20°C)	422	uS/cm	<2500
2026/1110	11.02.2026 09:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/1110	11.02.2026 09:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/1110	11.02.2026 09:20:00	C2 - Brest	pH-vrednost	7,5	-	6.5-9.5
2026/1110	11.02.2026 09:20:00	C2 - Brest	Prosti klor	0,11	mg/L	ni mej
2026/1110	11.02.2026 09:20:00	C2 - Brest	Temperatura vode	11,5	°C	ni mej
2026/1110	11.02.2026 09:20:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/1110	11.02.2026 09:20:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/1112	11.02.2026 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1112	11.02.2026 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1112	11.02.2026 09:20:00	C2 - Brest	Prosti klor	0,11	mg/L	ni mej
2026/1112	11.02.2026 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1112	11.02.2026 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1112	11.02.2026 09:20:00	C2 - Brest	Temperatura vode	11,5	°C	ni mej
2026/1397	19.02.2026 08:30:00	C2 - Brest	Absorbanca-barva	0,0002		ni mej
2026/1397	19.02.2026 08:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/1397	19.02.2026 08:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/1397	19.02.2026 08:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,39	mg/L	brez neobičajne spremembe
2026/1397	19.02.2026 08:30:00	C2 - Brest	Električna prevodnost (20°C)	428	uS/cm	<2500

2026/1397	19.02.2026 08:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/1397	19.02.2026 08:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/1397	19.02.2026 08:30:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/1397	19.02.2026 08:30:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/1397	19.02.2026 08:30:00	C2 - Brest	Temperatura vode	8,3	°C	ni mej
2026/1397	19.02.2026 08:30:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/1397	19.02.2026 08:30:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/1407	19.02.2026 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1407	19.02.2026 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1407	19.02.2026 08:30:00	C2 - Brest	Prosti klor	0,01	mg/L	ni mej
2026/1407	19.02.2026 08:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1407	19.02.2026 08:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1407	19.02.2026 08:30:00	C2 - Brest	Temperatura vode	8,3	°C	ni mej
2026/1398	19.02.2026 09:00:00	C2 - Brest	Absorbanca-barva	0,0002		ni mej
2026/1398	19.02.2026 09:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/1398	19.02.2026 09:00:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/1398	19.02.2026 09:00:00	C2 - Brest	Celotni organski ogljik (TOC)	0,39	mg/L	brez neobičajne spremembe
2026/1398	19.02.2026 09:00:00	C2 - Brest	Električna prevodnost (20°C)	426	uS/cm	<2500
2026/1398	19.02.2026 09:00:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/1398	19.02.2026 09:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/1398	19.02.2026 09:00:00	C2 - Brest	pH-vrednost	7,5	-	6.5-9.5
2026/1398	19.02.2026 09:00:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/1398	19.02.2026 09:00:00	C2 - Brest	Temperatura vode	9,6	°C	ni mej
2026/1398	19.02.2026 09:00:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/1398	19.02.2026 09:00:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/1411	19.02.2026 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1411	19.02.2026 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1411	19.02.2026 09:00:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/1411	19.02.2026 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1411	19.02.2026 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1411	19.02.2026 09:00:00	C2 - Brest	Temperatura vode	9,6	°C	ni mej
2026/1404	19.02.2026 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1404	19.02.2026 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1404	19.02.2026 09:30:00	C2 - Brest	Prosti klor	0,01	mg/L	ni mej
2026/1404	19.02.2026 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1404	19.02.2026 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1404	19.02.2026 09:30:00	C2 - Brest	Temperatura vode	8,7	°C	ni mej
2026/1405	19.02.2026 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1405	19.02.2026 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1405	19.02.2026 10:00:00	C2 - Brest	Prosti klor	0,02	mg/L	ni mej
2026/1405	19.02.2026 10:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1405	19.02.2026 10:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1405	19.02.2026 10:00:00	C2 - Brest	Temperatura vode	8,8	°C	ni mej
2026/1455	23.02.2026 08:20:00	C2 - Brest	Absorbanca-barva	0,0002		ni mej
2026/1455	23.02.2026 08:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/1455	23.02.2026 08:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/1455	23.02.2026 08:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,47	mg/L	brez neobičajne spremembe
2026/1455	23.02.2026 08:20:00	C2 - Brest	Električna prevodnost (20°C)	440	uS/cm	<2500
2026/1455	23.02.2026 08:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/1455	23.02.2026 08:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/1455	23.02.2026 08:20:00	C2 - Brest	pH-vrednost	7,3	-	6.5-9.5
2026/1455	23.02.2026 08:20:00	C2 - Brest	Prosti klor	0,02	mg/L	ni mej
2026/1455	23.02.2026 08:20:00	C2 - Brest	Temperatura vode	13,5	°C	ni mej
2026/1455	23.02.2026 08:20:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/1455	23.02.2026 08:20:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/1465	23.02.2026 08:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1465	23.02.2026 08:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1465	23.02.2026 08:20:00	C2 - Brest	Prosti klor	0,02	mg/L	ni mej
2026/1465	23.02.2026 08:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1465	23.02.2026 08:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1465	23.02.2026 08:20:00	C2 - Brest	Temperatura vode	13,5	°C	ni mej
2026/1515	24.02.2026 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1515	24.02.2026 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1515	24.02.2026 08:40:00	C2 - Brest	Prosti klor	0,08	mg/L	ni mej
2026/1515	24.02.2026 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1515	24.02.2026 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1515	24.02.2026 08:40:00	C2 - Brest	Temperatura vode	11,8	°C	ni mej
2026/1513	24.02.2026 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1513	24.02.2026 09:00:00	C2 - Brest	Klor dioksid	0,17	mg/L	ni mej
2026/1513	24.02.2026 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0

2026/1513	24.02.2026 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1513	24.02.2026 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1513	24.02.2026 09:00:00	C2 - Brest	Temperatura vode	12,4	°C	ni mej
2026/1517	24.02.2026 10:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1517	24.02.2026 10:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1517	24.02.2026 10:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/1517	24.02.2026 10:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1517	24.02.2026 10:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1517	24.02.2026 10:10:00	C2 - Brest	Temperatura vode	8,2	°C	ni mej
2026/1545	25.02.2026 11:10:00	C2 - Brest	Nitrat	12	mg/L	<50
2026/1545	25.02.2026 11:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/1545	25.02.2026 11:10:00	C2 - Brest	Temperatura vode	10,4	°C	ni mej
2026/1545	25.02.2026 11:10:00	C2 - Brest	Tetrakloroeten	<0.5	ug/L	<10
2026/1545	25.02.2026 11:10:00	C2 - Brest	Trikloroeten	<0.5	ug/L	<10
2026/1581	25.02.2026 11:10:00	C2 - Brest	Absorbanca-barva	0,0003		ni mej
2026/1581	25.02.2026 11:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/1581	25.02.2026 11:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/1581	25.02.2026 11:10:00	C2 - Brest	Celotni organski ogljik (TOC)	0,35	mg/L	brez neobičajne spremembe
2026/1581	25.02.2026 11:10:00	C2 - Brest	Električna prevodnost (20°C)	444	uS/cm	<2500
2026/1581	25.02.2026 11:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/1581	25.02.2026 11:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/1581	25.02.2026 11:10:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/1581	25.02.2026 11:10:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/1581	25.02.2026 11:10:00	C2 - Brest	Temperatura vode	10,4	°C	ni mej
2026/1581	25.02.2026 11:10:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/1581	25.02.2026 11:10:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/1588	25.02.2026 11:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1588	25.02.2026 11:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1588	25.02.2026 11:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/1588	25.02.2026 11:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1588	25.02.2026 11:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1588	25.02.2026 11:10:00	C2 - Brest	Temperatura vode	10,4	°C	ni mej
2026/1610	26.02.2026 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1610	26.02.2026 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1610	26.02.2026 09:40:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/1610	26.02.2026 09:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1610	26.02.2026 09:40:00	C2 - Brest	Število kolonij pri 36°C	16	cfu/mL	<100
2026/1610	26.02.2026 09:40:00	C2 - Brest	Temperatura vode	10,7	°C	ni mej
2026/1814	05.03.2026 07:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1814	05.03.2026 07:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1814	05.03.2026 07:50:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/1814	05.03.2026 07:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1814	05.03.2026 07:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1814	05.03.2026 07:50:00	C2 - Brest	Temperatura vode	10,7	°C	ni mej
2026/1813	05.03.2026 08:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1813	05.03.2026 08:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1813	05.03.2026 08:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/1813	05.03.2026 08:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1813	05.03.2026 08:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1813	05.03.2026 08:10:00	C2 - Brest	Temperatura vode	16,7	°C	ni mej
2026/1882	09.03.2026 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1882	09.03.2026 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1882	09.03.2026 09:00:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/1882	09.03.2026 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1882	09.03.2026 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1882	09.03.2026 09:00:00	C2 - Brest	Temperatura vode	10,5	°C	ni mej
2026/1883	09.03.2026 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1883	09.03.2026 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1883	09.03.2026 09:30:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/1883	09.03.2026 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/1883	09.03.2026 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1883	09.03.2026 09:30:00	C2 - Brest	Temperatura vode	15,4	°C	ni mej
2026/1961	11.03.2026 11:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/1961	11.03.2026 11:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/1961	11.03.2026 11:50:00	C2 - Brest	Prosti klor	0,02	mg/L	ni mej
2026/1961	11.03.2026 11:50:00	C2 - Brest	Število kolonij pri 22°C	34	cfu/mL	brez neobičajne spremembe
2026/1961	11.03.2026 11:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/1961	11.03.2026 11:50:00	C2 - Brest	Temperatura vode	8,9	°C	ni mej
2026/2028	12.03.2026 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2028	12.03.2026 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2028	12.03.2026 09:30:00	C2 - Brest	Prosti klor	0,1	mg/L	ni mej
2026/2028	12.03.2026 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe

2026/2028	12.03.2026 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2028	12.03.2026 09:30:00	C2 - Brest	Temperatura vode	11,1	°C	ni mej
2026/2025	12.03.2026 11:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2025	12.03.2026 11:00:00	C2 - Brest	Klor dioksid	0,18	mg/L	ni mej
2026/2025	12.03.2026 11:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2025	12.03.2026 11:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2025	12.03.2026 11:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2025	12.03.2026 11:00:00	C2 - Brest	Temperatura vode	12,1	°C	ni mej
2026/2030	12.03.2026 11:00:00	C2 - Brest	Absorbanca-barva	0,0014		ni mej
2026/2030	12.03.2026 11:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/2030	12.03.2026 11:00:00	C2 - Brest	Barva (436 nm)	0,03	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2030	12.03.2026 11:00:00	C2 - Brest	Celotni organski ogljik (TOC)	0,62	mg/L	brez neobičajne spremembe
2026/2030	12.03.2026 11:00:00	C2 - Brest	Električna prevodnost (20°C)	619	uS/cm	<2500
2026/2030	12.03.2026 11:00:00	C2 - Brest	Klor dioksid	0,18	mg/L	ni mej
2026/2030	12.03.2026 11:00:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/2030	12.03.2026 11:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/2030	12.03.2026 11:00:00	C2 - Brest	pH-vrednost	7,1	-	6.5-9.5
2026/2030	12.03.2026 11:00:00	C2 - Brest	Temperatura vode	12,1	°C	ni mej
2026/2030	12.03.2026 11:00:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/2030	12.03.2026 11:00:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2026	12.03.2026 11:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2026	12.03.2026 11:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2026	12.03.2026 11:30:00	C2 - Brest	Prosti klor	0,12	mg/L	ni mej
2026/2026	12.03.2026 11:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2026	12.03.2026 11:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2026	12.03.2026 11:30:00	C2 - Brest	Temperatura vode	11,5	°C	ni mej
2026/2031	12.03.2026 11:30:00	C2 - Brest	Absorbanca-barva	0,0006		ni mej
2026/2031	12.03.2026 11:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/2031	12.03.2026 11:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2031	12.03.2026 11:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,5	mg/L	brez neobičajne spremembe
2026/2031	12.03.2026 11:30:00	C2 - Brest	Električna prevodnost (20°C)	453	uS/cm	<2500
2026/2031	12.03.2026 11:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/2031	12.03.2026 11:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/2031	12.03.2026 11:30:00	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/2031	12.03.2026 11:30:00	C2 - Brest	Prosti klor	0,12	mg/L	ni mej
2026/2031	12.03.2026 11:30:00	C2 - Brest	Temperatura vode	11,5	°C	ni mej
2026/2031	12.03.2026 11:30:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/2031	12.03.2026 11:30:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2091	16.03.2026 07:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2091	16.03.2026 07:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2091	16.03.2026 07:30:00	C2 - Brest	Število kolonij pri 22°C	30	cfu/mL	brez neobičajne spremembe
2026/2091	16.03.2026 07:30:00	C2 - Brest	Število kolonij pri 36°C	72	cfu/mL	<100
2026/2091	16.03.2026 07:30:00	C2 - Brest	Temperatura vode	12,8	°C	ni mej
2026/2255	23.03.2026 09:10:00	C2 - Brest	Absorbanca-barva	0,0001		ni mej
2026/2255	23.03.2026 09:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/2255	23.03.2026 09:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2255	23.03.2026 09:10:00	C2 - Brest	Celotni organski ogljik (TOC)	0,42	mg/L	brez neobičajne spremembe
2026/2255	23.03.2026 09:10:00	C2 - Brest	Električna prevodnost (20°C)	447	uS/cm	<2500
2026/2255	23.03.2026 09:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/2255	23.03.2026 09:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/2255	23.03.2026 09:10:00	C2 - Brest	pH-vrednost	7,5	-	6.5-9.5
2026/2255	23.03.2026 09:10:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/2255	23.03.2026 09:10:00	C2 - Brest	Temperatura vode	13,9	°C	ni mej
2026/2255	23.03.2026 09:10:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/2255	23.03.2026 09:10:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2266	23.03.2026 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2266	23.03.2026 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2266	23.03.2026 09:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/2266	23.03.2026 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2266	23.03.2026 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2266	23.03.2026 09:10:00	C2 - Brest	Temperatura vode	13,9	°C	ni mej
2026/2295	24.03.2026 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2295	24.03.2026 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2295	24.03.2026 09:10:00	C2 - Brest	Prosti klor	0,11	mg/L	ni mej
2026/2295	24.03.2026 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2295	24.03.2026 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2295	24.03.2026 09:10:00	C2 - Brest	Temperatura vode	11,4	°C	ni mej
2026/2294	24.03.2026 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2294	24.03.2026 09:30:00	C2 - Brest	Klor dioksid	0,19	mg/L	ni mej

2026/2294	24.03.2026 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2294	24.03.2026 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2294	24.03.2026 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2294	24.03.2026 09:30:00	C2 - Brest	Temperatura vode	12,2	°C	ni mej
2026/2296	24.03.2026 10:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2296	24.03.2026 10:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2296	24.03.2026 10:40:00	C2 - Brest	Prosti klor	0,01	mg/L	ni mej
2026/2296	24.03.2026 10:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2296	24.03.2026 10:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2296	24.03.2026 10:40:00	C2 - Brest	Temperatura vode	9,9	°C	ni mej
2026/2316	24.03.2026 10:40:00	C2 - Brest	Absorbanca-barva	0,0001		ni mej
2026/2316	24.03.2026 10:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/2316	24.03.2026 10:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2316	24.03.2026 10:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,58	mg/L	brez neobičajne spremembe
2026/2316	24.03.2026 10:40:00	C2 - Brest	Električna prevodnost (20°C)	444	uS/cm	<2500
2026/2316	24.03.2026 10:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/2316	24.03.2026 10:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/2316	24.03.2026 10:40:00	C2 - Brest	pH-vrednost	7,5	-	6.5-9.5
2026/2316	24.03.2026 10:40:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/2316	24.03.2026 10:40:00	C2 - Brest	Temperatura vode	9,9	°C	ni mej
2026/2316	24.03.2026 10:40:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/2316	24.03.2026 10:40:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2297	24.03.2026 11:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2297	24.03.2026 11:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2297	24.03.2026 11:10:00	C2 - Brest	Prosti klor	0,04	mg/L	ni mej
2026/2297	24.03.2026 11:10:00	C2 - Brest	Število kolonij pri 22°C	11	cfu/mL	brez neobičajne spremembe
2026/2297	24.03.2026 11:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2297	24.03.2026 11:10:00	C2 - Brest	Temperatura vode	10,2	°C	ni mej
2026/2317	24.03.2026 11:10:00	C2 - Brest	Absorbanca-barva	0,0001		ni mej
2026/2317	24.03.2026 11:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/2317	24.03.2026 11:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2317	24.03.2026 11:10:00	C2 - Brest	Celotni organski ogljik (TOC)	0,46	mg/L	brez neobičajne spremembe
2026/2317	24.03.2026 11:10:00	C2 - Brest	Električna prevodnost (20°C)	435	uS/cm	<2500
2026/2317	24.03.2026 11:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/2317	24.03.2026 11:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/2317	24.03.2026 11:10:00	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/2317	24.03.2026 11:10:00	C2 - Brest	Prosti klor	0,04	mg/L	ni mej
2026/2317	24.03.2026 11:10:00	C2 - Brest	Temperatura vode	10,2	°C	ni mej
2026/2317	24.03.2026 11:10:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/2317	24.03.2026 11:10:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2299	24.03.2026 11:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2299	24.03.2026 11:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2299	24.03.2026 11:30:00	C2 - Brest	Prosti klor	0,05	mg/L	ni mej
2026/2299	24.03.2026 11:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2299	24.03.2026 11:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2299	24.03.2026 11:30:00	C2 - Brest	Temperatura vode	10,1	°C	ni mej
2026/2319	24.03.2026 11:30:00	C2 - Brest	Absorbanca-barva	0,0008		ni mej
2026/2319	24.03.2026 11:30:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/2319	24.03.2026 11:30:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2319	24.03.2026 11:30:00	C2 - Brest	Celotni organski ogljik (TOC)	0,58	mg/L	brez neobičajne spremembe
2026/2319	24.03.2026 11:30:00	C2 - Brest	Električna prevodnost (20°C)	447	uS/cm	<2500
2026/2319	24.03.2026 11:30:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/2319	24.03.2026 11:30:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/2319	24.03.2026 11:30:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/2319	24.03.2026 11:30:00	C2 - Brest	Prosti klor	0,05	mg/L	ni mej
2026/2319	24.03.2026 11:30:00	C2 - Brest	Temperatura vode	10,1	°C	ni mej
2026/2319	24.03.2026 11:30:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/2319	24.03.2026 11:30:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2298	24.03.2026 11:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2298	24.03.2026 11:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2298	24.03.2026 11:50:00	C2 - Brest	Prosti klor	0,05	mg/L	ni mej
2026/2298	24.03.2026 11:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2298	24.03.2026 11:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2298	24.03.2026 11:50:00	C2 - Brest	Temperatura vode	12,3	°C	ni mej
2026/2318	24.03.2026 11:50:00	C2 - Brest	Absorbanca-barva	0,0006		ni mej
2026/2318	24.03.2026 11:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/2318	24.03.2026 11:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2318	24.03.2026 11:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,55	mg/L	brez neobičajne spremembe
2026/2318	24.03.2026 11:50:00	C2 - Brest	Električna prevodnost (20°C)	430	uS/cm	<2500

2026/2318	24.03.2026 11:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/2318	24.03.2026 11:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/2318	24.03.2026 11:50:00	C2 - Brest	pH-vrednost	7,5	-	6.5-9.5
2026/2318	24.03.2026 11:50:00	C2 - Brest	Prosti klor	0,05	mg/L	ni mej
2026/2318	24.03.2026 11:50:00	C2 - Brest	Temperatura vode	12,3	°C	ni mej
2026/2318	24.03.2026 11:50:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/2318	24.03.2026 11:50:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2327	25.03.2026 10:40:00	C2 - Brest	Nitrat	8,72	mg/L	<50
2026/2327	25.03.2026 10:40:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/2327	25.03.2026 10:40:00	C2 - Brest	Temperatura vode	11,2	°C	ni mej
2026/2327	25.03.2026 10:40:00	C2 - Brest	Tetrakloroeten	<0.5	ug/L	<10
2026/2327	25.03.2026 10:40:00	C2 - Brest	Trikloroeten	<0.5	ug/L	<10
2026/2346	25.03.2026 10:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2346	25.03.2026 10:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2346	25.03.2026 10:40:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/2346	25.03.2026 10:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2346	25.03.2026 10:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2346	25.03.2026 10:40:00	C2 - Brest	Temperatura vode	11,2	°C	ni mej
2026/2453	30.03.2026 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2453	30.03.2026 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2453	30.03.2026 09:30:00	C2 - Brest	Prosti klor	0,02	mg/L	ni mej
2026/2453	30.03.2026 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2453	30.03.2026 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2453	30.03.2026 09:30:00	C2 - Brest	Temperatura vode	11,2	°C	ni mej
2026/2707	08.04.2026 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2707	08.04.2026 08:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2707	08.04.2026 08:50:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/2707	08.04.2026 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2707	08.04.2026 08:50:00	C2 - Brest	Število kolonij pri 36°C	12	cfu/mL	<100
2026/2707	08.04.2026 08:50:00	C2 - Brest	Temperatura vode	16,5	°C	ni mej
2026/2754	09.04.2026 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2754	09.04.2026 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2754	09.04.2026 08:40:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/2754	09.04.2026 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2754	09.04.2026 08:40:00	C2 - Brest	Število kolonij pri 36°C	11	cfu/mL	<100
2026/2754	09.04.2026 08:40:00	C2 - Brest	Temperatura vode	14,4	°C	ni mej
2026/2773	09.04.2026 08:40:00	C2 - Brest	Absorbanca-barva	0,0001		ni mej
2026/2773	09.04.2026 08:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/2773	09.04.2026 08:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2773	09.04.2026 08:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,41	mg/L	brez neobičajne spremembe
2026/2773	09.04.2026 08:40:00	C2 - Brest	Električna prevodnost (20°C)	418	uS/cm	<2500
2026/2773	09.04.2026 08:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/2773	09.04.2026 08:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/2773	09.04.2026 08:40:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/2773	09.04.2026 08:40:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/2773	09.04.2026 08:40:00	C2 - Brest	Temperatura vode	14,4	°C	ni mej
2026/2773	09.04.2026 08:40:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/2773	09.04.2026 08:40:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2760	09.04.2026 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2760	09.04.2026 09:20:00	C2 - Brest	Klor dioksid	0,14	mg/L	ni mej
2026/2760	09.04.2026 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2760	09.04.2026 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2760	09.04.2026 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2760	09.04.2026 09:20:00	C2 - Brest	Temperatura vode	11,3	°C	ni mej
2026/2783	09.04.2026 09:20:00	C2 - Brest	Absorbanca-barva	0,0015		ni mej
2026/2783	09.04.2026 09:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/2783	09.04.2026 09:20:00	C2 - Brest	Barva (436 nm)	0,03	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2783	09.04.2026 09:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,45	mg/L	brez neobičajne spremembe
2026/2783	09.04.2026 09:20:00	C2 - Brest	Električna prevodnost (20°C)	413	uS/cm	<2500
2026/2783	09.04.2026 09:20:00	C2 - Brest	Klor dioksid	0,14	mg/L	ni mej
2026/2783	09.04.2026 09:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/2783	09.04.2026 09:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/2783	09.04.2026 09:20:00	C2 - Brest	pH-vrednost	7,5	-	6.5-9.5
2026/2783	09.04.2026 09:20:00	C2 - Brest	Temperatura vode	11,3	°C	ni mej
2026/2783	09.04.2026 09:20:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/2783	09.04.2026 09:20:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2761	09.04.2026 09:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2761	09.04.2026 09:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2761	09.04.2026 09:50:00	C2 - Brest	Prosti klor	0,12	mg/L	ni mej
2026/2761	09.04.2026 09:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe

2026/2761	09.04.2026 09:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2761	09.04.2026 09:50:00	C2 - Brest	Temperatura vode	11,1	°C	ni mej
2026/2784	09.04.2026 09:50:00	C2 - Brest	Absorbanca-barva	0,0004		ni mej
2026/2784	09.04.2026 09:50:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/2784	09.04.2026 09:50:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2784	09.04.2026 09:50:00	C2 - Brest	Celotni organski ogljik (TOC)	0,44	mg/L	brez neobičajne spremembe
2026/2784	09.04.2026 09:50:00	C2 - Brest	Električna prevodnost (20°C)	409	uS/cm	<2500
2026/2784	09.04.2026 09:50:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/2784	09.04.2026 09:50:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/2784	09.04.2026 09:50:00	C2 - Brest	pH-vrednost	7,5	-	6.5-9.5
2026/2784	09.04.2026 09:50:00	C2 - Brest	Prosti klor	0,12	mg/L	ni mej
2026/2784	09.04.2026 09:50:00	C2 - Brest	Temperatura vode	11,1	°C	ni mej
2026/2784	09.04.2026 09:50:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/2784	09.04.2026 09:50:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2762	09.04.2026 10:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2762	09.04.2026 10:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2762	09.04.2026 10:20:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/2762	09.04.2026 10:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2762	09.04.2026 10:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2762	09.04.2026 10:20:00	C2 - Brest	Temperatura vode	12,2	°C	ni mej
2026/2785	09.04.2026 10:20:00	C2 - Brest	Absorbanca-barva	0,0002		ni mej
2026/2785	09.04.2026 10:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/2785	09.04.2026 10:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2785	09.04.2026 10:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,44	mg/L	brez neobičajne spremembe
2026/2785	09.04.2026 10:20:00	C2 - Brest	Električna prevodnost (20°C)	440	uS/cm	<2500
2026/2785	09.04.2026 10:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/2785	09.04.2026 10:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/2785	09.04.2026 10:20:00	C2 - Brest	pH-vrednost	7,5	-	6.5-9.5
2026/2785	09.04.2026 10:20:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/2785	09.04.2026 10:20:00	C2 - Brest	Temperatura vode	12,2	°C	ni mej
2026/2785	09.04.2026 10:20:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/2785	09.04.2026 10:20:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2736	09.04.2026 12:36:56	C2 - Brest	1,1,1-trikloroetan	<0.4	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	1,1,2,2-tetrakloroetan	<0.5	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	1,1,2-trikloroetan	<0.7	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	1,1-dikloroetan	<0.4	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	1,1-dikloroeten	<0.4	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	1,2-dikloroetan	<0.4	ug/L	<3
2026/2736	09.04.2026 12:36:56	C2 - Brest	17 alfa-Etinilestradiol	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	17 beta-Estradiol	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	1H-benzotriazol	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	1-metil-1H-benzotriazol	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	2,4 - DB	<0.016	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	2,4,5-T	<0.010	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	2,4,6-Triklorofenol	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	2,4-D	<0.015	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	2,4-Diklorofenol	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	2,4-Dimetilfenol	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	2,4-Dinitrofenol	<0.2	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	2,4-DP	<0.020	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	2,6-diklorobenzamid	<0.006	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	2-Klorofenol	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	2-Metil-4,6-dinitrofenol	<0.06	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	2-Metilfenol	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	2-Metoksifenol	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	2-Nitrofenol	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	3,5-Dimetilfenol	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	3-Metilfenol + 4-Metilfenol	<0.06	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	4-(1,1,3,3-tetrametilbutil)fenol	<0.25	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	4-(1,1,3,3-Tetrametilbutil)fenol dietoksilat	<0.25	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	4-(1,1,3,3-Tetrametilbutil)fenol monoetoksilat	<0.25	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	4-Kloro-3-metilfenol	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	4-metil-1H-benzotriazol	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	4-Nitrofenol	<0.06	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	4-Nonilfenol	<1.5	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	4-Nonilfenol dietoksilat (mešanica razvejanih izomerov)	<1.5	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	4-Nonilfenol monoetoksilat (mešanica razvejanih izomerov)	<1.5	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	5-metil-1H-benzotriazol	<0.004	ug/L	ni mej

2026/2736	09.04.2026 12:36:56	C2 - Brest	Acetoklor	<0.007	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Adsorbijivi organski halogeni (AOX)	8,3	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Alaklor	<0.007	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Aluminij	3,6	ug/L	<200
2026/2736	09.04.2026 12:36:56	C2 - Brest	Amidosulfuron	<0.013	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Aminometil fosfonska kislina	<0.09	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Amonij	<0.01	mg/L	<0.50
2026/2736	09.04.2026 12:36:56	C2 - Brest	Antimon	<0.05	ug/L	<10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Arzen	0,2	ug/L	<10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Atenolol	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Atrazin	<0.007	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Atrazin, Desetil-	0,054	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Atrazin, Desizopropil-	<0.003	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Azitromicin	<0.020	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Baker	0,0011	mg/L	<2.0
2026/2736	09.04.2026 12:36:56	C2 - Brest	Barva (436 nm)	<0.2	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2736	09.04.2026 12:36:56	C2 - Brest	Bentazon	<0.012	ug/L	
2026/2736	09.04.2026 12:36:56	C2 - Brest	Benzen	<0.3	ug/L	<1
2026/2736	09.04.2026 12:36:56	C2 - Brest	Benzil butil ftalat	<0.24	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Benzo(a)piren	<0.004	ug/L	<0.010
2026/2736	09.04.2026 12:36:56	C2 - Brest	Benzo(b)fluoranten	<0.005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Benzo(ghi)perilen	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Benzo(k)fluoranten	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Betaksolol	<0.004	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Bezafibrat	<0.006	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Bisfenol A	<0.25	ug/L	<2.5
2026/2736	09.04.2026 12:36:56	C2 - Brest	Bor	0,004	mg/L	<1.5
2026/2736	09.04.2026 12:36:56	C2 - Brest	Boskalid	<0.006	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Bromacil	<0.008	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Bromat	<3	ug/L	<10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Bromodiklorometan	0,6	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Celotni organski ogljik - TOC	0,33	mg/L	brez neobičajne spremembe
2026/2736	09.04.2026 12:36:56	C2 - Brest	Cianazin	<0.009	ug/L	
2026/2736	09.04.2026 12:36:56	C2 - Brest	Cianid - prosti	<0.3	ug/L	<50
2026/2736	09.04.2026 12:36:56	C2 - Brest	Cimoksanil	<0.01	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Clostridium perfringens s sporami	0	cfu/100mL	0
2026/2736	09.04.2026 12:36:56	C2 - Brest	Di-(2-etilheksil)-ftalat	<0.24	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Dibromoklorometan	0,7	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Dibromoocetna kislina	<5.0	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Dibutil ftalat	<0.24	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Dietil ftalat	<0.24	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Dietilstilbestrol	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Diflufenikan	<0.006	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Dikamba	<0.05	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Diklobenil	<0.03	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Diklofenak	<0.012	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Diklorometan	<0.6	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Dikloroocetna kislina	<5.0	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Dimetenamid	<0.001	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Dimetil ftalat	<0.24	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Dimetoat	<0.001	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Di-n-oktil ftalat	<0.24	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Dinonil ftalat	<0.24	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Dioktil ftalat	<0.24	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Diuron	<0.007	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Električna prevodnost (20°C)	439	uS/cm	<2500
2026/2736	09.04.2026 12:36:56	C2 - Brest	Epoksikonazol	<0.002	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Eritromicin	<0.020	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2736	09.04.2026 12:36:56	C2 - Brest	Estriol	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Estron	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Etilbenzen	<0.3	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Fenofibrat	<0.010	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Fenol	<5	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Fenolne snovi-skupne	<5	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Fenoterol	<0.003	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Fenuron	<0.008	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Flufenacet	<0.003	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Fluorid	<0.05	mg/L	<1.5
2026/2736	09.04.2026 12:36:56	C2 - Brest	Foramsulfuron	<0.014	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Fosfat-orto	0,023	mg/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Gemfibrozil	<0.005	ug/L	ni mej

2026/2736	09.04.2026 12:36:56	C2 - Brest	Glifosat	<0.09	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Glufosinat-amonijeva sol	<0.20	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Heksakloroetan	<0.4	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Hidrogenkarbonati	320	mg/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Ibuprofen	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Imidaklopidrid	<0.003	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Indeno(1,2,3-c,d)piren	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Indometacin	<0.005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Intestinalni enterokoki	0	cfu/100mL	0
2026/2736	09.04.2026 12:36:56	C2 - Brest	Izoksaflutol	<0.003	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Izoproturon	<0.008	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Jodosulfuron	<0.005	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Kadmij	<0.02	ug/L	<5.0
2026/2736	09.04.2026 12:36:56	C2 - Brest	Kalcij	57	mg/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Kalij	0,98	mg/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Karbamazepin	<0.006	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Karbendazim	<0.01	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Ketoprofen	<0.005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Klaritromicin	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Klofibrična kislina	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Kloramfenikol	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Klorat	<0.05	mg/L	<0.25
2026/2736	09.04.2026 12:36:56	C2 - Brest	Klorfenvinfos	<0.002	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Klorid	2,5	mg/L	<250
2026/2736	09.04.2026 12:36:56	C2 - Brest	Kloridazon	<0.004	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Klorit	<0.05	mg/L	<0.25
2026/2736	09.04.2026 12:36:56	C2 - Brest	Klorotalonil	<0.03	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Klorotetraciklin	<0.020	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Klorotoluron	<0.009	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Klorpirifos-etil	<0.002	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Klorpirifos-metil	<0.003	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Kodein	<0.017	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Kofein	<0.017	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2736	09.04.2026 12:36:56	C2 - Brest	Krom	<0.4	ug/L	<50
2026/2736	09.04.2026 12:36:56	C2 - Brest	Krom (VI)	<10	ug/L	<50
2026/2736	09.04.2026 12:36:56	C2 - Brest	kvinoksifen	<0.002	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Linuron	<0.009	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	m,p- Ksilen	<0.3	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Magnezij	30	mg/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Malation	<0.006	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	m-Alkaliteta	5,2	mmol/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Mandipropamid	<0.01	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Mangan	1,4	ug/L	<50
2026/2736	09.04.2026 12:36:56	C2 - Brest	MCPA	<0.013	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	MCPB	<0.022	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	MCPP	<0.013	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Metaflumizon	<0.01	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Metalaksil	<0.001	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Metamitron	<0.005	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Metazaklor	<0.008	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Metoksuron	<0.009	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Metolaklor	<0.011	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Metolaklor-ESA	<0.017	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Metolaklor-OXA	<0.015	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Metoprolol	<0.005	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Metosulam	<0.005	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Metribuzin	<0.010	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Mezosulfuron	<0.005	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Mezotrion	<0.006	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Molibden	0,14	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Monobromoocetna kislina	<5.0	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Monokloroocetna kislina	<5.0	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Monolinuron	<0.009	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Monuron	<0.010	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Motnost	<0.1	NTU	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	N,N-dietil-m-toluamid	<0.01	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Naproksen	<0.009	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Natrij	1,3	mg/L	<200
2026/2736	09.04.2026 12:36:56	C2 - Brest	Nikelj	0,21	ug/L	<20
2026/2736	09.04.2026 12:36:56	C2 - Brest	Nikosulfuron	<0.013	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Nitrat	9,1	mg/L	<50
2026/2736	09.04.2026 12:36:56	C2 - Brest	Nitrat/50+nitrit/3	0,184	mg/L	<1

2026/2736	09.04.2026 12:36:56	C2 - Brest	Nitrit	0,0055	mg/L	<0.50
2026/2736	09.04.2026 12:36:56	C2 - Brest	o-ksilen	<0.3	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Oksitetraciklin	<0.020	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Okus	brez posebnosti	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2736	09.04.2026 12:36:56	C2 - Brest	Paracetamol	<0.010	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Pendimetalin	<0.001	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	penicilin G	<0.021	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Pentaklorofenol	<0.06	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluorobutanojska kislina (PFBA)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluorobutansulfonska kislina (PFBS)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluorodekanojska kislina (PFDA)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluorodekansulfonska kislina (PFDS)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluorododekanojska kislina (PFDoA)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluorododekansulfonska kislina (PFDoS)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluoroheksanojska kislina (PFHxA)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluoroheksansulfonska kislina (PFHxS)	0,001	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluoroheptanojska kislina (PFHpA)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluoroheptansulfonska kislina (PFHpS)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluorononanojska kislina (PFNA)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluoronansulfonska kislina (PFNS)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluorooktanojska kislina (PFOA)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluorooktansulfonska kislina (PFOS)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluoropentanojska kislina (PFPeA)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluoropentansulfonska kislina (PFPeS)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluorotridekanojska kislina (PFTrDA)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluorotridekansulfonska kislina (PFTrDS)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluoroundekanojska kislina (PFUdA)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Perfluoroundekansulfonska kislina (PFUdS)	<0.0005	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Pesticidi (vsota)	0,054	ug/L	<0.50
2026/2736	09.04.2026 12:36:56	C2 - Brest	Petoksamid	<0.021	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/2736	09.04.2026 12:36:56	C2 - Brest	Pinoksaden	<0.007	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Piridat-M	<0.005	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Pirimikarb	<0.009	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Policiklični aromatski ogljikovodiki (vsota)	<0.005	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Prometrin	<0.010	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Propazin	<0.009	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Propifenazon	<0.009	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Propikonazol	<0.002	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Propranolol	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Prosti klor	<0.04	mg/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Prosulfokarb	<0.006	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Rimsulfuron	<0.05	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Salbutamol	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Salicilna kislina	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Sebutilazin	<0.008	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Selen	<0.1	ug/L	<20
2026/2736	09.04.2026 12:36:56	C2 - Brest	Simazin	<0.009	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Skupna trdota	15	°N	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	S-metolaklor	<0.03	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Sotalol	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Sulfadiazin	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Sulfadoksin	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Sulfamerazin	<0.010	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Sulfametoksazol	<0.006	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Sulfat	4,4	mg/L	<250
2026/2736	09.04.2026 12:36:56	C2 - Brest	Sulfatiazol	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Svinec	0,15	ug/L	<10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2736	09.04.2026 12:36:56	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2736	09.04.2026 12:36:56	C2 - Brest	Tamoksifen	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Tebukonazol	<0.001	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Temperatura vode	12,6	°C	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Teofilin	<0.02	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Terbutalin	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Terbutilazin	<0.015	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Terbutilazin-desetil	<0.004	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Terbutrin	<0.013	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Testosteron	<0.004	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Tetraciklin	<0.020	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Tetrakloroeten (tetrakloroetilen)	<0.5	ug/L	<10

2026/2736	09.04.2026 12:36:56	C2 - Brest	Tetrakloroeten+trikloroeten	<0.5	ug/L	<10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Tetraklorometan	<0.4	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Tiaklopid	<0.007	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Tiametoksam	<0.004	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Toluen	<0.3	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Triasulfuron	<0.010	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Tribenuron-metil	<0.06	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Tribromometan (bromoform)	<0.5	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Tributilfosfat	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Trihalometani (vsota)	1,7	ug/L	<100
2026/2736	09.04.2026 12:36:56	C2 - Brest	Triizobutilfosfat	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Triizopropilfosfat	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Trikloroeten (trikloroetilen)	<0.5	ug/L	<10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Trikloroetilfosfat	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Triklorometan (kloroform)	0,4	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Trikloroocetna kislina	<5.0	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Trikloropropilfosfat	<0.2	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Triklosan	<0.03	ug/L	ni mej
2026/2736	09.04.2026 12:36:56	C2 - Brest	Trimetoprim	<0.006	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Tritosulfuron	<0.004	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Uran	0,43	ug/L	<30
2026/2736	09.04.2026 12:36:56	C2 - Brest	Vinilklorid	<0.05	ug/L	<0.5
2026/2736	09.04.2026 12:36:56	C2 - Brest	Vonj	brez posebnosti	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2736	09.04.2026 12:36:56	C2 - Brest	Vsota 20 PFAS	<0,03	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Zoksamid	<0.01	ug/L	<0.10
2026/2736	09.04.2026 12:36:56	C2 - Brest	Železo	<40.00	ug/L	<200
2026/2736	09.04.2026 12:36:56	C2 - Brest	Živo srebro	<0.01	ug/L	<1.0
2026/2860	13.04.2026 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/2860	13.04.2026 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/2860	13.04.2026 08:40:00	C2 - Brest	Prosti klor	0,03	mg/L	ni mej
2026/2860	13.04.2026 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/2860	13.04.2026 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/2860	13.04.2026 08:40:00	C2 - Brest	Temperatura vode	11,3	°C	ni mej
2026/2874	13.04.2026 08:40:00	C2 - Brest	Absorbanca-barva	0,0001		ni mej
2026/2874	13.04.2026 08:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/2874	13.04.2026 08:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/2874	13.04.2026 08:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,46	mg/L	brez neobičajne spremembe
2026/2874	13.04.2026 08:40:00	C2 - Brest	Električna prevodnost (20°C)	428	uS/cm	<2500
2026/2874	13.04.2026 08:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/2874	13.04.2026 08:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/2874	13.04.2026 08:40:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/2874	13.04.2026 08:40:00	C2 - Brest	Prosti klor	0,03	mg/L	ni mej
2026/2874	13.04.2026 08:40:00	C2 - Brest	Temperatura vode	11,3	°C	ni mej
2026/2874	13.04.2026 08:40:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/2874	13.04.2026 08:40:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3003	16.04.2026 09:00:00	C2 - Brest	Nitrat	8,24	mg/L	<50
2026/3003	16.04.2026 09:00:00	C2 - Brest	Prosti klor	0,02	mg/L	ni mej
2026/3003	16.04.2026 09:00:00	C2 - Brest	Temperatura vode	12,6	°C	ni mej
2026/3003	16.04.2026 09:00:00	C2 - Brest	Tetrakloroeten	<0.5	ug/L	<10
2026/3003	16.04.2026 09:00:00	C2 - Brest	Trikloroeten	<0.5	ug/L	<10
2026/3009	16.04.2026 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3009	16.04.2026 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3009	16.04.2026 09:00:00	C2 - Brest	Prosti klor	0,02	mg/L	ni mej
2026/3009	16.04.2026 09:00:00	C2 - Brest	Število kolonij pri 22°C	14	cfu/mL	brez neobičajne spremembe
2026/3009	16.04.2026 09:00:00	C2 - Brest	Število kolonij pri 36°C	25	cfu/mL	<100
2026/3009	16.04.2026 09:00:00	C2 - Brest	Temperatura vode	12,6	°C	ni mej
2026/3019	16.04.2026 10:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3019	16.04.2026 10:40:00	C2 - Brest	Klor dioksid	0,18	mg/L	ni mej
2026/3019	16.04.2026 10:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3019	16.04.2026 10:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3019	16.04.2026 10:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3019	16.04.2026 10:40:00	C2 - Brest	Temperatura vode	11,1	°C	ni mej
2026/3021	16.04.2026 10:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3021	16.04.2026 10:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3021	16.04.2026 10:50:00	C2 - Brest	Prosti klor	0,12	mg/L	ni mej
2026/3021	16.04.2026 10:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3021	16.04.2026 10:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3021	16.04.2026 10:50:00	C2 - Brest	Temperatura vode	11	°C	ni mej
2026/3070	17.04.2026 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3070	17.04.2026 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3070	17.04.2026 10:00:00	C2 - Brest	Prosti klor	0	mg/L	ni mej

2026/3070	17.04.2026 10:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3070	17.04.2026 10:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3070	17.04.2026 10:00:00	C2 - Brest	Temperatura vode	10,8	°C	ni mej
2026/3137	23.04.2026 08:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3137	23.04.2026 08:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3137	23.04.2026 08:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/3137	23.04.2026 08:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3137	23.04.2026 08:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3137	23.04.2026 08:10:00	C2 - Brest	Temperatura vode	12,2	°C	ni mej
2026/3303	23.04.2026 08:10:00	C2 - Brest	Absorbanca-barva	0		ni mej
2026/3303	23.04.2026 08:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/3303	23.04.2026 08:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3303	23.04.2026 08:10:00	C2 - Brest	Celotni organski ogljik (TOC)	0,38	mg/L	brez neobičajne spremembe
2026/3303	23.04.2026 08:10:00	C2 - Brest	Električna prevodnost (20°C)	451	uS/cm	<2500
2026/3303	23.04.2026 08:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/3303	23.04.2026 08:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/3303	23.04.2026 08:10:00	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/3303	23.04.2026 08:10:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/3303	23.04.2026 08:10:00	C2 - Brest	Temperatura vode	12,2	°C	ni mej
2026/3303	23.04.2026 08:10:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/3303	23.04.2026 08:10:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3136	23.04.2026 08:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3136	23.04.2026 08:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3136	23.04.2026 08:50:00	C2 - Brest	Prosti klor	0,04	mg/L	ni mej
2026/3136	23.04.2026 08:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3136	23.04.2026 08:50:00	C2 - Brest	Število kolonij pri 36°C	63	cfu/mL	<100
2026/3136	23.04.2026 08:50:00	C2 - Brest	Temperatura vode	14,2	°C	ni mej
2026/3155	24.04.2026 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3155	24.04.2026 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3155	24.04.2026 09:10:00	C2 - Brest	Prosti klor	0,02	mg/L	ni mej
2026/3155	24.04.2026 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3155	24.04.2026 09:10:00	C2 - Brest	Število kolonij pri 36°C	11	cfu/mL	<100
2026/3155	24.04.2026 09:10:00	C2 - Brest	Temperatura vode	18,2	°C	ni mej
2026/3150	24.04.2026 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3150	24.04.2026 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3150	24.04.2026 10:00:00	C2 - Brest	Prosti klor	0,03	mg/L	ni mej
2026/3150	24.04.2026 10:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3150	24.04.2026 10:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3150	24.04.2026 10:00:00	C2 - Brest	Temperatura vode	14,2	°C	ni mej
2026/3332	28.04.2026 09:10:00	C2 - Brest	Absorbanca-barva	0		ni mej
2026/3332	28.04.2026 09:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/3332	28.04.2026 09:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3332	28.04.2026 09:10:00	C2 - Brest	Celotni organski ogljik (TOC)	0,46	mg/L	brez neobičajne spremembe
2026/3332	28.04.2026 09:10:00	C2 - Brest	Električna prevodnost (20°C)	425	uS/cm	<2500
2026/3332	28.04.2026 09:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/3332	28.04.2026 09:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/3332	28.04.2026 09:10:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/3332	28.04.2026 09:10:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/3332	28.04.2026 09:10:00	C2 - Brest	Temperatura vode	13,8	°C	ni mej
2026/3332	28.04.2026 09:10:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/3332	28.04.2026 09:10:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3335	28.04.2026 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3335	28.04.2026 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3335	28.04.2026 09:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/3335	28.04.2026 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3335	28.04.2026 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3335	28.04.2026 09:10:00	C2 - Brest	Temperatura vode	13,8	°C	ni mej
2026/3405	30.04.2026 08:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3405	30.04.2026 08:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3405	30.04.2026 08:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/3405	30.04.2026 08:10:00	C2 - Brest	Število kolonij pri 22°C	29	cfu/mL	brez neobičajne spremembe
2026/3405	30.04.2026 08:10:00	C2 - Brest	Število kolonij pri 36°C	39	cfu/mL	<100
2026/3405	30.04.2026 08:10:00	C2 - Brest	Temperatura vode	15,7	°C	ni mej
2026/3421	04.05.2026 10:25:00	C2 - Brest	Absorbanca-barva	0,0001		ni mej
2026/3421	04.05.2026 10:25:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/3421	04.05.2026 10:25:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3421	04.05.2026 10:25:00	C2 - Brest	Celotni organski ogljik (TOC)	0,47	mg/L	brez neobičajne spremembe
2026/3421	04.05.2026 10:25:00	C2 - Brest	Električna prevodnost (20°C)	412	uS/cm	<2500
2026/3421	04.05.2026 10:25:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/3421	04.05.2026 10:25:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50

2026/3421	04.05.2026 10:25:00	C2 - Brest	pH-vrednost	7,5	-	6.5-9.5
2026/3421	04.05.2026 10:25:00	C2 - Brest	Prosti klor	0,14	mg/L	ni mej
2026/3421	04.05.2026 10:25:00	C2 - Brest	Temperatura vode	11,5	°C	ni mej
2026/3421	04.05.2026 10:25:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/3421	04.05.2026 10:25:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3431	04.05.2026 10:25:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3431	04.05.2026 10:25:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3431	04.05.2026 10:25:00	C2 - Brest	Prosti klor	0,14	mg/L	ni mej
2026/3431	04.05.2026 10:25:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3431	04.05.2026 10:25:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3431	04.05.2026 10:25:00	C2 - Brest	Temperatura vode	11,5	°C	ni mej
2026/3422	04.05.2026 10:45:00	C2 - Brest	Absorbanca-barva	0,0002		ni mej
2026/3422	04.05.2026 10:45:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/3422	04.05.2026 10:45:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3422	04.05.2026 10:45:00	C2 - Brest	Celotni organski ogljik (TOC)	0,48	mg/L	brez neobičajne spremembe
2026/3422	04.05.2026 10:45:00	C2 - Brest	Električna prevodnost (20°C)	411	uS/cm	<2500
2026/3422	04.05.2026 10:45:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/3422	04.05.2026 10:45:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/3422	04.05.2026 10:45:00	C2 - Brest	pH-vrednost	7,5	-	6.5-9.5
2026/3422	04.05.2026 10:45:00	C2 - Brest	Prosti klor	0,09	mg/L	ni mej
2026/3422	04.05.2026 10:45:00	C2 - Brest	Temperatura vode	11,5	°C	ni mej
2026/3422	04.05.2026 10:45:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/3422	04.05.2026 10:45:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3432	04.05.2026 10:45:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3432	04.05.2026 10:45:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3432	04.05.2026 10:45:00	C2 - Brest	Prosti klor	0,09	mg/L	ni mej
2026/3432	04.05.2026 10:45:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3432	04.05.2026 10:45:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3432	04.05.2026 10:45:00	C2 - Brest	Temperatura vode	11,5	°C	ni mej
2026/3699	08.05.2026 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3699	08.05.2026 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3699	08.05.2026 09:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/3699	08.05.2026 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3699	08.05.2026 09:10:00	C2 - Brest	Število kolonij pri 36°C	17	cfu/mL	<100
2026/3699	08.05.2026 09:10:00	C2 - Brest	Temperatura vode	16,3	°C	ni mej
2026/3655	13.05.2026 08:45:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3655	13.05.2026 08:45:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3655	13.05.2026 08:45:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/3655	13.05.2026 08:45:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3655	13.05.2026 08:45:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3655	13.05.2026 08:45:00	C2 - Brest	Temperatura vode	13,8	°C	ni mej
2026/3662	14.05.2026 08:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3662	14.05.2026 08:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3662	14.05.2026 08:00:00	C2 - Brest	Prosti klor	0,07	mg/L	ni mej
2026/3662	14.05.2026 08:00:00	C2 - Brest	Število kolonij pri 22°C	39	cfu/mL	brez neobičajne spremembe
2026/3662	14.05.2026 08:00:00	C2 - Brest	Število kolonij pri 36°C	98	cfu/mL	<100
2026/3662	14.05.2026 08:00:00	C2 - Brest	Temperatura vode	13,7	°C	ni mej
2026/3661	14.05.2026 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3661	14.05.2026 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3661	14.05.2026 08:40:00	C2 - Brest	Prosti klor	0,07	mg/L	ni mej
2026/3661	14.05.2026 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3661	14.05.2026 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3661	14.05.2026 08:40:00	C2 - Brest	Temperatura vode	12,8	°C	ni mej
2026/3851	14.05.2026 08:40:00	C2 - Brest	Absorbanca-barva	0,0003		ni mej
2026/3851	14.05.2026 08:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/3851	14.05.2026 08:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3851	14.05.2026 08:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,53	mg/L	brez neobičajne spremembe
2026/3851	14.05.2026 08:40:00	C2 - Brest	Električna prevodnost (20°C)	416	uS/cm	<2500
2026/3851	14.05.2026 08:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/3851	14.05.2026 08:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/3851	14.05.2026 08:40:00	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/3851	14.05.2026 08:40:00	C2 - Brest	Prosti klor	0,07	mg/L	ni mej
2026/3851	14.05.2026 08:40:00	C2 - Brest	Temperatura vode	12,8	°C	ni mej
2026/3851	14.05.2026 08:40:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/3851	14.05.2026 08:40:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3690	15.05.2026 08:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3690	15.05.2026 08:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3690	15.05.2026 08:00:00	C2 - Brest	Prosti klor	0,03	mg/L	ni mej
2026/3690	15.05.2026 08:00:00	C2 - Brest	Število kolonij pri 22°C	11	cfu/mL	brez neobičajne spremembe
2026/3690	15.05.2026 08:00:00	C2 - Brest	Število kolonij pri 36°C	13	cfu/mL	<100

2026/3690	15.05.2026 08:00:00	C2 - Brest	Temperatura vode	13,2	°C	ni mej
2026/3680	15.05.2026 08:45:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3680	15.05.2026 08:45:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3680	15.05.2026 08:45:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/3680	15.05.2026 08:45:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3680	15.05.2026 08:45:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3680	15.05.2026 08:45:00	C2 - Brest	Temperatura vode	17,3	°C	ni mej
2026/3912	18.05.2026 08:40:00	C2 - Brest	Absorbanca-barva	0,0003		ni mej
2026/3912	18.05.2026 08:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/3912	18.05.2026 08:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3912	18.05.2026 08:40:00	C2 - Brest	Celotni organski ogljik (TOC)	0,41	mg/L	brez neobičajne spremembe
2026/3912	18.05.2026 08:40:00	C2 - Brest	Električna prevodnost (20°C)	421	uS/cm	<2500
2026/3912	18.05.2026 08:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/3912	18.05.2026 08:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/3912	18.05.2026 08:40:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/3912	18.05.2026 08:40:00	C2 - Brest	Prosti klor	0,02	mg/L	ni mej
2026/3912	18.05.2026 08:40:00	C2 - Brest	Temperatura vode	12,6	°C	ni mej
2026/3912	18.05.2026 08:40:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/3912	18.05.2026 08:40:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3917	18.05.2026 08:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3917	18.05.2026 08:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3917	18.05.2026 08:40:00	C2 - Brest	Prosti klor	0,02	mg/L	ni mej
2026/3917	18.05.2026 08:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3917	18.05.2026 08:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3917	18.05.2026 08:40:00	C2 - Brest	Temperatura vode	12,6	°C	ni mej
2026/3918	18.05.2026 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3918	18.05.2026 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3918	18.05.2026 09:40:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/3918	18.05.2026 09:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3918	18.05.2026 09:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3918	18.05.2026 09:40:00	C2 - Brest	Temperatura vode	12,3	°C	ni mej
2026/3910	18.05.2026 10:10:00	C2 - Brest	Absorbanca-barva	0,0002		ni mej
2026/3910	18.05.2026 10:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/3910	18.05.2026 10:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3910	18.05.2026 10:10:00	C2 - Brest	Celotni organski ogljik (TOC)	0,41	mg/L	brez neobičajne spremembe
2026/3910	18.05.2026 10:10:00	C2 - Brest	Električna prevodnost (20°C)	414	uS/cm	<2500
2026/3910	18.05.2026 10:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/3910	18.05.2026 10:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/3910	18.05.2026 10:10:00	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/3910	18.05.2026 10:10:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/3910	18.05.2026 10:10:00	C2 - Brest	Temperatura vode	14	°C	ni mej
2026/3910	18.05.2026 10:10:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/3910	18.05.2026 10:10:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/3916	18.05.2026 10:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/3916	18.05.2026 10:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/3916	18.05.2026 10:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/3916	18.05.2026 10:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/3916	18.05.2026 10:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/3916	18.05.2026 10:10:00	C2 - Brest	Temperatura vode	14	°C	ni mej
2026/4001	21.05.2026 07:20:00	C2 - Brest	Nitrat	6,91	mg/L	<50
2026/4001	21.05.2026 07:20:00	C2 - Brest	Prosti klor	0,05	mg/L	ni mej
2026/4001	21.05.2026 07:20:00	C2 - Brest	Temperatura vode	13,4	°C	ni mej
2026/4001	21.05.2026 07:20:00	C2 - Brest	Tetrakloroeten	<0.5	ug/L	<10
2026/4001	21.05.2026 07:20:00	C2 - Brest	Trikloroeten	<0.5	ug/L	<10
2026/4022	21.05.2026 07:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4022	21.05.2026 07:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4022	21.05.2026 07:20:00	C2 - Brest	Prosti klor	0,05	mg/L	ni mej
2026/4022	21.05.2026 07:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4022	21.05.2026 07:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4022	21.05.2026 07:20:00	C2 - Brest	Temperatura vode	13,4	°C	ni mej
2026/4034	21.05.2026 07:20:00	C2 - Brest	Absorbanca-barva	0		ni mej
2026/4034	21.05.2026 07:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/4034	21.05.2026 07:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4034	21.05.2026 07:20:00	C2 - Brest	Celotni organski ogljik (TOC)	0,35	mg/L	brez neobičajne spremembe
2026/4034	21.05.2026 07:20:00	C2 - Brest	Električna prevodnost (20°C)	415	uS/cm	<2500
2026/4034	21.05.2026 07:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/4034	21.05.2026 07:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/4034	21.05.2026 07:20:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/4034	21.05.2026 07:20:00	C2 - Brest	Prosti klor	0,05	mg/L	ni mej
2026/4034	21.05.2026 07:20:00	C2 - Brest	Temperatura vode	13,4	°C	ni mej

2026/4034	21.05.2026 07:20:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/4034	21.05.2026 07:20:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4048	22.05.2026 09:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4048	22.05.2026 09:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4048	22.05.2026 09:30:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4048	22.05.2026 09:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4048	22.05.2026 09:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4048	22.05.2026 09:30:00	C2 - Brest	Temperatura vode	13,6	°C	ni mej
2026/4088	25.05.2026 08:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4088	25.05.2026 08:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4088	25.05.2026 08:20:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4088	25.05.2026 08:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4088	25.05.2026 08:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4088	25.05.2026 08:20:00	C2 - Brest	Temperatura vode	18,9	°C	ni mej
2026/4111	25.05.2026 08:20:00	C2 - Brest	Absorbanca-barva	0,0001		ni mej
2026/4111	25.05.2026 08:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/4111	25.05.2026 08:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4111	25.05.2026 08:20:00	C2 - Brest	Električna prevodnost (20°C)	434	uS/cm	<2500
2026/4111	25.05.2026 08:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/4111	25.05.2026 08:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/4111	25.05.2026 08:20:00	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/4111	25.05.2026 08:20:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/4111	25.05.2026 08:20:00	C2 - Brest	Temperatura vode	18,9	°C	ni mej
2026/4111	25.05.2026 08:20:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/4111	25.05.2026 08:20:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4086	25.05.2026 09:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4086	25.05.2026 09:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4086	25.05.2026 09:40:00	C2 - Brest	Prosti klor	0,18	mg/L	ni mej
2026/4086	25.05.2026 09:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4086	25.05.2026 09:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4086	25.05.2026 09:40:00	C2 - Brest	Temperatura vode	12,5	°C	ni mej
2026/4087	25.05.2026 09:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4087	25.05.2026 09:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4087	25.05.2026 09:50:00	C2 - Brest	Prosti klor	0,1	mg/L	ni mej
2026/4087	25.05.2026 09:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4087	25.05.2026 09:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4087	25.05.2026 09:50:00	C2 - Brest	Temperatura vode	11,6	°C	ni mej
2026/4290	01.06.2026 10:00:00	C2 - Brest	Absorbanca-barva	0,0005		ni mej
2026/4290	01.06.2026 10:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/4290	01.06.2026 10:00:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4290	01.06.2026 10:00:00	C2 - Brest	Električna prevodnost (20°C)	412	uS/cm	<2500
2026/4290	01.06.2026 10:00:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/4290	01.06.2026 10:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/4290	01.06.2026 10:00:00	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/4290	01.06.2026 10:00:00	C2 - Brest	Prosti klor	0,1	mg/L	ni mej
2026/4290	01.06.2026 10:00:00	C2 - Brest	Temperatura vode	10,7	°C	ni mej
2026/4290	01.06.2026 10:00:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/4290	01.06.2026 10:00:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4308	01.06.2026 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4308	01.06.2026 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4308	01.06.2026 10:00:00	C2 - Brest	Prosti klor	0,1	mg/L	ni mej
2026/4308	01.06.2026 10:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4308	01.06.2026 10:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4308	01.06.2026 10:00:00	C2 - Brest	Temperatura vode	10,7	°C	ni mej
2026/4289	01.06.2026 10:20:00	C2 - Brest	Absorbanca-barva	0,0006		ni mej
2026/4289	01.06.2026 10:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/4289	01.06.2026 10:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4289	01.06.2026 10:20:00	C2 - Brest	Električna prevodnost (20°C)	413	uS/cm	<2500
2026/4289	01.06.2026 10:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/4289	01.06.2026 10:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/4289	01.06.2026 10:20:00	C2 - Brest	pH-vrednost	7,4	-	6.5-9.5
2026/4289	01.06.2026 10:20:00	C2 - Brest	Prosti klor	0,14	mg/L	ni mej
2026/4289	01.06.2026 10:20:00	C2 - Brest	Temperatura vode	11,6	°C	ni mej
2026/4289	01.06.2026 10:20:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/4289	01.06.2026 10:20:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4307	01.06.2026 10:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4307	01.06.2026 10:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4307	01.06.2026 10:20:00	C2 - Brest	Prosti klor	0,14	mg/L	ni mej
2026/4307	01.06.2026 10:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe

2026/4307	01.06.2026 10:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4307	01.06.2026 10:20:00	C2 - Brest	Temperatura vode	11,6	°C	ni mej
2026/4394	03.06.2026 08:45:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4394	03.06.2026 08:45:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4394	03.06.2026 08:45:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4394	03.06.2026 08:45:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4394	03.06.2026 08:45:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4394	03.06.2026 08:45:00	C2 - Brest	Temperatura vode	14,5	°C	ni mej
2026/4400	03.06.2026 08:45:00	C2 - Brest	Absorbanca-barva	0,0005		ni mej
2026/4400	03.06.2026 08:45:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/4400	03.06.2026 08:45:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4400	03.06.2026 08:45:00	C2 - Brest	Električna prevodnost (20°C)	416	uS/cm	<2500
2026/4400	03.06.2026 08:45:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/4400	03.06.2026 08:45:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/4400	03.06.2026 08:45:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/4400	03.06.2026 08:45:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/4400	03.06.2026 08:45:00	C2 - Brest	Temperatura vode	14,5	°C	ni mej
2026/4400	03.06.2026 08:45:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/4400	03.06.2026 08:45:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4448	04.06.2026 07:40:00	C2 - Brest	Absorbanca-barva	0,0002		ni mej
2026/4448	04.06.2026 07:40:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/4448	04.06.2026 07:40:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4448	04.06.2026 07:40:00	C2 - Brest	Električna prevodnost (20°C)	434	uS/cm	<2500
2026/4448	04.06.2026 07:40:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/4448	04.06.2026 07:40:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/4448	04.06.2026 07:40:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/4448	04.06.2026 07:40:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/4448	04.06.2026 07:40:00	C2 - Brest	Temperatura vode	20,1	°C	ni mej
2026/4448	04.06.2026 07:40:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/4448	04.06.2026 07:40:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4452	04.06.2026 07:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4452	04.06.2026 07:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4452	04.06.2026 07:40:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4452	04.06.2026 07:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4452	04.06.2026 07:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4452	04.06.2026 07:40:00	C2 - Brest	Temperatura vode	20,1	°C	ni mej
2026/4484	05.06.2026 10:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4484	05.06.2026 10:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4484	05.06.2026 10:00:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4484	05.06.2026 10:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4484	05.06.2026 10:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4484	05.06.2026 10:00:00	C2 - Brest	Temperatura vode	17	°C	ni mej
2026/4595	10.06.2026 07:10:00	C2 - Brest	Absorbanca-barva	0,0002		ni mej
2026/4595	10.06.2026 07:10:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/4595	10.06.2026 07:10:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4595	10.06.2026 07:10:00	C2 - Brest	Električna prevodnost (20°C)	412	uS/cm	<2500
2026/4595	10.06.2026 07:10:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/4595	10.06.2026 07:10:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/4595	10.06.2026 07:10:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/4595	10.06.2026 07:10:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/4595	10.06.2026 07:10:00	C2 - Brest	Temperatura vode	19,6	°C	ni mej
2026/4595	10.06.2026 07:10:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/4595	10.06.2026 07:10:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4607	10.06.2026 07:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4607	10.06.2026 07:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4607	10.06.2026 07:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4607	10.06.2026 07:10:00	C2 - Brest	Število kolonij pri 22°C	21	cfu/mL	brez neobičajne spremembe
2026/4607	10.06.2026 07:10:00	C2 - Brest	Število kolonij pri 36°C	51	cfu/mL	<100
2026/4607	10.06.2026 07:10:00	C2 - Brest	Temperatura vode	19,6	°C	ni mej
2026/4602	10.06.2026 09:00:00	C2 - Brest	Absorbanca-barva	0,0007		ni mej
2026/4602	10.06.2026 09:00:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/4602	10.06.2026 09:00:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4602	10.06.2026 09:00:00	C2 - Brest	Električna prevodnost (20°C)	412	uS/cm	<2500
2026/4602	10.06.2026 09:00:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/4602	10.06.2026 09:00:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/4602	10.06.2026 09:00:00	C2 - Brest	pH-vrednost	7,6	-	6.5-9.5
2026/4602	10.06.2026 09:00:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/4602	10.06.2026 09:00:00	C2 - Brest	Temperatura vode	16	°C	ni mej
2026/4602	10.06.2026 09:00:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej

2026/4602	10.06.2026 09:00:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4613	10.06.2026 09:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4613	10.06.2026 09:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4613	10.06.2026 09:00:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4613	10.06.2026 09:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4613	10.06.2026 09:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4613	10.06.2026 09:00:00	C2 - Brest	Temperatura vode	16	°C	ni mej
2026/4614	10.06.2026 09:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4614	10.06.2026 09:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4614	10.06.2026 09:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4614	10.06.2026 09:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4614	10.06.2026 09:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4614	10.06.2026 09:10:00	C2 - Brest	Temperatura vode	18,8	°C	ni mej
2026/4683	12.06.2026 07:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4683	12.06.2026 07:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4683	12.06.2026 07:50:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4683	12.06.2026 07:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4683	12.06.2026 07:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4683	12.06.2026 07:50:00	C2 - Brest	Temperatura vode	18,2	°C	ni mej
2026/4684	12.06.2026 08:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4684	12.06.2026 08:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4684	12.06.2026 08:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4684	12.06.2026 08:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4684	12.06.2026 08:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4684	12.06.2026 08:10:00	C2 - Brest	Temperatura vode	17,4	°C	ni mej
2026/4685	12.06.2026 08:30:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4685	12.06.2026 08:30:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4685	12.06.2026 08:30:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4685	12.06.2026 08:30:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4685	12.06.2026 08:30:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4685	12.06.2026 08:30:00	C2 - Brest	Temperatura vode	14,5	°C	ni mej
2026/4696	15.06.2026 08:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4696	15.06.2026 08:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4696	15.06.2026 08:00:00	C2 - Brest	Prosti klor	0,02	mg/L	ni mej
2026/4696	15.06.2026 08:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4696	15.06.2026 08:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4696	15.06.2026 08:00:00	C2 - Brest	Temperatura vode	14,4	°C	ni mej
2026/4697	15.06.2026 08:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4697	15.06.2026 08:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4697	15.06.2026 08:20:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4697	15.06.2026 08:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4697	15.06.2026 08:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4697	15.06.2026 08:20:00	C2 - Brest	Temperatura vode	14,6	°C	ni mej
2026/4799	15.06.2026 08:20:00	C2 - Brest	Absorbanca-barva	0,0001		ni mej
2026/4799	15.06.2026 08:20:00	C2 - Brest	Amonij NH4+	<LOQ=0.025	mg/L	<0.50
2026/4799	15.06.2026 08:20:00	C2 - Brest	Barva (436 nm)	<LOQ=0.02	m-1	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4799	15.06.2026 08:20:00	C2 - Brest	Električna prevodnost (20°C)	413	uS/cm	<2500
2026/4799	15.06.2026 08:20:00	C2 - Brest	Motnost	<LOQ=0.10	NTU	ni mej
2026/4799	15.06.2026 08:20:00	C2 - Brest	Nitrit NO2-	<LOQ=0.003	mg/L	<0.50
2026/4799	15.06.2026 08:20:00	C2 - Brest	pH-vrednost	7,7	-	6.5-9.5
2026/4799	15.06.2026 08:20:00	C2 - Brest	Prosti klor	<LOQ=0.02	mg/L	ni mej
2026/4799	15.06.2026 08:20:00	C2 - Brest	Temperatura vode	14,6	°C	ni mej
2026/4799	15.06.2026 08:20:00	C2 - Brest	Vidne nečistoče	brez	-	ni mej
2026/4799	15.06.2026 08:20:00	C2 - Brest	Vonj	brez	-	sprejemljiva za uporabnike in brez neobičajne spremembe
2026/4739	17.06.2026 10:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4739	17.06.2026 10:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4739	17.06.2026 10:20:00	C2 - Brest	Prosti klor	0,07	mg/L	ni mej
2026/4739	17.06.2026 10:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4739	17.06.2026 10:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4739	17.06.2026 10:20:00	C2 - Brest	Temperatura vode	13,3	°C	ni mej
2026/4737	17.06.2026 10:40:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4737	17.06.2026 10:40:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4737	17.06.2026 10:40:00	C2 - Brest	Prosti klor	0,11	mg/L	ni mej
2026/4737	17.06.2026 10:40:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4737	17.06.2026 10:40:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4737	17.06.2026 10:40:00	C2 - Brest	Temperatura vode	10,9	°C	ni mej
2026/4736	17.06.2026 11:00:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4736	17.06.2026 11:00:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4736	17.06.2026 11:00:00	C2 - Brest	Prosti klor	0,18	mg/L	ni mej
2026/4736	17.06.2026 11:00:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4736	17.06.2026 11:00:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100

2026/4736	17.06.2026 11:00:00	C2 - Brest	Temperatura vode	11,2	°C	ni mej
2026/4781	19.06.2026 07:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4781	19.06.2026 07:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4781	19.06.2026 07:20:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4781	19.06.2026 07:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4781	19.06.2026 07:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4781	19.06.2026 07:20:00	C2 - Brest	Temperatura vode	16,5	°C	ni mej
2026/4938	22.06.2026 09:20:00	C2 - Brest	Nitrat	5,8	mg/L	<50
2026/4938	22.06.2026 09:20:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4938	22.06.2026 09:20:00	C2 - Brest	Temperatura vode	16	°C	ni mej
2026/4938	22.06.2026 09:20:00	C2 - Brest	Tetrakloroeten	<0.5	ug/L	<10
2026/4938	22.06.2026 09:20:00	C2 - Brest	Trikloroeten	<0.5	ug/L	<10
2026/4947	22.06.2026 09:20:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/4947	22.06.2026 09:20:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/4947	22.06.2026 09:20:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/4947	22.06.2026 09:20:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/4947	22.06.2026 09:20:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/4947	22.06.2026 09:20:00	C2 - Brest	Temperatura vode	16	°C	ni mej
2026/5052	29.06.2026 07:50:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/5052	29.06.2026 07:50:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/5052	29.06.2026 07:50:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/5052	29.06.2026 07:50:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/5052	29.06.2026 07:50:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/5052	29.06.2026 07:50:00	C2 - Brest	Temperatura vode	19	°C	ni mej
2026/5053	29.06.2026 08:10:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/5053	29.06.2026 08:10:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/5053	29.06.2026 08:10:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/5053	29.06.2026 08:10:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/5053	29.06.2026 08:10:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/5053	29.06.2026 08:10:00	C2 - Brest	Temperatura vode	18,5	°C	ni mej
2026/5091	30.06.2026 08:35:00	C2 - Brest	Escherichia coli 36°C	0	cfu/100mL	0
2026/5091	30.06.2026 08:35:00	C2 - Brest	Koliformne bakterije 36°C	0	cfu/100mL	0
2026/5091	30.06.2026 08:35:00	C2 - Brest	Prosti klor	0	mg/L	ni mej
2026/5091	30.06.2026 08:35:00	C2 - Brest	Število kolonij pri 22°C	<10	cfu/mL	brez neobičajne spremembe
2026/5091	30.06.2026 08:35:00	C2 - Brest	Število kolonij pri 36°C	<10	cfu/mL	<100
2026/5091	30.06.2026 08:35:00	C2 - Brest	Temperatura vode	19,2	°C	ni mej